

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: Date Evaluated: 10/1/09
 Proposed Facility: 3 BEOROOMS Design Flow (.1949): 360 gpd
 Location of Site: Property Recorded:

Property Size:

Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS	0-19"	G SL	VFL NS/HP					PS.4
	7-10"	19-44"	SBK SCL	FL SS/SP					
2		0-19"	G SL	VFL NS/HP					U3
		19-44"	PM						
3		0-12"	G SL	VFL NS/HP					
		12-32"	SBK SCL	FL SS/SP					PS.35
		32-44"	PM						
4		0-12"	G S	VFL NS/HP					
		12-40"	SBK SCL	FL SS/SP					PS.4
		40-44"	PM						
5		0-20"	G S	VFL NS/HP					
		20-40"	SBK SCL	FL SS/SP					PS.35
		40-44"	PM						

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OT Others Present: —
Available Space (.1945)	✓	✓	
System Type(s)	PUMP MINDY	PUMP MINDY	
Site LTAR	.35	.35	

4 x 65 @ 18"
 = REPAIR

