Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 9/2/09
Proposed Facility: 3 BEDROOM HOME Design Flow (.1949): 360 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-24	G LS	VRF NS/NP					PS .5
		24-40"	SBK SCL	FR SS/SP					
		40"+	PM						
2		0-25"	G LS	VFR NS/NP					PS .45
		25-40"	SBK SCL	FR SS/SP					

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	PUMP ELEV	PUMP CONV
Site LTAR	.45	.45

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: DT
Others Present: —

5x55' @ 18"-28"