

ADDRESS : 100 SUNRIDGE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : LDS HOMES
PARCEL : 09-9566-01- -0001- -67-
APPL NUMBER: 09-50022804 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/10/2009 09:11 AM JBROCK ----
MIRE BRANCH #65
27 W FROM LILLINGTON TURN RIGHT INTO
S/D TURN RIGHT ON LAKERIDGE DR LOT WILL
BE MARKED ON RIGHT

SUBDIV: MIRE BRANCH SECT 7
PHONE : (910) 892-4345
PHONE : (910) 892-2120

STRUCTURE: 000 000 49X51 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/09 <i>10-12-9</i>	<i>TR</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001834779

COMMENTS AND NOTES

IS

/

ADDRESS : 100 SUNRIDGE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : LDS HOMES
PARCEL : 09-9566-01- -0001- -67-
APPL NUMBER: 09-50022804 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/10/2009 09:11 AM JBROCK ----
MIRE BRANCH #65
27 W FROM LILLINGTON TURN RIGHT INTO
S/D TURN RIGHT ON LAKERIDGE DR LOT WILL
BE MARKED ON RIGHT

SUBDIV: MIRE BRANCH SECT 7
PHONE : (910) 892-4345
PHONE : (910) 892-2120

STRUCTURE: 000 000 49X51 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/09	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001834779
	10/12/09	AP	T/S: 10/12/2009 02:12 PM FSPIVEY -----
A814 01	10/26/09	TI	ADDRESS CONFIRMATION VRU #: 001841568
B103 01	<u>10/26/09</u> <i>10/26/09</i>	TI <i>AP</i>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001841550

FS

COMMENTS AND NOTES

ADDRESS : 100 SUNRIDGE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : LDS HOMES
PARCEL : 09-9566-01- -0001- -67-
APPL NUMBER: 09-50022804 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/10/2009 09:11 AM JBROCK ----
MIRE BRANCH #65
27 W FROM LILLINGTON TURN RIGHT INTO
S/D TURN RIGHT ON LAKERIDGE DR LOT WILL
BE MARKED ON RIGHT

SUBDIV: MIRE BRANCH SECT 7
PHONE : (910) 892-4345
PHONE : (910) 892-2120

STRUCTURE: 000 000 49X51 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/09	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001834779
	10/12/09	AP	T/S: 10/12/2009 02:12 PM FSPIVEY -----
B103 01	10/26/09	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001841550
	10/26/09	AP	T/S: 10/26/2009 01:53 PM FSPIVEY -----
A814 01	10/26/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001841568
	11/04/09	AP	100 sunridge dr lot 65 ----- cameron 28326
			T/S: 11/04/2009 04:10 PM TWARD -----
B105 01	11/16/09	TI	R*OPEN FLOOR VRU #: 001850125

Handwritten signature and date:
11-16-09 AP

COMMENTS AND NOTES

Large handwritten signature:
FS

ADDRESS : 100 SUNRIDGE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : LDS HOMES
PARCEL : 09-9566-01- -0001- -67-
APPL NUMBER: 09-50022804 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/10/2009 09:11 AM JBROCK ----
MIRE BRANCH #65
27 W FROM LILLINGTON TURN RIGHT INTO
S/D TURN RIGHT ON LAKERIDGE DR LOT WILL
BE MARKED ON RIGHT

SUBDIV: MIRE BRANCH SECT 7
PHONE : (910) 892-4345
PHONE : (910) 892-2120

STRUCTURE: 000 000 49X51 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/09	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001834779
	10/12/09	AP	T/S: 10/12/2009 02:12 PM FSPIVEY -----
B103 01	10/26/09	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001841550
	10/26/09	AP	T/S: 10/26/2009 01:53 PM FSPIVEY -----
A814 01	10/26/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001841568
	11/04/09	AP	100 sunridge dr lot 65 ----- cameron 28326 T/S: 11/04/2009 04:10 PM TWARD -----
B105 01	11/16/09	FS	R*OPEN FLOOR VRU #: 001850125
	11/16/09	AP	T/S: 11/16/2009 02:13 PM FSPIVEY -----
R425 01	12/08/09	TL	FOUR TRADE ROUGH IN VRU #: 001858778

Handwritten initials and dates:
12-8-9 [Signature]

COMMENTS AND NOTES

Large handwritten signature: [Signature]

ADDRESS : 100 SUNRIDGE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : LDS HOMES
PARCEL : 09-9566-01- -0001- -67-
APPL NUMBER: 09-50022804 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/10/2009 09:11 AM JBROCK ----
MIRE BRANCH #65
27 W FROM LILLINGTON TURN RIGHT INTO
S/D TURN RIGHT ON LAKERIDGE DR LOT WILL
BE MARKED ON RIGHT

SUBDIV: MIRE BRANCH SECT 7
PHONE : (910) 892-4345
PHONE : (910) 892-2120

STRUCTURE: 000 000 49X51 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/09	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001834779
	10/12/09	AP	T/S: 10/12/2009 02:12 PM FSPIVEY -----
B103 01	10/26/09	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001841550
	10/26/09	AP	T/S: 10/26/2009 01:53 PM FSPIVEY -----
A814 01	10/26/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001841568
	11/04/09	AP	100 sunridge dr lot 65 ----- cameron 28326 T/S: 11/04/2009 04:10 PM TWARD -----
B105 01	11/16/09	FS	R*OPEN FLOOR VRU #: 001850125
	11/16/09	AP	T/S: 11/16/2009 02:13 PM FSPIVEY -----
R425 01	12/08/09	FS	FOUR TRADE ROUGH IN VRU #: 001858778
	12/08/09	AP	T/S: 12/08/2009 02:34 PM FSPIVEY -----
I129 01	12/10/09	TI	R*INSULATION INSPECTION VRU #: 001859925

12-10-09
AP
FS

COMMENTS AND NOTES

ADDRESS : 100 SUNRIDGE DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : LDS HOMES
PARCEL : 09-9566-01- -0001- -67-
APPL NUMBER: 09-50022804 CP NEW RESIDENTIAL (SFD)
DIRECTIONS: T/S: 09/10/2009 09:11 AM JBROCK ----
MIRE BRANCH #65
27 W FROM LILLINGTON TURN RIGHT INTO
S/D TURN RIGHT ON LAKERIDGE DR LOT WILL
BE MARKED ON RIGHT

SUBDIV: MIRE BRANCH SECT 7
PHONE : (910) 892-4345
PHONE : (910) 892-2120

STRUCTURE: 000 000 49X51 3BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/09	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001834779
	10/12/09	AP	T/S: 10/12/2009 02:12 PM FSPIVEY -----
B103 01	10/26/09	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001841550
	10/26/09	AP	T/S: 10/26/2009 01:53 PM FSPIVEY -----
A814 01	10/26/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001841568
	11/04/09	AP	√100 sunridge dr lot 65 ----- cameron 28326
			T/S: 11/04/2009 04:10 PM TWARD -----
B105 01	11/16/09	FS	R*OPEN FLOOR VRU #: 001850125
	11/16/09	AP	T/S: 11/16/2009 02:13 PM FSPIVEY -----
R425 01	12/08/09	FS	FOUR TRADE ROUGH IN VRU #: 001858778
	12/08/09	AP	T/S: 12/08/2009 02:34 PM FSPIVEY -----
I129 01	12/10/09	FS	R*INSULATION INSPECTION VRU #: 001859925
	12/10/09	AP	T/S: 12/10/2009 03:07 PM FSPIVEY -----
H824 01	4/05/10	OT	√ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001905645
	4/05/10	AP	T/S: 04/06/2010 11:02 AM SSTEWARD -----
			T/S: 04/06/2010 11:02 AM SSTEWARD -----
R429 01	4/09/10	TI	FOUR TRADE FINAL VRU #: 001907299

4-9 DA

weep holes? positive
microwave recep
grand block.

COMMENTS AND NOTES

ADDRESS : 100 SUNRIDGE DR SUBDIV: MIRE BRANCH SECT 7
 CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
 OWNER : LDS HOMES PHONE : (910) 892-2120
 PARCEL : 09-9566-01- -0001- -67-
 APPL NUMBER: 09-50022804 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/10/2009 09:11 AM JBROCK ----
 MIRE BRANCH #65
 27 W FROM LILLINGTON TURN RIGHT INTO
 S/D TURN RIGHT ON LAKERIDGE DR LOT WILL
 BE MARKED ON RIGHT

STRUCTURE: 000 000 49X51 3BDR SLAB W/ GARAGE & PATIO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/12/09	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001834779
	10/12/09	AP	T/S: 10/12/2009 02:12 PM FSPIVEY -----
B103 01	10/26/09	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001841550
	10/26/09	AP	T/S: 10/26/2009 01:53 PM FSPIVEY -----
A814 01	10/26/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001841568
	11/04/09	AP	✓ 100 sunridge dr lot 65 ----- cameron 28326 T/S: 11/04/2009 04:10 PM TWARD -----
B105 01	11/16/09	FS	R*OPEN FLOOR VRU #: 001850125
	11/16/09	AP	T/S: 11/16/2009 02:13 PM FSPIVEY -----
R425 01	12/08/09	FS	FOUR TRADE ROUGH IN VRU #: 001858778
	12/08/09	AP	T/S: 12/08/2009 02:34 PM FSPIVEY -----
I129 01	12/10/09	FS	R*INSULATION INSPECTION VRU #: 001859925
	12/10/09	AP	✓ T/S: 12/10/2009 03:07 PM FSPIVEY -----
H824 01	4/05/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001905645
	4/05/10	AP	T/S: 04/06/2010 11:02 AM SSTEWARD ----- T/S: 04/06/2010 11:02 AM SSTEWARD -----
R429 01	4/09/10	NS	FOUR TRADE FINAL VRU #: 001907299
	4/09/10	DA	1. Need weep holes in brick veneer garage door 2. Need positive drainage away from home at rear of house 3. Need 20 amp receptacle for microwave. 4. Need terminal no ground for phone, cable, etc T/S: 04/09/2010 11:12 AM KSLATTUM ----- eer
R429 02	4/13/10	TI	FOUR TRADE FINAL VRU #: 001908862
	4/13/10	AE DR	

COMMENTS AND NOTES

