

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address: Date Evaluated: 9/7/09

Proposed Facility: 3 bedroom Design Flow (.1949): 360 gpd

Property Size:

Location of Site: Property Recorded:

Water Supply: Public Individual Well Spring Other


Evaluation Method: Auger Boring Pit Cut

Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-14	G S	VFR NS/NP					
		14-36"	SBK SCL	FR SS/NP	2.578/2@34"				PS .5
2		0-24	G SL	VFR NS/NP					
		24-32"	SBK SCL	FR SS/NP	2.578/2@27"				US/PS .5
3		0-12	G SL	VFR NS/NP					US
		12"	PM						
4		0-14	G SL	VFR NS/NP					US
		14-21"	SBK SCL	FR SS/NP	2.578/1 @ 21"				
5		0-12"	G S	VFR NS/NP					
		12-38"	SBK SCL	FR SS/NP	2.58/1 @ 36"				PS .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OI Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	INDIVIDUAL	ULTRASHALLOW TANK w/ PUMP	
Site LTAR	.5	.5	

4x50' @ 18"



SITE PLAN APPROVAL

DISTRICT RA20R USE SFD

#BEDROOMS 3

Date 9/10/09 [Signature]
 Zoning Administrator

SUNRIDGE DRIVE

**LDS HOMES
 THE RG13-D84BF
 LOT # 65 MIRE BRANCH
 SCALE: 1"=40'**