



North Carolina State Laboratory Public Health  
Environmental Sciences  
**Microbiology**  
Certificate of Analysis

P.O. Box 28047  
306 N. Wilmington St.  
Raleigh, NC 27611-8047  
<http://slph.ncpublichealth.com>  
Phone: 919-733-7834  
Fax: 919-733-8695

**Report To:**

**HARNETT CO ENVIRONMENTAL HEALTH**

**307 CORNELIUS HARNETT BLVD  
LILLINGTON, NC 27546  
EIN:566000306EH**

**Name of System:**

**BRADLEY SHEFFER**

**387 ROBERTS RD.  
SANFORD, NC 27332**

StarLIMS Sample ID: **ES102810-0106001**



Collected: 10/27/2010 13:24

Received: 10/28/2010 09:18

**Bryan McSwain**

**Angela Heybroek**

ES Microbiology ID: **21998**

GPS Number:

Sample Source: **New Well**

Sampling Point: **Spigot @ house**

Well Permit Number:

**09-5-22835**

Sample Description:

Comment:

**Environmental Microbiology - Colilert Profile**

**Method: SM 9223B**

**Test Name: Colilert**

Analyte	Test Result	Analyst	Date
Total Coliform, Colilert	Absent	Valerie Yager	10/29/2010
<i>E. coli</i> , Colilert	Absent	Valerie Yager	10/29/2010

**Report Date:** 10/29/2010

**Reported By:** Joy Hayes

**Explanations of Coliform Analysis:**

If coliform bacteria are **Absent**, the water is considered safe for drinking purpose. If coliform bacteria are **Present**, the water is considered unsafe for drinking purpose. Presence of *E. coli* (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.