

HTE# 09-5-22560

Harnett County Department of Public Health

25636

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Caviness Land Development PROPERTY LOCATION: Nursery Rd.
 NEW REPAIR EXPANSION SUBDIVISION: Forest Oak Ph 4 LOT # 185
 Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance: _____
 Proposed Wastewater System Type: 25% Reduction
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: _____ No expiration

Authorized State Agent: Bryan McWain, REHS Date: 10/16/2009 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Caviness Land Development PROPERTY LOCATION: Nursery Rd.
 SUBDIVISION: Forest Oak Ph 4 LOT # 185
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** 25% Reduction (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable 25% Reduction (Repair))

Installation Requirements/Conditions

Septic Tank Size 1000 gallons Number of trenches 1
 Pump Tank Size _____ gallons Exact length of each trench 240 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: 6-12 inches
 Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM _____ inches below pipe
 _____ inches above pipe
 _____ inches total

Conditions: A French drain is to be installed in front of the house
to run down the property lines. Drain lines to be run on contour + NO DEEPER than 18" deep
No utilities allowed in system or repair areas. Water line must be min 10ft from system

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____
 This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Bryan McWain, REHS Date: 10/16/2009
 Construction Authorization Expiration Date: 10/16/2014

HTE# 09-5-22860

Permit # 25636

Harnett County Department of Public Health Site Sketch

ISSUED TO: Carriger's Land Development PROPERTY LOCATOR: Nursery Rd.
SUBDIVISION: Forest Oaks Ph 4 LOT # 185

Authorized State Agent: Bryan McSwain, CEHS Date: 10/16/2009

* Contractor to meet on site
prior to installing system

* French Drain to be
Run in front of house
+ down Property line 167'

