
ADDRESS . . : 24 EMMA CT
CONTRACTOR : RBC HOMES INC
OWNER . . . : ABJ INVESTMENTS LLC
PARCEL . . . : 12-0555- - -0216- -37-
APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
KENLAN FARMS #37
US HWY 401 S TO RIGHT ON MCNEILL HOBBS
RD TO LEFT ON WIRE RD PASS JOSEY
WILLIAMS ON THE LEFT AND TURN RIGHT ON
KENLAN RD

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
PHONE : (910) 423-3555
PHONE :

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09 <u>11.6.9</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210

----- COMMENTS AND NOTES -----

ADDRESS . . : 24 EMMA CT
CONTRACTOR : RBC HOMES INC
OWNER . . . : ABJ INVESTMENTS LLC
PARCEL . . . : 12-0555- - -0216- -37-
APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
KENLAN FARMS #37
US HWY 401 S TO RIGHT ON MCNEILL HOBBS
RD TO LEFT ON WIRE RD PASS JOSEY
WILLIAMS ON THE LEFT AND TURN RIGHT ON
KENLAN RD
T/S: 11/17/2009 01:32 PM DJOHNSON --
*****PREMISE # 55390924*****

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
PHONE : (910) 423-3555
PHONE :

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09 11/06/09	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210 T/S: 11/06/2009 12:45 PM MREARIC -----
B103 01	11/18/09 <u>11-18-09</u>	TI <u>APTH</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001851856
A814 01	11/18/09	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001851914 T/S: 11/17/2009 01:28 PM DJOHNSON ----- T/S: 11/17/2009 01:29 PM DJOHNSON -----

----- COMMENTS AND NOTES -----

ADDRESS : 24 EMMA CT
 CONTRACTOR : RBC HOMES INC
 OWNER : ABJ INVESTMENTS LLC
 PARCEL : 12-0555- - -0216- -37-
 APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
 KENLAN FARMS #37
 US HWY 401 S TO RIGHT ON MCNEILL HOBBS
 RD TO LEFT ON WIRE RD PASS JOSEY
 WILLIAMS ON THE LEFT AND TURN RIGHT ON
 KENLAN RD
 T/S: 11/17/2009 01:32 PM DJOHNSON --
 *****PREMISE # 55390924*****

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
 PHONE : (910) 423-3555
 PHONE :

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210
	11/06/09	AP	T/S: 11/06/2009 12:45 PM MREARIC -----
B103 01	11/18/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001851856
	11/18/09	AP	-----
A814 01	11/18/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001851914
	11/18/09	AP	24 EMMA CT LINDEN 28356 -----
			T/S: 11/18/2009 02:05 PM TWARD -----
B105 01	11/25/09	TI	R*OPEN FLOOR VRU #: 001854835
	<u>11/25/09</u>	<u>AP DT</u>	

COMMENTS AND NOTES

ADDRESS : 24 EMMA CT
CONTRACTOR : RBC HOMES INC
OWNER : ABJ INVESTMENTS LLC
PARCEL : 12-0555- - -0216- -37-
APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
KENLAN FARMS #37
US HWY 401 S TO RIGHT ON MCNEILL HOBBS
RD TO LEFT ON WIRE RD PASS JOSEY
WILLIAMS ON THE LEFT AND TURN RIGHT ON
KENLAN RD
T/S: 11/17/2009 01:32 PM DJOHNSON --
*****PREMISE # 55390924*****

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
PHONE : (910) 423-3555
PHONE :

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210
	11/06/09	AP	T/S: 11/06/2009 12:45 PM MREARIC -----
B103 01	11/18/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001851856
	11/18/09	AP	-----
A814 01	11/18/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001851914
	11/18/09	AP	24 EMMA CT ----- LINDEN 28356 ----- -----
			T/S: 11/18/2009 02:05 PM TWARD -----
B105 01	11/25/09	DT	R*OPEN FLOOR VRU #: 001854835
	11/25/09	AP	
R425 01	1/07/10	TI	FOUR TRADE ROUGH IN VRU #: 001867928
	1/06/10	CA	
R425 02	1/08/10	JH	FOUR TRADE ROUGH IN VRU #: 001868512
	1/08/10	CA	T/S: 01/08/2010 10:54 AM JBROCK -----
R425 03	1/11/10	TI	FOUR TRADE ROUGH IN VRU #: 001869023

1/11/10 DA DT

COMMENTS AND NOTES

ADDRESS : 24 EMMA CT
 CONTRACTOR : RBC HOMES INC
 OWNER : ABJ INVESTMENTS LLC
 PARCEL : 12-0555- - -0216- -37-
 APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
 KENLAN FARMS #37
 US HWY 401 S TO RIGHT ON MCNEILL HOBBS
 RD TO LEFT ON WIRE RD PASS JOSEY
 WILLIAMS ON THE LEFT AND TURN RIGHT ON
 KENLAN RD
 T/S: 11/17/2009 01:32 PM DJOHNSON --
 *****PREMISE # 55390924*****

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
 PHONE : (910) 423-3555
 PHONE :

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210
	11/06/09	AP	T/S: 11/06/2009 12:45 PM MREARIC -----
B103 01	11/18/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001851856
	11/18/09	AP	-----
A814 01	11/18/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001851914
	11/18/09	AP	24 EMMA CT ----- LINDEN 28356 -----
			T/S: 11/18/2009 02:05 PM TWARD -----
B105 01	11/25/09	DT	R*OPEN FLOOR VRU #: 001854835
	11/25/09	AP	-----
R425 01	1/07/10	TI	FOUR TRADE ROUGH IN VRU #: 001867928
	1/06/10	CA	-----
R425 02	1/08/10	JH	FOUR TRADE ROUGH IN VRU #: 001868512
	1/08/10	CA	T/S: 01/08/2010 10:54 AM JBROCK -----
R425 03	1/11/10	DT	FOUR TRADE ROUGH IN VRU #: 001869023
	1/11/10	DA	1. No test on pex. 2. B1 trusses not strapped at joint 9 3. Branch drain must extend beyond foundation wall 4. Ladder frame gables. T/S: 01/11/2010 02:11 PM DETAYLOR -----
I129 01	1/13/10	DT	R*INSULATION INSPECTION VRU #: 001869668
	1/13/10	DA	Rough in not approved. T/S: 01/13/2010 11:40 AM DETAYLOR -----
R425 04	1/13/10	DT	FOUR TRADE ROUGH IN VRU #: 001869643
	1/13/10	DP	1. Still do not have 100 psi on water lines. T/S: 01/13/2010 11:40 AM DETAYLOR -----
R425 05	1/15/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001870971
	<u>1-15-10</u>	<u>APJ</u>	T/S: 01/14/2010 09:34 AM DJOHNSON -----

----- COMMENTS AND NOTES -----

ADDRESS : 24 EMMA CT
 CONTRACTOR : RBC HOMES INC
 OWNER : ABJ INVESTMENTS LLC
 PARCEL : 12-0555- - -0216- -37-
 APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
 KENLAN FARMS #37
 US HWY 401 S TO RIGHT ON MCNEILL HOBBS
 RD TO LEFT ON WIRE RD PASS JOSEY
 WILLIAMS ON THE LEFT AND TURN RIGHT ON
 KENLAN RD
 T/S: 11/17/2009 01:32 PM DJOHNSON --
 *****PREMISE # 55390924*****

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
 PHONE : (910) 423-3555
 PHONE :

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210
	11/06/09	AP	T/S: 11/06/2009 12:45 PM MREARIC -----
B103 01	11/18/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001851856
	11/18/09	AP	-----
A814 01	11/18/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001851914
	11/18/09	AP	24 EMMA CT ----- LINDEN 28356 ----- -----
			T/S: 11/18/2009 02:05 PM TWARD -----
B105 01	11/25/09	DT	R*OPEN FLOOR VRU #: 001854835
	11/25/09	AP	
R425 01	1/07/10	TI	FOUR TRADE ROUGH IN VRU #: 001867928
	1/06/10	CA	
R425 02	1/08/10	JH	FOUR TRADE ROUGH IN VRU #: 001868512
	1/08/10	CA	T/S: 01/08/2010 10:54 AM JBROCK -----
R425 03	1/11/10	DT	FOUR TRADE ROUGH IN VRU #: 001869023
	1/11/10	DA	1. No test on pex. 2. B1 trusses not strapped at joint 9 3. Branch drain must extend beyond foundation wall 4. Ladder frame gables. T/S: 01/11/2010 02:11 PM DETAYLOR -----
I129 01	1/13/10	TI	R*INSULATION INSPECTION VRU #: 001869668
	1/13/10	DA DT	
R425 04	1/13/10	TI	FOUR TRADE ROUGH IN VRU #: 001869643
	1/13/10	DA DT	

COMMENTS AND NOTES

ADDRESS : 24 EMMA CT
CONTRACTOR : RBC HOMES INC
OWNER : ABJ INVESTMENTS LLC
PARCEL : 12-0555- - -0216- -37-
APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
PHONE : (910) 423-3555
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 01	4/01/10 4/01/10	JH DP	T/S: 01/22/2010 11:28 AM SSTEWARD FOUR TRADE FINAL VRU #: 001902998 1)Need receptacle on front of house accessible from grade. 2)Need 20amp receptacle for microwave. 3)Cleanout to grade & cover with at least 3" of dirt. 4)Label AHU in attic & crawl space. 5)Sleeve refrigerant lines in foundation wall. 6)Breaker for condensing units to big & they are not wired.
I129 02	4/05/10 11	TI AD DT	R-INSULATION INSPECTION TIME: 17:00 VRU #: 001904952 T/S: 04/05/2010 10:20 AM DJOHNSON

COMMENTS AND NOTES

ADDRESS : 24 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
CONTRACTOR : RBC HOMES INC PHONE : (910) 423-3555
OWNER : ABJ INVESTMENTS LLC PHONE :
PARCEL : 12-0555- - -0216- -37-
APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
KENLAN FARMS #37
US HWY 401 S TO RIGHT ON MCNEILL HOBBS
RD TO LEFT ON WIRE RD PASS JOSEY
WILLIAMS ON THE LEFT AND TURN RIGHT ON
KENLAN RD
T/S: 11/17/2009 01:32 PM DJOHNSON --
*****PREMISE # 55390924*****

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210
	11/06/09	AP	T/S: 11/06/2009 12:45 PM MREARIC
B103 01	11/18/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001851856
	11/18/09	AP	
A814 01	11/18/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001851914
	11/18/09	AP	24 EMMA CT LINDEN 28356
			T/S: 11/18/2009 02:05 PM TWARD
B105 01	11/25/09	DT	R*OPEN FLOOR VRU #: 001854835
	11/25/09	AP	
R425 01	1/07/10	TI	FOUR TRADE ROUGH IN VRU #: 001867928
	1/06/10	CA	
R425 02	1/08/10	JH	FOUR TRADE ROUGH IN VRU #: 001868512
	1/08/10	CA	T/S: 01/08/2010 10:54 AM JBROCK
R425 03	1/11/10	DT	FOUR TRADE ROUGH IN VRU #: 001869023
	1/11/10	DA	1. No test on pex. 2. B1 trusses not strapped at joint 9 3. Branch drain must extend beyond foundation wall 4. Ladder frame gables. T/S: 01/11/2010 02:11 PM DETAYLOR
I129 01	1/13/10	DT	R*INSULATION INSPECTION VRU #: 001869668
	1/13/10	DA	Rough in not approved. T/S: 01/13/2010 11:40 AM DETAYLOR
R425 04	1/13/10	DT	FOUR TRADE ROUGH IN VRU #: 001869643
	1/13/10	DP	1. Still do not have 100 psi on water lines. T/S: 01/13/2010 11:40 AM DETAYLOR
R425 05	1/15/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001870971
	1/15/10	AP	T/S: 01/14/2010 09:34 AM DJOHNSON T/S: January 15, 2010 11:47 AM BSUTTON
H824 01	1/21/10	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001875210
	1/21/10	AP	T/S: 01/22/2010 11:27 AM SSTEWARD

ADDRESS : 24 EMMA CT
CONTRACTOR : RBC HOMES INC
OWNER : ABJ INVESTMENTS LLC
PARCEL : 12-0555- - -0216- -37-
APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
PHONE : (910) 423-3555
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 01	4/01/10 4/01/10	JH DP	T/S: 01/22/2010 11:28 AM SSTEWARD ----- FOUR TRADE FINAL VRU #: 001902998 1) Need receptacle on front of house accessible from grade. 2) Need 20amp receptacle for microwave. 3) Cleanout to grade & cover with at least 3" of dirt. 4) Label AHU in attic & crawl space. 5) Sleeve refrigerant lines in foundation wall. 6) Breaker for condensing units to big & they are not wired.
I129 02	4/05/10 4/05/10	DT AP	R+INSULATION INSPECTION TIME: 17:00 VRU #: 001904952 T/S: 04/05/2010 10:20 AM DJOHNSON -----
R429 02	4/06/10 <u>4-6-10</u>	TI <u>DP JH</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 001905397 T/S: 04/05/2010 04:31 PM DJOHNSON -----

----- COMMENTS AND NOTES -----

ADDRESS : 24¹/₂ EMMA CT
 CONTRACTOR : RBC HOMES INC
 OWNER : ABJ INVESTMENTS LLC
 PARCEL : 12-0555- - -0216- -37-
 APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
 KENLAN FARMS #37
 US HWY 401 S TO RIGHT ON MCNEILL HOBBS
 RD TO LEFT ON WIRE RD PASS JOSEY
 WILLIAMS ON THE LEFT AND TURN RIGHT ON
 KENLAN RD
 T/S: 11/17/2009 01:32 PM DJOHNSON --
 *****PREMISE # 55390924*****

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
 PHONE : (910) 423-3555
 PHONE :

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210
	11/06/09	AP	T/S: 11/06/2009 12:45 PM MREARIC -----
B103 01	11/18/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001851856
	11/18/09	AP	-----
A814 01	11/18/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001851914
	11/18/09	AP	✓ 24 EMMA CT LINDEN 28356 -----
			T/S: 11/18/2009 02:05 PM TWARD -----
B105 01	11/25/09	DT	R*OPEN FLOOR VRU #: 001854835
	11/25/09	AP	
R425 01	1/07/10	TI	FOUR TRADE ROUGH IN VRU #: 001867928
	1/06/10	CA	
R425 02	1/08/10	JH	FOUR TRADE ROUGH IN VRU #: 001868512
	1/08/10	CA	T/S: 01/08/2010 10:54 AM JBROCK -----
R425 03	1/11/10	DT	FOUR TRADE ROUGH IN VRU #: 001869023
	1/11/10	DA	1. No test on pex. 2. B1 trusses not strapped at joint 9 3. Branch drain must extend beyond foundation wall 4. Ladder frame gables. T/S: 01/11/2010 02:11 PM DETAYLOR -----
I129 01	1/13/10	DT	R*INSULATION INSPECTION VRU #: 001869668
	1/13/10	DA	Rough in not approved. T/S: 01/13/2010 11:40 AM DETAYLOR -----
R425 04	1/13/10	DT	FOUR TRADE ROUGH IN VRU #: 001869643
	1/13/10	DP	1. Still do not have 100 psi on water lines. T/S: 01/13/2010 11:40 AM DETAYLOR -----
R425 05	1/15/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001870971
	1/15/10	AP	T/S: 01/14/2010 09:34 AM DJOHNSON -----
H824 01	1/21/10	OT	✓ T/S: January 15, 2010 11:47 AM BSUTTON -----
	1/21/10	AP	ENVR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001875210 T/S: 01/22/2010 11:27 AM SSTEWARD ----- T/S: 01/22/2010 11:28 AM SSTEWARD -----

PREPARED 3/31/10, 13:58:33
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 19
DATE 4/01/10

ADDRESS . : 24th EMMA CT
CONTRACTOR : RBC HOMES INC
OWNER . . : ABJ INVESTMENTS LLC
PARCEL . . : 12-0555- - -0216- -37-
APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
PHONE : (910) 423-3555
PHONE :

TYP/SQ REQUESTED INSP DESCRIPTION
 COMPLETED RESULT RESULTS/COMMENTS

R429 01 4/01/10 TI FOUR TRADE FINAL VRU #: 001902998
 4-1-10 DP TH

----- COMMENTS AND NOTES -----

ADDRESS : 24 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
 CONTRACTOR : RBC HOMES INC PHONE : (910) 423-3555
 OWNER : ABJ INVESTMENTS LLC PHONE :
 PARCEL : 12-0555- - -0216- -37-
 APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/24/2009 11:21 AM JBROCK ----
 KENLAN FARMS #37
 US HWY 401 S TO RIGHT ON MCNEILL HOBBS
 RD TO LEFT ON WIRE RD PASS JOSEY
 WILLIAMS ON THE LEFT AND TURN RIGHT ON
 KENLAN RD
 T/S: 11/17/2009 01:32 PM DJOHNSON --
 *****PREMISE # 55390924*****

STRUCTURE: 000 000 39X34 3BDR CRAWL W/ GARAGE
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/06/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001847210
	11/06/09	AP	T/S: 11/06/2009 12:45 PM MREARIC -----
B103 01	11/18/09	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 001851856
	11/18/09	AP	-----
A814 01	11/18/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001851914
	11/18/09	AP	24 EMMA CT ----- LINDEN 28356 ----- ----- T/S: 11/18/2009 02:05 PM TWARD -----
B105 01	11/25/09	DT	R*OPEN FLOOR VRU #: 001854835
	11/25/09	AP	
R425 01	1/07/10	TI	FOUR TRADE ROUGH IN VRU #: 001867928
	1/06/10	CA	
R425 02	1/08/10	JH	FOUR TRADE ROUGH IN VRU #: 001868512
	1/08/10	CA	T/S: 01/08/2010 10:54 AM JBROCK -----
R425 03	1/11/10	DT	FOUR TRADE ROUGH IN VRU #: 001869023
	1/11/10	DA	1. No test on pex. 2. B1 trusses not strapped at joint 9 3. Branch drain must extend beyond foundation wall 4. Ladder frame gables. T/S: 01/11/2010 02:11 PM DETAYLOR -----
I129 01	1/13/10	DT	R*INSULATION INSPECTION VRU #: 001869668
	1/13/10	DA	Rough in not approved. T/S: 01/13/2010 11:40 AM DETAYLOR -----
R425 04	1/13/10	DT	FOUR TRADE ROUGH IN VRU #: 001869643
	1/13/10	DP	1. Still do not have 100 psi on water lines. T/S: 01/13/2010 11:40 AM DETAYLOR -----
R425 05	1/15/10	BS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001870971
	1/15/10	AP	T/S: 01/14/2010 09:34 AM DJOHNSON ----- T/S: January 15, 2010 11:47 AM BSUTTON -----
H824 01	1/21/10	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001875210
	1/21/10	AP	T/S: 01/22/2010 11:27 AM SSTEWARD ----- T/S: 01/22/2010 11:28 AM SSTEWARD -----

ADDRESS : 24 EMMA CT
CONTRACTOR : RBC HOMES INC
OWNER : ABJ INVESTMENTS LLC
PARCEL : 12-0555- - -0216- -37-
APPL NUMBER: 09-50022916 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS
PHONE : (910) 423-3555
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 01	4/01/10 4/01/10	JH DP	FOUR TRADE FINAL VRU #: 001902998 1)Need receptacle on front of house accessible from grade. 2)Need 20amp receptacle for microwave. 3)Cleanout to grade & cover with at least 3" of dirt. 4)Label AHU in attic & crawl space. 5)Sleeve refrigerant lines in foundation wall. 6)Breaker for condensing units to big & they are not wired.
I129 02	4/05/10 4/05/10	DT AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001904952 T/S: 04/05/2010 10:20 AM DJOHNSON -----
R429 02	4/06/10 4/06/10	JH DP	FOUR TRADE FINAL TIME: 17:00 VRU #: 001905397 T/S: 04/05/2010 04:31 PM DJOHNSON ----- Previous violations # 2,3,&6 were not corrected per code.--
R429 03	4/08/10 <u>4-8-10</u>	TI <u>AP JH</u>	FOUR TRADE FINAL TIME: 17:00 VRU #: 001906437 T/S: 04/07/2010 12:32 PM RDCONTE -----

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: SFQ

Type of Construction: V

Owner of Building: RBC Homes Inc

Building Address: 24 Emma Ct

Zoning District: _____

Zoning Permit No.: _____

Conditional Use Permit No.: _____

Building Permit No.: _____

Electrical Permit No.: _____

Insulation Permit No.: _____

Plumbing Permit No.: _____

Mech. Permit No.: _____

Envir. C.O. No.: _____

Date: 4-8-10
James T. Hall
Building Official

91628005-60
Zoning Official