

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Proposed Facility:

Location of Site:

Water Supply:

Evaluation Method:

Type of Wastewater:

Date Evaluated: 10/8/2008 10/13/09 10/19/09

Design Flow (.1949):

Property Size:

Property Recorded:

- Public Individual Well Spring Other
 Auger Boring Pit Cut
 Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapro Class	.1944 Restr Horiz	
L9 0-24"	0-4%	0-10	G/LS	VFR NSNP					JS .6
		10-35	SBR/SC1	FR SSSP	2.5 YR 8/2 20"				
		0-10	G/LS	VFR NSNP					
		10-25	SBR/SC1	FR SSSP	2.5 YR 8/2 22"				JS .6
		0-15	G/LS	VFR NSNP					
		15-35	SBR/SC1	FR SSSP	7.5 YR 8/1 20"				JS/PS .6
		0-18	G/LS	VFR NSNP					
		18-75	SBR/SC1	FR SSSP	7.5 YR 8/1 22"				JS/PS .5
		0-10"	G LS	VFR NS/MP					
		10-34"	SBR/SC1	FR SS/MP					PS .6
		34-90"	G S	VFR NS/MP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OT / Ben Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	INNOV	PRMP/TERRNOX	
Site LTAR	15	15	