

-----  
ADDRESS : 168 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
TENANT, NBR: CUSTOMER HAS PLANS  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
OWNER : RAMBEAUT CONSTRUCTION INC PHONE :  
PARCEL : 12-0555- - -0216- -29-  
APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 10/09/2009 11:30 AM JBROCK ----  
KENLAN FARMS #29  
SOUTH 401 TO WIRE RD TRUN RIGHT APPROX  
2 MILES ON LEFT KENLAN FARMS  
-----

STRUCTURE: 000 000 68X45 3BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
COMPLETED	RESULT	RESULTS/COMMENTS	
B101 01	11/17/09 <i>11-17-09</i>	TI <i>APJH</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001851151 <i>T-pole passed</i>
----- COMMENTS AND NOTES -----			

-----

ADDRESS . . : 168 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
 TENANT, NBR: CUSTOMER HAS PLANS  
 CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
 OWNER . . : RAMBEAUT CONSTRUCTION INC PHONE :  
 PARCEL . . : 12-0555- - -0216- -29-  
 APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 10/09/2009 11:30 AM JBROCK ----  
 KENLAN FARMS #29  
 SOUTH 401 TO WIRE RD TRUN RIGHT APPROX  
 2 MILES ON LEFT KENLAN FARMS

-----

STRUCTURE: 000 000 68X45 3BDR CRAWL W/ GARAGE & DECK  
 FLOOD ZONE . . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . . : NEW WATER SUPPLY . . . . . : COUNTY

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/17/09	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001851151
	11/17/09	AP	t-pole passed
A814 01	11/24/09	TI	ADDRESS CONFIRMATION VRU #: 001854264
B103 01	11/24/09	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001854256
	<u>11-24-09</u>	<u>AP MR</u>	

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 168 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
TENANT, NBR: CUSTOMER HAS PLANS  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
OWNER : RAMBEAUT CONSTRUCTION INC PHONE :  
PARCEL : 12-0555- - -0216- -29-  
APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 10/09/2009 11:30 AM JBROCK ----  
KENLAN FARMS #29  
SOUTH 401 TO WIRE RD TRUN RIGHT APPROX  
2 MILES ON LEFT KENLAN FARMS  
-----

STRUCTURE: 000 000 68X45 3BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/17/09	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001851151
	11/17/09	AP	t-pole passed -----
B103 01	11/24/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001854256
	11/24/09	AP	T/S: 11/24/2009 12:59 PM MREARIC -----
A814 01	11/24/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001854264
	11/25/09	AP	168 emma ct lot 29 ----- linden 28356 T/S: 11/25/2009 02:51 PM TWARD -----
B105 01	12/04/09	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 001857481
	<u>12-4-09</u>	<u>APBS</u>	T/S: 12/03/2009 09:39 AM RDCONTE -----

----- COMMENTS AND NOTES -----  
-----

-----  
ADDRESS . . : 168 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
TENANT, NBR: CUSTOMER HAS PLANS  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
OWNER . . . : RAMBEAUT CONSTRUCTION INC PHONE :  
PARCEL . . . : 12-0555- - -0216- -29-  
APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 10/09/2009 11:30 AM JBROCK ----  
KENLAN FARMS #29  
SOUTH 401 TO WIRE RD TRUN RIGHT APPROX  
2 MILES ON LEFT KENLAN FARMS  
-----

STRUCTURE: 000 000 68X45 3BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/17/09	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001851151
	11/17/09	AP	t-pole passed -----
B103 01	11/24/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001854256
	11/24/09	AP	T/S: 11/24/2009 12:59 PM MREARIC -----
A814 01	11/24/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001854264
	11/25/09	AP	168 emma ct lot 29 ----- linden 28356 T/S: 11/25/2009 02:51 PM TWARD -----
B105 01	12/04/09	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001857481
	12/04/09	AP	T/S: 12/03/2009 09:39 AM RDCONTE ----- T/S: December 04, 2009 11:27 AM BSUTTON -----
R425 01	12/23/09	TI	FOUR TRADE ROUGH IN VRU #: 001864545
	<i>12-23-09</i>	<i>DA JV</i>	PLEASE CALL WHEN YOU ARE ON YOUR WAY OUT 910-237-5006

----- COMMENTS AND NOTES -----

ADDRESS : 168 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
TENANT, NBR: CUSTOMER HAS PLANS  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
OWNER . . : RAMBEAUT CONSTRUCTION INC PHONE :  
PARCEL . . : 12-0555- - -0216- -29-  
APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 10/09/2009 11:30 AM JBROCK ----  
KENLAN FARMS #29  
SOUTH 401 TO WIRE RD TRUN RIGHT APPROX  
2 MILES ON LEFT KENLAN FARMS

STRUCTURE: 000 000 68X45 3BDR CRAWL W/ GARAGE & DECK  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY


PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/17/09	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001851151
	11/17/09	AP	t-pole passed
B103 01	11/24/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001854256
	11/24/09	AP	T/S: 11/24/2009 12:59 PM MREARIC
A814 01	11/24/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001854264
	11/25/09	AP	168 emma ct lot 29 linden 28356 T/S: 11/25/2009 02:51 PM TWARD
B105 01	12/04/09	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001857481
	12/04/09	AP	T/S: 12/03/2009 09:39 AM RDCONTE T/S: December 04, 2009 11:27 AM BSUTTON
R425 01	12/23/09	JH	FOUR TRADE ROUGH IN VRU #: 001864545
	12/23/09	DA	PLEASE CALL WHEN YOU ARE ON YOUR WAY OUT 910-237-5006 Support trunk line every 64" per code. Bath fans flex duct 14' max. 100psi on water line. 3' head of water on drain lines. Nail 2ply truss per truss drawings. Need truss repair letter for truss in bonus room 31" apart. Boots for plumbing need to be installed.
R425 02	12/30/09	TI	FOUR TRADE ROUGH IN VRU #: 001865922

12-30-09 AIV

COMMENTS AND NOTES

Job	Truss	Truss Type	Qty	Ply	316205/W/Rambeau/RG13A88BL-29/Kenlan	1 UNIT YF	116097308
316205	CO1	ATTIC	10	1	Job Reference (optional)		
Builders FirstSource, Sumter, SC					6.500 e Mar 8 2007 MiTek Industries, Inc. Mon Dec 28 17:06:40 2009 Page 1		



Scale = 1:79.4

ORIGINAL TRUSS WAS DESIGNED AT 24" O.C.  
TRUSS WAS INSTALLED AT 28" O.C.




Plate Offsets (X,Y): [O:0-3-8,0-5-0], [Q:0-3-8,0-5-0]

<b>LOADING</b> (psf)	<b>SPACING</b> 2-4-0	<b>CSI</b>	<b>DEFL</b> in (loc) l/defl L/d	<b>PLATES</b>	<b>GRIP</b>
TCLL 20.0	Plates Increase 1.15	TC 0.88	Vert(LL) -0.22 O-Q >999 240	MT20	244/190
TCDL 10.0	Lumber Increase 1.15	BC 0.39	Vert(TL) -0.34 O-Q >967 180		
BCLL 0.0 *	Rep Stress Incr NO	WB 0.86	Horz(TL) 0.02 N n/a n/a		
BCDL 10.0	Code IRC2006/TPI2002	(Matrix)			Weight: 278 lb


<b>LUMBER</b>	<b>BRACING</b>
TOP CHORD 2 X 6 SYP No.2 *Except* E-F 2 X 4 SYP No.2, H-I 2 X 4 SYP No.2	TOP CHORD 2-0-0 oc purlins (4-1-14 max.), except end verticals (Switched from sheeted: Spacing > 2-0-0).
BOT CHORD 2 X 10 SYP DSS	BOT CHORD Rigid ceiling directly applied or 10-0-0 oc bracing.
WEBS 2 X 4 SYP No.2 *Except* C-Q 2 X 4 SYP No.3, K-O 2 X 4 SYP No.3, G-S 2 X 4 SYP No.3 C-R 2 X 4 SYP No.3, K-N 2 X 4 SYP No.3	JOINTS 1 Brace at Jt(s): G, S, B, L

**REACTIONS** (lb/size) R=2185/0-3-8, N=2185/0-3-8  
Max Horz R=-446(LC 4)  
Max Uplift R=-3(LC 6), N=-3(LC 7)

**FORCES** (lb) - Maximum Compression/Maximum Tension  
TOP CHORD A-B=0/43, B-C=-122/116, C-D=-2439/21, D-E=-2243/49, E-F=-1735/179, F-G=-248/112, G-H=-248/112, H-I=-1735/179,  
I-J=-2243/49, J-K=-2439/21, K-L=-122/116, L-M=0/43, B-R=-157/133, L-N=-157/133  
BOT CHORD Q-R=-102/1410, P-Q=0/1792, O-P=0/1792, N-O=0/1410  
WEBS F-S=-1768/156, H-S=-1768/156, E-Q=-77/770, I-O=-76/770, C-Q=-33/516, K-O=-33/516, G-S=0/101, C-R=-2441/0,  
K-N=-2441/0

- NOTES** (10)
- Unbalanced roof live loads have been considered for this design.
  - Wind: ASCE 7-05; 100mph; h=15ft; TCDL=6.0psf, BCDL=5.0psf; Category II; Exp B; enclosed; MWFRS gable end zone and C-C Exterior(2) zone; cantilever left and right exposed; end vertical left and right exposed; Lumber DOL=1.60 plate grip DOL=1.60. This truss is designed for C-C for members and forces, and for MWFRS for reactions specified.
  - This truss has been designed for a 10.0 psf bottom chord live load nonconcurrent with any other live loads.
  - \* This truss has been designed for a live load of 20.0psf on the bottom chord in all areas where a rectangle 3-6-0 tall by 1-0-0 wide will fit between the bottom chord and any other members.
  - Ceiling dead load (5.0 psf) on member(s) E-F, H-I, F-S, H-S; Wall dead load (10.0psf) on member(s) E-Q, I-O
  - Bottom chord live load (40.0 psf) and additional bottom chord dead load (0.0 psf) applied only to room. O-Q
  - Provide mechanical connection (by others) of truss to bearing plate capable of withstanding 3 lb uplift at joint R and 3 lb uplift at joint N.
  - This truss is designed in accordance with the 2006 International Residential Code sections R502.11.1 and R802.10.2 and referenced standard ANSI/TPI 1.
  - Graphical purlin representation does not depict the size or the orientation of the purlin along the top and/or bottom chord.
  - This manufactured truss is designed as an individual building component. The suitability and use of this component for any particular building is the responsibility of the building designer per ANSI TPI 1 as referenced by the building code.

**LOAD CASE(S)** Standard



December 29, 2009

**WARNING - Verify design parameters and READ NOTES ON THIS AND INCLUDED MITEK REFERENCE PAGE 53 7 473 rev. 10/08 BEFORE USE**  
Design valid for use only with MiTek connectors. This design is based only upon parameters shown, and is for an individual building component. Applicability of design parameters and proper incorporation of component is responsibility of building designer, not truss designer. Bracing shown is for lateral support of individual web members only. Additional temporary bracing to insure stability during construction is the responsibility of the erector. Additional permanent bracing of the overall structure is the responsibility of the building designer. For general guidance regarding fabrication, quality control, storage, delivery, erection and bracing, consult **ANSI/TPI1 Quality Criteria, D58-89 and BCSI Building Component Safety Information** available from Truss Plate Institute, 281 N. Lee Street, Suite 312, Alexandria, VA 22314.

**ENGINEERS BY TRENCO**  
818 Southside Road  
Edenton, NC 27932

ADDRESS : 168 EMMA CT  
 TENANT, NBR: CUSTOMER HAS PLANS  
 CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
 OWNER . . : RAMBEAUT CONSTRUCTION INC  
 PARCEL . . : 12-0555- - -0216- -29-  
 APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 10/09/2009 11:30 AM JBROCK ----  
 KENLAN FARMS #29  
 SOUTH 401 TO WIRE RD TRUN RIGHT APPROX  
 2 MILES ON LEFT KENLAN FARMS

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
 PHONE : (910) 237-5006  
 PHONE :

**STRUCTURE: 000 000 68X45 3BDR CRAWL W/ GARAGE & DECK**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/17/09	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001851151
	11/17/09	AP	t-pole passed
B103 01	11/24/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001854256
	11/24/09	AP	T/S: 11/24/2009 12:59 PM MREARIC -----
A814 01	11/24/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001854264
	11/25/09	AP	168 emma ct lot 29 ----- linden 28356 T/S: 11/25/2009 02:51 PM TWARD -----
B105 01	12/04/09	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001857481
	12/04/09	AP	T/S: 12/03/2009 09:39 AM RDCONTE ----- T/S: December 04, 2009 11:27 AM BSUTTON -----
R425 01	12/23/09	JH	FOUR TRADE ROUGH IN VRU #: 001864545
	12/23/09	DA	PLEASE CALL WHEN YOU ARE ON YOUR WAY OUT 910-237-5006 1)Support trunk line every 64" per code. 2)Bath fans flex duct 14' max. 3)100psi on water line. 4)3' head of water on drain lines. 5)Nail 2ply truss per truss drawings. 6)Need truss repair letter for truss in bonus room 31" apart. 7) Boots for plumbing need to be installed.
R425 02	12/30/09	JH	FOUR TRADE ROUGH IN VRU #: 001865922
	12/30/09	AP	-----
I129 01	1/05/10	TI	R*INSULATION INSPECTION VRU #: 001867217
	<u>1/5/10</u>	<u>AP DT</u>	

COMMENTS AND NOTES

ADDRESS : 168 EMMA CT  
TENANT, NBR: CUSTOMER HAS PLANS  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS  
OWNER . . : RAMBEAUT CONSTRUCTION INC  
PARCEL . . : 12-0555- - -0216- -29-  
APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 10/09/2009 11:30 AM JBROCK ----  
KENLAN FARMS #29  
SOUTH 401 TO WIRE RD TRUN RIGHT APPROX  
2 MILES ON LEFT KENLAN FARMS

SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
PHONE : (910) 237-5006  
PHONE :

STRUCTURE: 000 000 68X45 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/17/09	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001851151
	11/17/09	AP	t-pole passed
B103 01	11/24/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001854256
	11/24/09	AP	T/S: 11/24/2009 12:59 PM MREARIC
A814 01	11/24/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001854264
	11/25/09	AP	✓ 168 emma ct lot 29 linden 28356 T/S: 11/25/2009 02:51 PM TWARD
B105 01	12/04/09	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001857481
	12/04/09	AP	T/S: 12/03/2009 09:39 AM RDCONTE T/S: December 04, 2009 11:27 AM BSUTTON
R425 01	12/23/09	JH	FOUR TRADE ROUGH IN VRU #: 001864545
	12/23/09	DA	PLEASE CALL WHEN YOU ARE ON YOUR WAY OUT 910-237-5006 1)Support trunk line every 64" per code. 2)Bath fans flex duct 14' max. 3)100psi on water line. 4)3' head of water on drain lines. 5)Nail 2ply truss per truss drawings. 6)Need truss repair letter for truss in bonus room 31" apart. 7) Boots for plumbing need to be installed.
R425 02	12/30/09	JH	FOUR TRADE ROUGH IN VRU #: 001865922
	12/30/09	AP	
I129 01	1/05/10	DT	R*INSULATION INSPECTION VRU #: 001867217
	1/05/10	AP	
H824 01	1/13/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001871078
	1/13/10	AP	T/S: 01/14/2010 10:22 AM SSTEWARD T/S: 01/14/2010 10:22 AM SSTEWARD
R429 01	2/11/10	TI	FOUR TRADE FINAL VRU #: 001881424
	2/11/10	DA DT	

COMMENTS AND NOTES



ADDRESS : 168 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
 TENANT, NEW: CUSTOMER HAS PLANS  
 CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
 OWNER . . : RAMBEAUT CONSTRUCTION INC PHONE :  
 PARCEL . . : 12-0555- - -0216- -29-  
 APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 10/09/2009 11:30 AM JBROCK ----  
 KENLAN FARMS #29  
 SOUTH 401 TO WIRE RD TRUN RIGHT APPROX  
 2 MILES ON LEFT KENLAN FARMS 65317286

STRUCTURE: 000 000 68X45 3BDR CRAWL W/ GARAGE & DECK  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	11/17/09	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001851151
	11/17/09	AP	t-pole passed
B103 01	11/24/09	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001854256
	11/24/09	AP	T/S: 11/24/2009 12:59 PM MREARIC -----
A814 01	11/24/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001854264
	11/25/09	AP	✓ 168 emma ct lot 29 ----- linden 28356 T/S: 11/25/2009 02:51 PM TWARD -----
B105 01	12/04/09	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 001857481
	12/04/09	AP	T/S: 12/03/2009 09:39 AM RDCONTE ----- T/S: December 04, 2009 11:27 AM BSUTTON -----
R425 01	12/23/09	JH	FOUR TRADE ROUGH IN VRU #: 001864545
	12/23/09	DA	PLEASE CALL WHEN YOU ARE ON YOUR WAY OUT 910-237-5006 1)Support trunk line every 64" per code. 2)Bath fans flex duct 14' max. 3)100psi on water line. 4)3' head of water on drain lines. 5)Nail 2ply truss per truss drawings. 6)Need truss repair letter for truss in bonus room 31" apart. 7) Boots for plumbing need to be installed.
R425 02	12/30/09	JH	FOUR TRADE ROUGH IN VRU #: 001865922
	12/30/09	AP	-----
I129 01	1/05/10	DT	R*INSULATION INSPECTION VRU #: 001867217
	1/05/10	AP	
H824 01	1/13/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001871078
	1/13/10	AP	T/S: 01/14/2010 10:22 AM SSTEWARD ----- T/S: 01/14/2010 10:22 AM SSTEWARD -----
R429 01	2/11/10	BT	FOUR TRADE FINAL VRU #: 001881424
	2/11/10	DA	1. Step from ground to garage personel door greater than 8 1/4 inches 2. Crawl space access door broken 3. Microwave is on 20 amp breaker, must have 20 amp receptacle T/S: 02/11/2010 10:51 AM DETAYLOR-----
R429 02	2/12/10	TI	FOUR TRADE FINAL VRU #: 001882257

-----  
ADDRESS . . : 168 EMMA CT SUBDIV: KENLAN FARMS PH1 SET1 41LOTS  
TENANT, NRR: CUSTOMER HAS PLANS  
CONTRACTOR : RAMBEAUT, WAYNE THOMAS PHONE : (910) 237-5006  
OWNER . . : RAMBEAUT CONSTRUCTION INC PHONE :  
PARCEL . . : 12-0555- - -0216- -29-  
APPL NUMBER: 09-50023023 CP NEW RESIDENTIAL (SFD)  
-----

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

2/12/10 AP DT

----- COMMENTS AND NOTES -----

**COUNTY OF HARNETT  
DEPARTMENT OF BUILDING INSPECTION  
AND PLANNING/DEVELOPMENT  
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: Residential

Type of Construction: \_\_\_\_\_

Owner of Building: Rambeau Construction Inc.

Building Address: 68 Emma Ct.

Zoning District: Linden NC 28356

Zoning Permit No.: \_\_\_\_\_

Date: 2/12/10

D E T L

Building Official

Conditional Use Permit No.: \_\_\_\_\_

Building Permit No.: \_\_\_\_\_

Electrical Permit No.: \_\_\_\_\_

Insulation Permit No.: \_\_\_\_\_

Plumbing Permit No.: \_\_\_\_\_

Mech. Permit No.: 09-50023023

Envir. C.O. No.: \_\_\_\_\_

Zoning Official