Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 10/19/09
Proposed Facility: 3 Bedroom home Design Flow (.1949): 360 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 7-10%	0-12	G SL	VFR NS/NP					
		12-48"	SBK CL	FR SS/SP	10YR 7/2 @ 45"				PS .35
2		0-8	G SL	VFR NS/NP					
		8-48"	SBK SCL	FR SS/SP	10YR 7/2 @ 46"				PS .4

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25%, 260	25%, 260
Site LTAR	.35	.35

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: JT
Others Present: —