

**SOIL/SITE EVALUATION**  
 for ON-SITE WASTEWATER SYSTEM

Owner:                      Applicant:  
 Address:  
 Proposed Facility: 38820050      Date Evaluated: 10/26/09  
 Location of Site:                      Design Flow (.1949): 560 yd  
 Water Supply:                      Property Recorded:  
 Evaluation Method:                       Public       Individual       Well       Spring       Other  
 Type of Wastewater:                       Auger Boring       Pit       Cut  
     Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS S	0-24	G S	VFD NS/NP					P3 .5
		24-48	BK SCL	FL SS/SP					
2		0-44	C S	VFD NS/NP					S .8

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): Evaluated By: Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	C.S	2028	
Site LTAR	.5	.5	