
ADDRESS . . : 129 MICRO CT
 CONTRACTOR : D WALSH CONSTRUCTION LLC
 OWNER . . . : D WALSH CONSTRUCTION CO LLC
 PARCEL . . . : 03-9597- - -0033- -43-
 APPL NUMBER: 09-50023099 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 10/21/2009 12:18 PM VBROWN ----
 129 MICRO COURT, TINGEN PLACE #48 PH2.
 27W, LEFT ON TINGEN RD GO 1.5MI, LEFT
 INTO TINGEN PL, 2ND RIGHT MICRO COURT
 LOT IN CUL-DA-SAC.

SUBDIV: TINGEN PLACE PH 2 28LOTS
 PHONE : (919) 542-4506
 PHONE :

STRUCTURE: 000 000 40X41 CRAWL 3BD/2.5BA W/GAR & PATIO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	12/02/09	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001856361
	<i>12-2-09</i>	<i>AP-IVR</i>	

COMMENTS AND NOTES

Deen did this yesterday

ADDRESS : 129 MICRO CT
CONTRACTOR : D WALSH CONSTRUCTION LLC
OWNER : D WALSH CONSTRUCTION CO LLC
PARCEL : 03-9597- - -0033- -43-
APPL NUMBER: 09-50023099 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 10/21/2009 12:18 PM VBROWN ----
129 MICRO COURT, TINGEN PLACE #48 PH2.
27W, LEFT ON TINGEN RD GO 1.5MI, LEFT
INTO TINGEN PL, 2ND RIGHT MICRO COURT
LOT IN CUL-DA-SAC.

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-4506
PHONE :

STRUCTURE: 000 000 40X41 CRAWL 3BD/2.5BA W/GAR & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/02/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001856361
	12/02/09	AP	T/S: 12/02/2009 11:43 AM MREARIC -----
B103 01	12/08/09	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001858513
	<u>12-8-9</u>	<u>AP-MR</u>	T/S: 12/07/2009 09:16 AM VBROWN -----

COMMENTS AND NOTES

ADDRESS : 129 MICRO CT
CONTRACTOR : D WALSH CONSTRUCTION LLC
OWNER : D WALSH CONSTRUCTION CO LLC
PARCEL : 03-9597- - -0033- -43-
APPL NUMBER: 09-50023099 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 10/21/2009 12:18 PM VBROWN ----
129 MICRO COURT, TINGEN PLACE #48 PH2.
27W, LEFT ON TINGEN RD GO 1.5MI, LEFT
INTO TINGEN PL, 2ND RIGHT MICRO COURT
LOT IN CUL-DA-SAC.

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-4506
PHONE :

STRUCTURE: 000 000 40X41 CRAWL 3BD/2.5BA W/GAR & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/02/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001856361
	12/02/09	AP	T/S: 12/02/2009 11:43 AM MREARIC -----
B103 01	12/08/09	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001858513
	12/08/09	AP	T/S: 12/07/2009 09:16 AM VBROWN ----- T/S: 12/08/2009 01:27 PM MREARIC -----
B105 01	12/09/09	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 001859578
	<u>12-9-9</u>	<u>AP-MR</u>	T/S: 12/08/2009 01:56 PM RDCONTE -----

COMMENTS AND NOTES

ADDRESS : 129 MICRO CT
CONTRACTOR : D WALSH CONSTRUCTION LLC
OWNER : D WALSH CONSTRUCTION CO LLC
PARCEL : 03-9597- - -0033- -43-
APPL NUMBER: 09-50023099 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 10/21/2009 12:18 PM VBROWN ----
129 MICRO COURT, TINGEN PLACE #48 PH2.
27W, LEFT ON TINGEN RD GO 1.5MI, LEFT
INTO TINGEN PL, 2ND RIGHT MICRO COURT
LOT IN CUL-DA-SAC.

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-4506
PHONE :

STRUCTURE: 000 000 40X41 CRAWL 3BD/2.5BA W/GAR & PATIO

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/02/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001856361
	12/02/09	AP	T/S: 12/02/2009 11:43 AM MREARIC -----
B103 01	12/08/09	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001858513
	12/08/09	AP	T/S: 12/07/2009 09:16 AM VBROWN ----- T/S: 12/08/2009 01:27 PM MREARIC -----
B105 01	12/09/09	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 001859578
	12/09/09	AP	T/S: 12/08/2009 01:56 PM RDCONTE ----- T/S: 12/09/2009 01:30 PM MREARIC -----
A814 01	12/14/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001859484
	12/09/09	AP	129 micro ct lot 48 ----- broadway 27505 T/S: 12/09/2009 03:56 PM TWARD -----
R425 01	1/15/10	TI	FOUR TRADE ROUGH IN VRU #: 001870997
	<u>1-15-10</u>	<u>DA-ml</u>	

COMMENTS AND NOTES

Nail beam strap in garage
Water Leak
OK to Sideinsulate

ADDRESS : 129 MICRO CT
CONTRACTOR : D WALSH CONSTRUCTION LLC
OWNER : D WALSH CONSTRUCTION CO LLC
PARCEL : 03-9597- - -0033- -43-
APPL NUMBER: 09-50023099 CP NEW RESIDENTIAL (SFD)

SUBDIV: TINGEN PLACE PH 2 28LOTS
PHONE : (919) 542-4506
PHONE :

DIRECTIONS : T/S: 10/21/2009 12:18 PM VBROWN ----
129 MICRO COURT, TINGEN PLACE #48 PH2.
27W, LEFT ON TINGEN RD GO 1.5MI, LEFT
INTO TINGEN PL, 2ND RIGHT MICRO COURT
LOT IN CUL-DA-SAC.

STRUCTURE: 000 000 40X41 CRAWL 3BD/2.5BA W/GAR & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/02/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001856361
	12/02/09	AP	T/S: 12/02/2009 11:43 AM MREARIC -----
B103 01	12/08/09	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001858513
	12/08/09	AP	T/S: 12/07/2009 09:16 AM VBROWN ----- T/S: 12/08/2009 01:27 PM MREARIC -----
B105 01	12/09/09	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 001859578
	12/09/09	AP	T/S: 12/08/2009 01:56 PM RDCONTE ----- T/S: 12/09/2009 01:30 PM MREARIC -----
A814 01	12/14/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001859484
	12/09/09	AP	129 micro ct lot 48 ----- broadway 27505 T/S: 12/09/2009 03:56 PM TWARD -----
R425 01	1/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001870997
	1/15/10	DA	T/S: 01/15/2010 01:00 PM MREARIC ----- 1. hanger on beam not strapped in garage 2. water line has leak at tub ok to side and insul.
I129 01	1/19/10	TI	R*INSULATION INSPECTION VRU #: 001872030
	1-19-10	AP-MR	
R425 02	1/19/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001872225
	1-19-10	AP-MR	T/S: 01/15/2010 02:34 PM DJOHNSON -----

COMMENTS AND NOTES

ADDRESS : 129 MICRO CT SUBDIV: TINGEN PLACE PH 2 28LOTS
 CONTRACTOR : D WALSH CONSTRUCTION LLC PHONE : (919) 542-4506
 OWNER : D WALSH CONSTRUCTION CO LLC PHONE :
 PARCEL : 03-9597- - -0033- -43-
 APPL NUMBER: 09-50023099 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 10/21/2009 12:18 PM VBROWN ----
 129 MICRO COURT, TINGEN PLACE #48 PH2.
 27W, LEFT ON TINGEN RD GO 1.5MI, LEFT
 INTO TINGEN PL, 2ND RIGHT MICRO COURT
 LOT IN CUL-DA-SAC.

STRUCTURE: 000 000 40X41 CRAWL 3BD/2.5BA W/GAR & PATIO
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/02/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001856361
	12/02/09	AP	T/S: 12/02/2009 11:43 AM MREARIC -----
B103 01	12/08/09	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001858513
	12/08/09	AP	T/S: 12/07/2009 09:16 AM VBROWN ----- T/S: 12/08/2009 01:27 PM MREARIC -----
B105 01	12/09/09	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 001859578
	12/09/09	AP	T/S: 12/08/2009 01:56 PM RDCONTE ----- T/S: 12/09/2009 01:30 PM MREARIC -----
A814 01	12/14/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001859484
	12/09/09	AP	129 micro ct lot 48 ----- broadway 27505 ----- T/S: 12/09/2009 03:56 PM TWARD -----
R425 01	1/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001870997
	1/15/10	DA	T/S: 01/15/2010 01:00 PM MREARIC ----- 1. hanger on beam not strapped in garage 2. water line has leak at tub ok to side and insul.
I129 01	1/19/10	MR	R*INSULATION INSPECTION VRU #: 001872030
	1/19/10	AP	T/S: 01/19/2010 01:46 PM MREARIC -----
R425 02	1/19/10	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001872225
	1/19/10	AP	T/S: 01/15/2010 02:34 PM DJOHNSON ----- T/S: 01/19/2010 01:46 PM MREARIC -----
H824 01	1/27/10	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001878578
	1/27/10	AP	T/S: 01/29/2010 12:11 PM SSTEWARD ----- T/S: 01/29/2010 12:12 PM SSTEWARD -----
R429 01	5/13/10	TI	FOUR TRADE FINAL VRU #: 001925670

5-12-10 DP MR

COMMENTS AND NOTES

Back stairs
 (us. around boots)
 Positive drain

ADDRESS : 129 MICRO CT SUBDIV: TINGEN PLACE PH 2 28LOTS
 CONTRACTOR : D WALSH CONSTRUCTION LLC PHONE : (919) 542-4506
 OWNER : D WALSH CONSTRUCTION CO LLC PHONE :
 PARCEL : 03-9597- - -0033- -43-
 APPL NUMBER: 09-50023099 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 10/21/2009 12:18 PM VBROWN ----
 129 MICRO COURT, TINGEN PLACE #48 PH2.
 27W, LEFT ON TINGEN RD GO 1.5MI, LEFT
 INTO TINGEN PL, 2ND RIGHT MICRO COURT
 LOT IN CUL-DA-SAC.

STRUCTURE: 000 000 40X41 CRAWL 3BD/2.5BA W/GAR & PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/02/09	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001856361
	12/02/09	AP	T/S: 12/02/2009 11:43 AM MREARIC -----
B103 01	12/08/09	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001858513
	12/08/09	AP	T/S: 12/07/2009 09:16 AM VBROWN ----- T/S: 12/08/2009 01:27 PM MREARIC -----
B105 01	12/09/09	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 001859578
	12/09/09	AP	T/S: 12/08/2009 01:56 PM RDCONTE ----- T/S: 12/09/2009 01:30 PM MREARIC -----
A814 01	12/14/09	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001859484
	12/09/09	AP	√ 129 micro ct lot 48 ----- broadway 27505 T/S: 12/09/2009 03:56 PM TWARD -----
R425 01	1/15/10	MR	FOUR TRADE ROUGH IN VRU #: 001870997
	1/15/10	DA	T/S: 01/15/2010 01:00 PM MREARIC ----- 1. hanger on beam not strapped in garage 2. water line has leak at tub ok to side and insul.
I129 01	1/19/10	MR	R*INSULATION INSPECTION VRU #: 001872030
	1/19/10	AP	T/S: 01/19/2010 01:46 PM MREARIC -----
R425 02	1/19/10	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001872225
	1/19/10	AP	T/S: 01/15/2010 02:34 PM DJOHNSON ----- T/S: 01/19/2010 01:46 PM MREARIC -----
H824 01	1/27/10	OT	√ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001878578
	1/27/10	AP	T/S: 01/29/2010 12:11 PM SSTEWARD ----- T/S: 01/29/2010 12:12 PM SSTEWARD -----
R429 01	5/13/10	MR	FOUR TRADE FINAL VRU #: 001925670
	5/13/10	DP	T/S: 05/13/2010 11:56 AM MREARIC ----- guardrail on rear steps insulate around floor boots provide positive drainage for foundation
R429 02	6/29/10	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001947324
	6-29-10	AP-IVR	T/S: 06/28/2010 11:54 AM RDCONTE -----

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: D. Walsh Construction

Building: 0950023099

Address: 129 Misco Ct.

Electrical: "

Insulation: "

Plumbing: "

Mechanical: "

MFG Home: "

Date: 6-29-10

Building Official: G. Michael Roan