

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 1/12/09
 Proposed Facility: 3 BEDROOM HOME Design Flow (.1949): 360 gpd
 Location of Site: Property Recorded: Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

PROFILE #	.1940 Landscape Position/Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-14"	C SL	VFL NS/NP					S.G
		14-36"	G LS	VFL NS/NP					
		PIT DEPTH							
2	⊙	0-20"	G SL	VFL NS/NP					S.G
		20-40"	G LS	VFL NS/NP					
		PIT DEPTH							

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): 5 Evaluated By: OT Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	25% RED	25% RED	
Site LTAR	.C	.G	

1 x 150' @ 18" ON DOWNHILL SIDE
 = REPAIR



SYSTEM BASED ON PROPOSAL FROM CONSULTANT