

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant: 23174 Date Evaluated: 11-17-09-11-20-09  
 Address: Design Flow (.1949): 360 Property Size:  
 Proposed Facility: SPV Property Recorded:  
 Location of Site:  Public  Individual  Well  Spring  Other  
 Water Supply:  Auger Boring  Pit  Cut  
 Evaluation Method:  Sewage  Industrial Process  Mixed  
 Type of Wastewater:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L	0-24	SL	FR GRAN					.3
		24-30	SL	FR GRAN					
		30-36	SL-ORAG	FRM 1/2 BK SP	36"	30"		P	
		36-44	P	-					
2	LT	0-28	SL	FR GRAN				.4	
		28-48	SC-	FRM 1/2 BK S.P.					
3	LT	0-36	SL	FR GRAN				.4	
		36-48	SC-	FRM 1/2 BK S.P.		48			P

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: JN - part of + on Others Present:
Available Space (.1945)	✓	✓	
System Type(s)	25"u	76"u	
Site LTAR	.4	13-5-1	