

-----  
ADDRESS . . : 940 WILBURN RD  
CONTRACTOR :  
OWNER . . . : BARBOUR TOMMY W& CRYSTAL H  
PARCEL . . . : 08-0641- - -0012- -02-  
APPL NUMBER: 09-50023177 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 11/03/2009 10:57 AM RDCONTE ---  
KATHY ADAMS #2A / WILBURN ROAD TAKE  
401 TO FOUR WAY INTOERSECTIN. T/L GO  
NORTH ON 401.T/L ON WILBURN ROAD. GOTO  
END OF WILBURN LOT 2Z WILL BE ON THE  
RIGHT  
\*\*\*PWR CO: WAITING ON CUS\*\*\*

SUBDIV: DIVISION OF W L SENTER ESTATE  
PHONE :  
PHONE :

-----  
**STRUCTURE: 000 000 67.6X74 CRAWL 3BD/2BA W/GAR, PATIO**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

-----  
**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/10/10 <u>3-10-10</u>	TI <u>DAB</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892642

-----  
COMMENTS AND NOTES  
-----

-----

ADDRESS : 940 WILBURN RD  
 CONTRACTOR :  
 OWNER : BARBOUR TOMMY W& CRYSTAL H  
 PARCEL : 08-0641- - -0012- -02-  
 APPL NUMBER: 09-50023177 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 11/03/2009 10:57 AM RDCONTE ---  
 KATHY ADAMS #2A / WILBURN ROAD TAKE  
 401 TO FOUR WAY INTOERSECTIN. T/L GO  
 NORTH ON 401.T/L ON WILBURN ROAD. GOTO  
 END OF WILBURN LOT 2Z WILL BE ON THE  
 RIGHT  
 \*\*\*PWR CO: WAITING ON CUS\*\*\*

-----

STRUCTURE: 000 000 67.6X74 CRAWL 3BD/2BA W/GAR, PATIO  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/10/10 3/10/10	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892642 1. Left side and rear of footings are less than 12 inches below grade. T/S: March 10, 2010 11:33 AM BSUTTON ----- went back, problems corrected
B103 01	3/19/10 <u>3-19-10</u>	TI <u>AEBS</u>	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001896695 T/S: 03/17/2010 03:07 PM NTART ----- TSP IS READY.....

----- COMMENTS AND NOTES -----

ADDRESS : 940 WILBURN RD  
CONTRACTOR :  
OWNER : BARBOUR TOMMY W& CRYSTAL H  
PARCEL : 08-0641- - -0012- -02-  
APPL NUMBER: 09-50023177 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 11/03/2009 10:57 AM RDCONTE ---  
KATHY ADAMS #2A / WILBURN ROAD TAKE  
401 TO FOUR WAY INTOERSECTIN. T/L GO  
NORTH ON 401.T/L ON WILBURN ROAD. GOTO  
END OF WILBURN LOT 2Z WILL BE ON THE  
RIGHT  
\*\*\*PWR CO: WAITING ON CUS\*\*\*  
T/S: 03/19/2010 11:05 AM NTART -----  
PREMISE NUMBER 30024309\*\*\*\*\*

SUBDIV: DIVISION OF W L SENTER ESTATE  
PHONE :  
PHONE :

STRUCTURE: 000 000 67.6X74 CRAWL 3BD/2BA W/GAR, PATIO

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00  
SEPTIC - EXISTING? : NEW  
PROPOSED USE : SFD  
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/10/10 3/10/10	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892642 1. Left side and rear of footings are less than 12 inches below grade. T/S: March 10, 2010 11:33 AM BSUTTON ----- went back, problems corrected
B103 01	3/19/10 3/19/10	BS AE	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001896695 T/S: 03/17/2010 03:07 PM NTART ----- TSP IS READY..... Damproof exterior of foundation from footing up to final grade height. Leave exterior open, will check at open floor
A814 01	3/24/10	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001898980 T/S: 03/23/2010 12:00 PM RDCONTE -----
B105 01	<u>3/24/10</u> <u>3-24</u>	<u>TI</u> <u>AP</u>	R*OPEN FLOOR TIME: 17:00 VRU #: 001898972 T/S: 03/23/2010 12:00 PM RDCONTE ----- NEEDS INSPECTION AFTER 2:00PM


----- COMMENTS AND NOTES -----

**Howerton Services, LLC.**  
7316 Laketree Drive  
Raleigh, NC 27615  
(919) 270-3460

April 8, 2010

Subject: Barbour Residence  
Plan Revision  
Harnett County Application #: 09-50023177

Per my site review of the framing, the double 2 x 10's and proposed 4" x 6" lintel above the hallway area are acceptable for the added brick veneer. These members meet all the requirements for brick veneers as described in the North Carolina State Building Code for Residences.



-----

ADDRESS . . : 940 WILBURN RD SUBDIV: DIVISION OF W L SENTER ESTATE  
 CONTRACTOR : PHONE :  
 OWNER . . : BARBOUR TOMMY W& CRYSTAL H PHONE :  
 PARCEL . . : 08-0641- - -0012- -02-  
 APPL NUMBER: 09-50023177 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 11/03/2009 10:57 AM RDCONTE ---  
 KATHY ADAMS #2A / WILBURN ROAD TAKE  
 401 TO FOUR WAY INTOERSECTIN. T/L GO  
 NORTH ON 401.T/L ON WILBURN ROAD. GOTO  
 END OF WILBURN LOT 2Z WILL BE ON THE  
 RIGHT  
 \*\*\*PWR CO: WAITING ON CUS\*\*\*  
 T/S: 03/19/2010 11:05 AM NTART -----  
 PREMISE NUMBER 30024309\*\*\*\*\*

-----

**STRUCTURE: 000 000 67.6X74 CRAWL 3BD/2BA W/GAR, PATIO**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/10/10 3/10/10	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892642 1. Left side and rear of footings are less than 12 inches below grade. T/S: March 10, 2010 11:33 AM BSUTTON ----- went back, problems corrected
B103 01	3/19/10 3/19/10	BS AE	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001896695 T/S: 03/17/2010 03:07 PM NTART ----- TSP IS READY..... Damproof exterior of foundation from footing up to final grade height. Leave exterior open, will check at open floor
A814 01	3/24/10 3/30/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001898980 T/S: 03/23/2010 12:00 PM RDCONTE ----- 940 WILBURN RD ----- FUQUAY VARINA 27526 T/S: 03/30/2010 03:56 PM TWARD -----
B105 01	3/24/10 3/24/10	KS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001898972 T/S: 03/23/2010 12:00 PM RDCONTE ----- NEEDS INSPECTION AFTER 2:00PM
R427 01	4/29/10 <u>4-29-10</u>	TI <u>DABS</u>	FOUR TRADE ROUGH IN >2500 VRU #: 001917681

-----  
COMMENTS AND NOTES  
-----

ADDRESS : 940 WILBURN RD  
 CONTRACTOR :  
 OWNER : BARBOUR TOMMY W& CRYSTAL H  
 PARCEL : 08-0641- - -0012- -02-  
 APPL NUMBER: 09-50023177 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 11/03/2009 10:57 AM RDCONTE ---  
 KATHY ADAMS #2A / WILBURN ROAD TAKE  
 401 TO FOUR WAY INTOERSECTIN. T/L GO  
 NORTH ON 401.T/L ON WILBURN ROAD. GOTO  
 END OF WILBURN LOT 2Z WILL BE ON THE  
 RIGHT  
 \*\*\*PWR CO: WAITING ON CUS\*\*\*  
 T/S: 03/19/2010 11:05 AM NTART -----  
 PREMISE NUMBER 30024309\*\*\*\*\*

STRUCTURE: 000 000 67.6X74 CRAWL 3BD/2BA W/GAR, PATIO  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/10/10 3/10/10	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892642 1. Left side and rear of footings are less than 12 inches below grade. T/S: March 10, 2010 11:33 AM BSUTTON ----- went back, problems corrected
B103 01	3/19/10 3/19/10	BS AE	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001896695 T/S: 03/17/2010 03:07 PM NTART ----- TSP IS READY..... Damproof exterior of foundation from footing up to final grade height. Leave exterior open, will check at open floor
A814 01	3/24/10 3/30/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001898980 T/S: 03/23/2010 12:00 PM RDCONTE ----- 940 WILBURN RD ----- FUQUAY VARINA 27526 T/S: 03/30/2010 03:56 PM TWARD -----
B105 01	3/24/10 3/24/10	KS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001898972 T/S: 03/23/2010 12:00 PM RDCONTE ----- NEEDS INSPECTION AFTER 2:00PM
R427 01	4/29/10 4/30/10	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001917681 1. Complete firecaulk on interior walls. 2. Staple range wire up under house. OK to insulate
I129 01	5/10/10 <u>5-10-10</u>	TI <u>APBS</u>	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001923200 T/S: 05/07/2010 12:46 PM VBROWN -----
R427 02	5/10/10 <u>5-10-10</u>	TI <u>✓</u>	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001923192 T/S: 05/07/2010 12:46 PM VBROWN -----

COMMENTS AND NOTES

ADDRESS : 940 WILBURN RD SUBDIV: DIVISION OF W L SENTER ESTATE  
 CONTRACTOR : PHONE :  
 OWNER : BARBOUR TOMMY W& CRYSTAL H PHONE :  
 PARCEL : 08-0641- - -0012- -02-  
 APPL NUMBER: 09-50023177 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 11/03/2009 10:57 AM RDCONTE ---  
 KATHY ADAMS #2A / WILBURN ROAD TAKE  
 401 TO FOUR WAY INTOERSECTIN. T/L GO  
 NORTH ON 401.T/L ON WILBURN ROAD. GOTO  
 END OF WILBURN LOT 2Z WILL BE ON THE  
 RIGHT  
 \*\*\*PWR CO: WAITING ON CUS\*\*\*  
 T/S: 03/19/2010 11:05 AM NTART -----  
 PREMISE NUMBER 30024309\*\*\*\*\*

**STRUCTURE: 000 000 67.6X74 CRAWL 3BD/2BA W/GAR, PATIO**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/10/10 3/10/10	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892642 1. Left side and rear of footings are less than 12 inches below grade. T/S: March 10, 2010 11:33 AM BSUTTON ----- went back, problems corrected
B103 01	3/19/10 3/19/10	BS AE	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001896695 T/S: 03/17/2010 03:07 PM NTART ----- TSP IS READY..... Damproof exterior of foundation from footing up to final grade height. Leave exterior open, will check at open floor
A814 01	3/24/10 3/30/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001898980 T/S: 03/23/2010 12:00 PM RDCONTE ----- ✓ 940 WILBURN RD ----- FUQUAY VARINA 27526 T/S: 03/30/2010 03:56 PM TWARD -----
B105 01	3/24/10 3/24/10	KS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001898972 T/S: 03/23/2010 12:00 PM RDCONTE ----- NEEDS INSPECTION AFTER 2:00PM
R427 01	4/29/10 4/30/10	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001917681 1. Complete firecaulk on interior walls. 2. Staple range wire up under house. OK to insulate
I129 01	5/10/10 5/10/10	BS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001923200 T/S: 05/07/2010 12:46 PM VBROWN ----- T/S: May 10, 2010 10:19 AM BSUTTON -----
R427 02	5/10/10 5/10/10	BS AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001923192 T/S: 05/07/2010 12:46 PM VBROWN ----- T/S: May 10, 2010 10:19 AM BSUTTON -----
H824 01	6/23/10 6/23/10	JM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001945930 T/S: 06/24/2010 08:52 AM SZIMMER ----- T/S: 06/24/2010 08:53 AM SZIMMER -----
R431 01	6/25/10 <u>6-25-10</u>	TI <u>DABS</u>	FOUR TRADE FINAL >2500 VRU #: 001945963 WOULD LIKE THIS IN THE MORNING AS EARLY AS POSSIBLE,

ADDRESS : 940 WILBURN RD SUBDIV: DIVISION OF W L SENTER ESTATE  
 CONTRACTOR : PHONE :  
 OWNER : BARBOUR TOMMY W& CRYSTAL H PHONE :  
 PARCEL : 08-0641- - -0012- -02-  
 APPL NUMBER: 09-50023177 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 11/03/2009 10:57 AM RDCONTE ---  
 KATHY ADAMS #2A / WILBURN ROAD TAKE  
 401 TO FOUR WAY INTOERSECTIN. T/L GO  
 NORTH ON 401.T/L ON WILBURN ROAD. GOTO  
 END OF WILBURN LOT 2Z WILL BE ON THE  
 RIGHT  
 \*\*\*PWR CO: WAITING ON CUS\*\*\*  
 T/S: 03/19/2010 11:05 AM NTART -----  
 PREMISE NUMBER 30024309\*\*\*\*\*

**STRUCTURE: 000 000 67.6X74 CRAWL 3BD/2BA W/GAR, PATIO**

FLOOD ZONE . . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
 SEPTIC - EXISTING? . . . . . : NEW WATER SUPPLY . . . . . : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/10/10 3/10/10	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001892642 1. Left side and rear of footings are less than 12 inches below grade. T/S: March 10, 2010 11:33 AM BSUTTON ----- went back, problems corrected
B103 01	3/19/10 3/19/10	BS AE	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001896695 T/S: 03/17/2010 03:07 PM NTART ----- TSP IS READY..... Damproof exterior of foundation from footing up to final grade height. Leave exterior open, will check at open floor
A814 01	3/24/10 3/30/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001898980 T/S: 03/23/2010 12:00 PM RDCONTE ----- ✓ 940 WILBURN RD ----- FUQUAY VARINA 27526 T/S: 03/30/2010 03:56 PM TWARD -----
B105 01	3/24/10 3/24/10	KS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 001898972 T/S: 03/23/2010 12:00 PM RDCONTE ----- NEEDS INSPECTION AFTER 2:00PM
R427 01	4/29/10 4/30/10	BS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001917681 1. Complete firecaulk on interior walls. 2. Staple range wire up under house. OK to insulate
I129 01	5/10/10 5/10/10	BS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 001923200 T/S: 05/07/2010 12:46 PM VBROWN ----- T/S: May 10, 2010 10:19 AM BSUTTON -----
R427 02	5/10/10 5/10/10	BS AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001923192 T/S: 05/07/2010 12:46 PM VBROWN ----- T/S: May 10, 2010 10:19 AM BSUTTON -----
H824 01	6/23/10 6/23/10	JM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001945930 T/S: 06/24/2010 08:52 AM SZIMMER ----- T/S: 06/24/2010 08:53 AM SZIMMER -----
R431 01	6/25/10 6/25/10	BS DA	FOUR TRADE FINAL >2500 VRU #: 001945963 WOULD LIKE THIS IN THE MORNING AS EARLY AS POSSIBLE,



PREPARED 6/28/10, 13:59:34  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 15  
DATE 6/29/10

ADDRESS : 940 WILBURN RD  
CONTRACTOR :  
OWNER : BARBOUR TOMMY W& CRYSTAL H  
PARCEL : 08-0641- - -0012- -02-  
APPL NUMBER: 09-50023177 CP NEW RESIDENTIAL (SFD)

SUBDIV: DIVISION OF W L SENTER ESTATE  
PHONE :  
PHONE :

REQUESTED INSP DESCRIPTION  
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

R431 02 6/29/10 TT  
*6-29-10* *APBS* 1. Need address posted on house. 2. Range breaker shall be  
50 amp max 3. Need a receptacle for condensate pump, and  
pump control must be wired to unit. 4. Garage doors must be  
up for final inspection. 5. Need a disconnect or breaker  
lock on water heater.  
FOUR TRADE FINAL >2500 VRU #: 001946979  
NEED INSPECTION AFTER LUNCH

----- COMMENTS AND NOTES -----

**County of Harnett  
Building Inspections Department  
Planning Services**

**Certificate of Compliance: \_\_\_ Occupancy: X**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

**Permit Numbers**

Name: Tommy W & Crystal H Barbour

Building: 09-50023177

Electrical: 09-50023177

Address: 940 Wilburn Road

Insulation: 09-50023177

Fuquay Varina NC 27526

Plumbing: 09-50023177

Mechanical: 09-50023177

MFG Home: NA NA NA NA

Date: 06-29-10

Building Official: BSutton