

ADDRESS : 10 BOULDER DR
CONTRACTOR : DUSTIN BLACKWELL, INC
OWNER : DIVERSIFIED HOLDINGS LLC
PARCEL : 03-9587-13- -0020- -19-
APPL NUMBER: 09-50023256 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 11/13/2009 10:48 AM RDCONTIE ---
15 BOULDER / THE SUMMITT PH:3 #99
TAKE 27W. T/L ON BUFFALO LAKE ROAD. T/L
INTO THE SUMMITT. T/R ON CASTLE ROCK.
T/R ON BOULDER. LOT IS ON THE RIGHT.
CENTRAL ELECTRIC
T/S: 11/13/2009 03:50 PM DJOHNSON --

SUBDIV: THE SUMMIT SEC3 50 LOTS
PHONE : (919) 606-4696
PHONE :

STRUCTURE: 000 000 46X53 CRAWL 3BD/2.5BA W/GAR,DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/06/10 <u>1-6-10</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001867787

COMMENTS AND NOTES

ADDRESS : 10 BOULDER DR
CONTRACTOR : DUSTIN BLACKWELL, INC
OWNER : DIVERSIFIED HOLDINGS LLC
PARCEL : 03-9587-13- -0020- -19-
APPL NUMBER: 09-50023256 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 11/13/2009 10:48 AM RDCONTE ---
15 BOULDER / THE SUMMITT PH:3 #99
TAKE 27W. T/L ON BUFFALO LAKE ROAD. T/L
INTO THE SUMMITT. T/R ON CASTLE ROCK.
T/R ON BOULDER. LOT IS ON THE RIGHT.
CENTRAL ELECTRIC
T/S: 11/13/2009 03:50 PM DJOHNSON --

SUBDIV: THE SUMMIT SEC3 50 LOTS
PHONE : (919) 606-4696
PHONE :

STRUCTURE: 000 000 46X53 CRAWL 3BD/2.5BA W/GAR, DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001867787
	1/06/10	AP	T/S: 01/06/2010 12:30 PM MREARIC
A814 01	1/13/10	TI	ADDRESS CONFIRMATION VRU #: 001869890
B103 01	1/13/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001869908

1-13-10 AP-MR

COMMENTS AND NOTES

ADDRESS . : 10 BOULDER DR
 CONTRACTOR : DUSTIN BLACKWELL, INC
 OWNER . . : DIVERSIFIED HOLDINGS LLC
 PARCEL . . : 03-9587-13- -0020- -19-
 APPL NUMBER: 09-50023256 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 11/13/2009 10:48 AM RDCONTE ---
 15 BOULDER / THE SUMMITT PH:3 #99
 TAKE 27W. T/L ON BUFFALO LAKE ROAD. T/L
 INTO THE SUMMITT. T/R ON CASTLE ROCK.
 T/R ON BOULDER. LOT IS ON THE RIGHT.
 CENTRAL ELECTRIC
 T/S: 11/13/2009 03:50 PM DJOHNSON --

STRUCTURE: 000 000 46X53 CRAWL 3BD/2.5BA W/GAR, DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001867787
	1/06/10	AP	T/S: 01/06/2010 12:30 PM MREARIC -----
A814 01	1/13/10	FB	ADDRESS CONFIRMATION VRU #: 001869890
	1/13/10	AP	T/S: 01/13/2010 11:09 AM FBURGESS ----- 10 BOULDER DR SANFORD, NC 27332 LOT 99
B103 01	1/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001869908
	1/13/10	AP	T/S: 01/13/2010 11:31 AM MREARIC -----
B105 01	1/14/10	TI	R*OPEN FLOOR VRU #: 001870641

1-14-10 AP-MR

COMMENTS AND NOTES

ADDRESS . . : 10 BOULDER DR
CONTRACTOR : DUSTIN BLACKWELL, INC
OWNER . . . : DIVERSIFIED HOLDINGS LLC
PARCEL . . . : 03-9587-13- -0020- -19-
APPL NUMBER: 09-50023256 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 11/13/2009 10:48 AM RDCONTE ---
15 BOULDER / THE SUMMITT PH:3 #99
TAKE 27W. T/L ON BUFFALO LAKE ROAD. T/L
INTO THE SUMMITT. T/R ON CASTLE ROCK.
T/R ON BOULDER. LOT IS ON THE RIGHT.
CENTRAL ELECTRIC
T/S: 11/13/2009 03:50 PM DJOHNSON --

SUBDIV: THE SUMMIT SEC3 50 LOTS
PHONE : (919) 606-4696
PHONE :

STRUCTURE: 000 000 46X53 CRAWL 3BD/2.5BA W/GAR, DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001867787
	1/06/10	AP	T/S: 01/06/2010 12:30 PM MREARIC
A814 01	1/13/10	FB	ADDRESS CONFIRMATION VRU #: 001869890
	1/13/10	AP	T/S: 01/13/2010 11:09 AM FBURGESS 10 BOULDER DR SANFORD, NC 27332 LOT 99
B103 01	1/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001869908
	1/13/10	AP	T/S: 01/13/2010 11:31 AM MREARIC
B105 01	1/14/10	MR	R*OPEN FLOOR VRU #: 001870641
	1/14/10	AP	T/S: 01/14/2010 12:19 PM MREARIC
R427 01	1/26/10	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001874478
	<u>1-26-10</u>	<u>DAJH</u>	

COMMENTS AND NOTES

ADDRESS : 10 BOULDER DR SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : DIVERSIFIED HOLDINGS LLC PHONE :
 PARCEL : 03-9587-13- -0020- -19-
 APPL NUMBER: 09-50023256 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 11/13/2009 10:48 AM RDCONTE ---
 15 BOULDER / THE SUMMITT PH:3 #99
 TAKE 27W. T/L ON BUFFALO LAKE ROAD. T/L
 INTO THE SUMMITT. T/R ON CASTLE ROCK.
 T/R ON BOULDER. LOT IS ON THE RIGHT.
 CENTRAL ELECTRIC
 T/S: 11/13/2009 03:50 PM DJOHNSON --

STRUCTURE: 000 000 46X53 CRAWL 3BD/2.5BA W/GAR,DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001867787
	1/06/10	AP	T/S: 01/06/2010 12:30 PM MREARIC -----
A814 01	1/13/10	FB	ADDRESS CONFIRMATION VRU #: 001869890
	1/13/10	AP	T/S: 01/13/2010 11:09 AM FBURGESS ----- 10 BOULDER DR SANFORD, NC 27332 LOT 99
B103 01	1/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001869908
	1/13/10	AP	T/S: 01/13/2010 11:31 AM MREARIC -----
B105 01	1/14/10	MR	R*OPEN FLOOR VRU #: 001870641
	1/14/10	AP	T/S: 01/14/2010 12:19 PM MREARIC -----
R427 01	1/26/10	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001874478
	1/26/10	DA	1)Window @ master bath tub needs to be tempered by final. 2)Missing duct work for half bath exhaust fan. 3)Missing nails in floor truss hangers in garage.-
I129 01	1/28/10	TI	R*INSULATION INSPECTION VRU #: 001876952
	<u>1/28/10</u>	<u>AP-MR</u>	
R427 02	1/28/10	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001876937
	<u>1/28/10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : 10 BOULDER DR
CONTRACTOR : DUSTIN BLACKWELL, INC
OWNER : DIVERSIFIED HOLDINGS LLC
PARCEL : 03-9587-13- -0020- -19-
APPL NUMBER: 09-50023256 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 11/13/2009 10:48 AM RDCONTE ---
15 BOULDER / THE SUMMITT PH:3 #99
TAKE 27W. T/L ON BUFFALO LAKE ROAD. T/L
INTO THE SUMMITT. T/R ON CASTLE ROCK.
T/R ON BOULDER. LOT IS ON THE RIGHT.
CENTRAL ELECTRIC
T/S: 11/13/2009 03:50 PM DJOHNSON --

SUBDIV: THE SUMMIT SEC3 50 LOTS
PHONE : (919) 606-4696
PHONE :

STRUCTURE: 000 000 46X53 CRAWL 3BD/2.5BA W/GAR, DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001867787
	1/06/10	AP	T/S: 01/06/2010 12:30 PM MREARIC
A814 01	1/13/10	FB	ADDRESS CONFIRMATION VRU #: 001869890
	1/13/10	AP	T/S: 01/13/2010 11:09 AM FBURGESS 10 BOULDER DR SANFORD, NC 27332 LOT 99
B103 01	1/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001869908
	1/13/10	AP	T/S: 01/13/2010 11:31 AM MREARIC
B105 01	1/14/10	MR	R*OPEN FLOOR VRU #: 001870641
	1/14/10	AP	T/S: 01/14/2010 12:19 PM MREARIC
R427 01	1/26/10	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001874478
	1/26/10	DA	1)Window @ master bath tub needs to be tempered by final. 2)Missing duct work for half bath exhaust fan. 3)Missing nails in floor truss hangers in garage.-
I129 01	1/28/10	MR	R*INSULATION INSPECTION VRU #: 001876952
	1/28/10	AP	T/S: 01/28/2010 01:44 PM MREARIC
R427 02	1/28/10	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001876937
	1/28/10	AP	T/S: 01/28/2010 01:44 PM MREARIC
H824 01	2/08/10	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001881457
	2/08/10	AP	T/S: 02/10/2010 10:32 AM SSTEWARD
			T/S: 02/10/2010 10:38 AM SSTEWARD
R431 01	3/01/10	TI	FOUR TRADE FINAL >2500 VRU #: 001888411

3-1-10 DP MR

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 03-01-10

PERMIT # 09-50023256

ADDRESS: 10 boulder

VIOLATIONS:

1. Plastic (6mil) must cover all soil under house
2. Provide ladder for attic inspection

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 10 BOULDER DR SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : DUSTIN BLACKWELL, INC PHONE : (919) 606-4696
 OWNER : DIVERSIFIED HOLDINGS LLC PHONE :
 PARCEL : 03-9587-13- -0020- -19-
 APPL NUMBER: 09-50023256 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 11/13/2009 10:48 AM RD CONTE ---
 15 BOULDER / THE SUMMITT PH:3 #99
 TAKE 27W. T/L ON BUFFALO LAKE ROAD. T/L
 INTO THE SUMMITT. T/R ON CASTLE ROCK.
 T/R ON BOULDER. LOT IS ON THE RIGHT.
 CENTRAL ELECTRIC
 T/S: 11/13/2009 03:50 PM DJOHNSON --

STRUCTURE: 000 000 46X53 CRAWL 3BD/2.5BA W/GAR, DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/06/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001867787
	1/06/10	AP	T/S: 01/06/2010 12:30 PM MREARIC -----
A814 01	1/13/10	FB	ADDRESS CONFIRMATION VRU #: 001869890
	1/13/10	AP	T/S: 01/13/2010 11:09 AM FBURGESS ----- 10 BOULDER DR SANFORD, NC 27332 LOT 99
B103 01	1/13/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001869908
	1/13/10	AP	T/S: 01/13/2010 11:31 AM MREARIC -----
B105 01	1/14/10	MR	R*OPEN FLOOR VRU #: 001870641
	1/14/10	AP	T/S: 01/14/2010 12:19 PM MREARIC -----
R427 01	1/26/10	JH	FOUR TRADE ROUGH IN >2500 VRU #: 001874478
	1/26/10	DA	1) Window @ master bath tub needs to be tempered by final. 2) Missing duct work for half bath exhaust fan. 3) Missing nails in floor truss hangers in garage.-
I129 01	1/28/10	MR	R*INSULATION INSPECTION VRU #: 001876952
	1/28/10	AP	T/S: 01/28/2010 01:44 PM MREARIC -----
R427 02	1/28/10	MR	FOUR TRADE ROUGH IN >2500 VRU #: 001876937
	1/28/10	AP	T/S: 01/28/2010 01:44 PM MREARIC -----
H824 01	2/08/10	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001881457
	2/08/10	AP	T/S: 02/10/2010 10:32 AM S STEWART ----- T/S: 02/10/2010 10:38 AM S STEWART -----
R431 01	3/01/10	MR	FOUR TRADE FINAL >2500 VRU #: 001888411
	3/01/10	DP	T/S: 03/01/2010 09:56 AM MREARIC ----- 1. provide ladder for attic access 2. 6 mil plastic must be everywhere under house
R431 02	3/02/10	TI	FOUR TRADE FINAL >2500 VRU #: 001889021

3-2-10 AP-ME

COMMENTS AND NOTES

**COUNTY OF HARNETT
DEPARTMENT OF BUILDING INSPECTION
AND PLANNING/DEVELOPMENT
CERTIFICATE OF OCCUPANCY**

This certificate issued pursuant to the requirements of Section 105 of the North Carolina State Building Code and the Harnett County Zoning Ordinance certifies at the time of issuance this structure was in compliance with the various ordinances of the County of Harnett regulating development and building construction or use. For the following:

Use Classification: <u>R-3</u>	Conditional Use Permit No.: _____
Type of Construction: <u>R</u>	Building Permit No.: <u>09-50023256</u>
Owner of Building: <u>Div. certified Holding</u>	Electrical Permit No.: <u>11</u>
Building Address: <u>10 Boulder</u>	Insulation Permit No.: <u>11</u>
Zoning District: _____	Plumbing Permit No.: <u>11</u>
Zoning Permit No.: _____	Mech. Permit No.: <u>3</u>
Date: <u>3-2-10</u>	Envir. C.O. No.: _____
<u>T. Mark Ream</u> Building Official	_____ Zoning Official