

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:

Address: Date Evaluated: 11/20/09
 Proposed Facility: 3 @ 2000 LHM L Design Flow (.1949): 360 gpd

Property Size:

Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-3%0	0-28"	G S	VFR NSHP					S 8
2		0-48"	G S	VFR NSHP					S 8

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): S Evaluated By: [Signature] Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	8	8	