

HTE# 09-S-2332RR

Harnett County Department of Public Health

26029

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: CAVINESS LAND DEV. PROPERTY LOCATION: NURSERY RD
 SUBDIVISION FOREST OAKS LOT # 184
 NEW REPAIR EXPANSION
 Type of Structure: SFD (50'x51') Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: Pump To 95% REDUCTION
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well 100 feet Permit valid for: Five years
 Permit conditions: No expiration

Authorized State Agent: [Signature] PCAS Date: 5/3/10 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: CAVINESS LAND DEV. PROPERTY LOCATION: NURSERY RD
 SUBDIVISION FOREST OAKS LOT # 184
 Facility Type: SFD (50'x51') New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** Pump To 25% REDUCTION (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable) Pump To 25% REDUCTION (Repair)

Installation Requirements/Conditions
 Septic Tank Size 1000 gallons
 Pump Tank Size 1000 gallons
 Number of trenches 1
 Exact length of each trench 300 feet
 Trenches shall be installed on contour at a
 Maximum Trench Depth of: 18 inches
 (Trench bottoms shall be level to +/-1/4" in all directions)
 Trench Spacing: 9 Feet on Center
 Soil Cover: 6 inches
 (Maximum soil cover shall not exceed 36" above the trench bottom)
 Pump Requirements: _____ ft. TDH vs. _____ GPM
 Aggregate Depth: _____ inches below pipe
 _____ inches above pipe
 _____ inches total
 Conditions: WATER LINE & POWER LINE MUST BE 10' FROM SEPTIC SYSTEM. PERMIT BASED ON PROPOSAL FROM APPLICANT'S SOIL CONSULTANT

****If applicable:** I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] PCAS Date: 5/3/10
 Construction Authorization Expiration Date: 5/3/15

HTE# 09-5-23332RR

Permit # 26029

Harnett County Department of Public Health Site Sketch

ISSUED TO: CAVINNESS LAND DEV. PROPERTY LOCATOR: NURSEY RD
SUBDIVISION FOREST OAKS LOT # 184

Authorized State Agent: [Signature] REMS (OLIVER TOLKSPON) Date: 5/3/10

