

COMMENTS:

Well app. not att'd
sgp

New Horizons Bldg - 09-5-23347

12/23/2009 Bm Spoke with Mr. Pugh about the lot on

Brinkly Rd. & explained that because of all the recent rain the

lot was too wet to evaluate. We will go back to the lot

after some time of dry weather

Tried to call
unavailable 2:34 pm
12/23/09

Central Carolina Soils

cell 919-235-2843

Private Consultant - Alex Adams - 919-784-9441

Call Chris Pugh after speaking w/ Alex.

App. noted in
HTE & disapproved

6/14/2010 Checked tanks & discolored installation of system w/
contractor. Repair area ~~disturbed~~ disturbed, still has 18"
of soil before wetness (chrome 2) observed

COMMENTS:

8/25/2010

Met with Jay Siker + Amanda Bader on 102 Brinkley Rd.

+ discussed drainage issues with owner. Also talked about the septic system. I let the owner know that I did not think they should have a problem with it unless water ponded over the tanks.

11/8/2010 BM Application for a building was prepared by Timothy Hart. Visit was made on 11/5 + then again on 11/8/2010. Application must be denied due to site limitation (repair area 90x100 in backyard)

Building site prepared in area for repair. Building could be moved to other side of property 10 ft from side property line + be out of the repair area, however the supply line from the pump tank to initial drain field would ~~need~~ need to be located.

11/12/2010 BM Spoke w/ Mr. Hart + told him that if the building ^{did} not have a permanent foundation + the soil was not disturbed I would allow the building to go in the repair area.