

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 1/7/10
 Proposed Facility: 3 Bedroom Design Flow (.1949): 360 gpd
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-10%	0-28"	G S	VFR NS/NP					S 8
2		0-38"	G S	VFR NS/NP					
		38-48"	SBX 5/8 CL	FR SS/SP					P5.6
3		0-38"	G S	VFR NS/NP					
		38-48"	SBX 5/8 CL	FR SS/SP					P3 .6

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P5 Evaluated By: OT Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	.6	8	

1200' @ 24"