Department of Environment, Health and Natural Resources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated: 12/21/09
Proposed Facility: 4 BEDROOMS Design Flow (.1949): 480 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS CV/CV	0-22"	G S	VFR NS/NP					
	7-10%	22-32"	SBK SCL	FR SS/SP					PS.5
"		32-48"	G SL	VFR NS/NP					
2		0-6"	G S	VFR NS/NP					
		6"+	M C	FI	CR2 @ 6"				US
3		0-40"	G S	VFR NS/NP					
		40"+	SBK SCL	FR SS/SP					PS.45
4		0-24"	G S	VFR NS/NP					
		24-40"	G S	VFR NS/NP					
		40"+	SBK FINE SCL	FR SS/SP					PS.45
5		0-22"	G S	VFR NS/NP					
		22-48"	SBK SCL	FR SS/SP	CR2 @ 36"				PS.45
6		0-24"	G S	VFR NS/NP					
		24-39"+	SBK SCL	FR SS/SP					PS.45

Description	Initial System	Repair System
Available Space (.1945)		
System Type(s)		
Site LTAR		

Other Factors (.1946):
Site Classification (.1948):
Evaluated By: OT
Others Present: