

PREPARED 2/11/10, 14:01:31

Harnett County

SUBDIV: PERSIMMON HILL 83LOTS

ADDRESS 405 OLD FIELD LOOP

CONTRACTOR: WM KENT PIRCE INC.

OWNER: WM KENT PIRCE INC.

PARCEL: 03-9577-0028-54

APPL NUMBER: 09-50023492 CP NEW RESIDENTIAL (SFD)

DIRECTIONS: T/S: 12/29/2009 08:46 AM RDCONTE ---

PERSIMMON HILL #54

TAKE 27 T/R ON HANOVER RD. T/L ON TRAIL

RIDER LANE, T/L ON OLD FIELD LANE, LOT

IS ON THE RIGHT

PWR CO: WAITING ON CUS

STRUCTURE: 000 000 37X51 CRAWL 3RD/2.5HA W/GAR & DECK

FLOOD ZONE

FLOOD ZONE X

BEDROOMS 3.00

PROPOSED USE

SEPTIC - EXISTING? NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSS 00 CP * SFD

REQUESTED INSP

DESCRIPTION

TYP/SQ COMPLETED RESULT

RESULTS/COMMENTS

B101 01

1/27/10

DT

R*BLDG FOOTING / TEMP SVC POLE VRU #: 001876296

B103 01

2/05/10

FS

R*BLDG FOUND & TEMP SVC POLE VRU #: 001879881

A814 01

2/10/10

TI

ADDRESS CONFIRMATION VRU #: 001879890

B105 01

2/12/10

TI

R*OPEN FLOOR VRU #: 001882038

COMMENTS AND NOTES

[Handwritten signatures and dates]

ADDRESS : 405 OLD FIELD LOOP SUBDIV: PERSIMMON HILL 83LOTS
CONTRACTOR : WM KENT PIERCE INC. PHONE :
OWNER : WM KENT PIERCE INC PHONE : (910) 391-0194
PARCEL : 03-9577- - -0028- -54-
APPL NUMBER: 09-50023492 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 12/29/2009 08:46 AM RDCONTE ---
PERSIMMON HILL #54
TAKE 27 T/R ON HANOVER RD. T/L ON TRAIL
RIDER LANE. T/L ON OLD FIELD LANE. LOT
IS ON THE RIGHT.
PWR CO: WAITING ON CUS

STRUCTURE: 000 000 37X51 CRAWL 3BD/2.5BA W/GAR & DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/27/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001876296
	1/27/10	AP	
B103 01	2/05/10	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001879881
	2/08/10	AP	T/S: 02/08/2010 03:36 PM FSPIVEY -----
A814 01	2/10/10	FB	ADDRESS CONFIRMATION VRU #: 001879890
	2/18/10	AP	T/S: 02/18/2010 02:36 PM FBURGESS ----- 405 OLD FIELD LOOP SANFORD, NC 27332 LOT 54
B105 01	2/12/10	FS	R*OPEN FLOOR VRU #: 001882038
	2/12/10	AP	T/S: 02/12/2010 01:05 PM FSPIVEY -----
R425 01	3/25/10	TI	FOUR TRADE ROUGH IN VRU #: 001899459

3-25-10 OA JV

COMMENTS AND NOTES

ADDRESS : 405 OLD FIELD LOOP
CONTRACTOR : WM KENT PIERCE INC.
OWNER : WM KENT PIERCE INC
PARCEL : 03-9577- - -0028- -54-
APPL NUMBER: 09-50023492 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 12/29/2009 08:46 AM RDCONTE ---
PERSIMMON HILL #54
TAKE 27 T/R ON HANOVER RD. T/L ON TRAIL
RIDER LANE. T/L ON OLD FIELD LANE. LOT
IS ON THE RIGHT.
PWR CO: WAITING ON CUS

SUBDIV: PERSIMMON HILL 83LOTS
PHONE :
PHONE : (910) 391-0194

STRUCTURE: 000 000 37X51 CRAWL 3BD/2.5BA W/GAR & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/27/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001876296
	1/27/10	AP	
B103 01	2/05/10	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001879881
	2/08/10	AP	T/S: 02/08/2010 03:36 PM FSPIVEY -----
A814 01	2/10/10	FB	ADDRESS CONFIRMATION VRU #: 001879890
	2/18/10	AP	T/S: 02/18/2010 02:36 PM FBURGESS ----- 405 OLD FIELD LOOP SANFORD, NC 27332 LOT 54
B105 01	2/12/10	FS	R*OPEN FLOOR VRU #: 001882038
	2/12/10	AP	T/S: 02/12/2010 01:05 PM FSPIVEY -----
R425 01	3/25/10	JH	FOUR TRADE ROUGH IN VRU #: 001899459
	3/25/10	DA	1)Need receptacle on front of house accessable from grade. 2)Nail all lvls & 3ply truss per drawings throughout house. 3)Bond faucet to tub in master bath & roughin receptacle @ tub in master bath. 4)Support drain line per code every 4' under house. 5) Replace cut floor joist under half bath.
I129 01	3/29/10	TI	R*INSULATION INSPECTION VRU #: 001900928
	<u>3-29-10</u>	<u>AP-MR</u>	
R425 02	3/29/10	TI	FOUR TRADE ROUGH IN VRU #: 001900919
	<u>3-29-10</u>	<u>AP-MR</u>	


COMMENTS AND NOTES


ADDRESS : 405 OLD FIELD LOOP SUBDIV: PERSIMMON HILL 83LOTS
 CONTRACTOR : WM KENT PIERCE INC. PHONE :
 OWNER : WM KENT PIERCE INC PHONE : (910) 391-0194
 PARCEL : 03-9577- - -0028- -54-
 APPL NUMBER: 09-50023492 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 12/29/2009 08:46 AM RDCONTE ---
 PERSIMMON HILL #54
 TAKE 27 T/R ON HANOVER RD. T/L ON TRAIL
 RIDER LANE. T/L ON OLD FIELD LANE. LOT
 IS ON THE RIGHT.
 PWR CO: WAITING ON CUS

STRUCTURE: 000 000 37X51 CRAWL 3BD/2.5BA W/GAR & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/27/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001876296
	1/27/10	AP	
B103 01	2/05/10	FS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001879881
	2/08/10	AP	T/S: 02/08/2010 03:36 PM FSPIVEY -----
A814 01	2/10/10	FB	ADDRESS CONFIRMATION VRU #: 001879890
	2/18/10	AP	T/S: 02/18/2010 02:36 PM FBURGESS ----- ✓ 405 OLD FIELD LOOP SANFORD, NC 27332 LOT 54
B105 01	2/12/10	FS	R*OPEN FLOOR VRU #: 001882038
	2/12/10	AP	T/S: 02/12/2010 01:05 PM FSPIVEY -----
R425 01	3/25/10	JH	FOUR TRADE ROUGH IN VRU #: 001899459
	3/25/10	DA	1)Need receptacle on front of house accessible from grade. 2)Nail all lvls & 3ply truss per drawings throughout house. 3)Bond faucet to tub in master bath & roughin receptacle @ tub in master bath. 4)Support drain line per code every 4' under house. 5) Replace cut floor joist under half bath.
I129 01	3/29/10	MR	R*INSULATION INSPECTION VRU #: 001900928
	3/29/10	AP	T/S: 03/29/2010 12:21 PM MREARIC -----
R425 02	3/29/10	MR	FOUR TRADE ROUGH IN VRU #: 001900919
	3/29/10	AP	T/S: 03/29/2010 12:21 PM MREARIC -----
H824 01	5/17/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001928365
	5/17/10	AP	T/S: 05/18/2010 09:38 AM SSTEWARD ----- T/S: 05/18/2010 09:38 AM SSTEWARD -----
R429 01	5/20/10	TF	FOUR TRADE FINAL VRU #: 001929453

5-25-10


P.F.
11:28
5-20-10


COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: Occupancy: ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: ✓ Home

Name: KENT PIERCE

Address: 405 Old Loop

Camden Sanford 27332

Date: 5-20-10

Building Official: [Signature]

Permit Numbers

Building: 95-23492

Electrical: 95-23492

Insulation: 95-23492

Plumbing: 95-23492

Mechanical: 95-23492

MFG Home: