
ADDRESS . . : 158 WINGED FOOT DR
 CONTRACTOR : MOSS KENNETH A
 OWNER . . . : EVEN PAR DEVELOPMENT LLC
 PARCEL . . . : 01-0525- - -0062- -17-
 APPL NUMBER: 10-50023546 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/09/2010 07:26 PM VBROWN ----
 158 WINGED FOOT DRIVE, WALNUT GROVE SUB
 DIV #8. 210S, LEFT ON LASATER RD, LEFT
 INTO WALNUT GROVE DRIVE, LEFT ON WINGED
 FOOT DRIVE, LOT ON RIGHT.

STRUCTURE: 000 000 46X55 3BDR 2.5BATH SFD WITH GAR, DECK, CWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW SEPTIC

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10 <u>3-8</u>	TI <u>AP</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001891466

----- COMMENTS AND NOTES -----

ADDRESS . . : 158 WINGED FOOT DR SUBDIV: WALNUT GROVE 37LOTS
 CONTRACTOR : MOSS KENNETH A PHONE : (910) 893-4875
 OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
 PARCEL . . : 01-0525- - -0062- -17-
 APPL NUMBER: 10-50023546 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/09/2010 07:26 PM VBROWN ----
 158 WINGED FOOT DRIVE, WALNUT GROVE SUB
 DIV #8. 210S, LEFT ON LASATER RD, LEFT
 INTO WALNUT GROVE DRIVE, LEFT ON WINGED
 FOOT DRIVE, LOT ON RIGHT.

STRUCTURE: 000 000 46X55 3BDR 2.5BATH SFD WITH GAR, DECK, CWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10 3/08/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001891466
B103 01	3/18/10 3/18/10	DT AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001896602
B105 01	3/25/10 <u>3/25/10</u>	TI <u>AP DT</u>	R*OPEN FLOOR VRU #: 001899253

----- COMMENTS AND NOTES -----

ADDRESS . . : 158 WINGED FOOT DR SUBDIV: WALNUT GROVE 37LOTS
CONTRACTOR : MOSS KENNETH A PHONE : (910) 893-4875
OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
PARCEL . . : 01-0525- - -0062- -17-
APPL NUMBER: 10-50023546 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/09/2010 07:26 PM VBROWN ----
158 WINGED FOOT DRIVE, WALNUT GROVE SUB
DIV #8. 210S, LEFT ON LASATER RD, LEFT
INTO WALNUT GROVE DRIVE, LEFT ON WINGED
FOOT DRIVE, LOT ON RIGHT.

STRUCTURE: 000 000 46X55 3BDR 2.5BATH SFD WITH GAR, DECK, CWL
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001891466
	3/08/10	AP	
B103 01	3/18/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001896602
	3/18/10	AP	
B105 01	3/25/10	DT	R*OPEN FLOOR VRU #: 001899253
	3/25/10	AP	
R425 01	4/20/10	TI	FOUR TRADE ROUGH IN VRU #: 001912328
	<u>4/20/10</u>	<u>DA Df</u>	
A814 01	4/20/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001912310
	4/19/10	AP	T/S: 04/19/2010 08:16 AM VBROWN ----- T/S: 04/19/2010 10:27 AM FBURGESS ----- 158 WINGED FOOT DR BUNNLEVEL, NC 28323 LOT 8

----- COMMENTS AND NOTES -----

 ADDRESS . : 158 WINGED FOOT DR SUBDIV: WALNUT GROVE 37LOTS
 CONTRACTOR : MOSS KENNETH A PHONE : (910) 893-4875
 OWNER . . : EVEN PAR DEVELOPMENT LLC PHONE :
 PARCEL . . : 01-0525- - -0062- -17-
 APPL NUMBER: 10-50023546 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/09/2010 07:26 PM VBROWN ----
 158 WINGED FOOT DRIVE, WALNUT GROVE SUB
 DIV #8. 210S, LEFT ON LASATER RD, LEFT
 INTO WALNUT GROVE DRIVE, LEFT ON WINGED
 FOOT DRIVE, LOT ON RIGHT.

STRUCTURE: 000 000 46X55 3BDR 2.5BATH SFD WITH GAR, DECK, CWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001891466
	3/08/10	AP	
B103 01	3/18/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001896602
	3/18/10	AP	
B105 01	3/25/10	DT	R*OPEN FLOOR VRU #: 001899253
	3/25/10	AP	
R425 01	4/20/10	DT	FOUR TRADE ROUGH IN VRU #: 001912328
	4/20/10	DA	1. Window within 24 inches of rear door must be tempered. 2. No gas pressure. 3. Plumbing boots missing. 4. Front door not installed. Okay to side and insulate. T/S: 04/20/2010 12:47 PM DETAYLOR -----
A814 01	4/20/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001912310
	4/19/10	AP	T/S: 04/19/2010 08:16 AM VBROWN ----- T/S: 04/19/2010 10:27 AM FBURGESS ----- 158 WINGED FOOT DR BUNNLEVEL, NC 28323 LOT 8
I129 01	4/23/10	TI	R*INSULATION INSPECTION VRU #: 001914852
	<u>4/23/10</u>	<u>AP DT</u>	
R327 01	4/23/10	TI	THREE TRADE ROUGH IN >2500 VRU #: 001914837
	<u>4/23/10</u>	<u>AP DT</u>	If tempered window is not changed by inspection it will be done by siding guy and before final

----- COMMENTS AND NOTES -----

ADDRESS . . : 158 WINGED FOOT DR SUBDIV: WALNUT GROVE 37LOTS
 CONTRACTOR : MOSS KENNETH A PHONE : (910) 893-4875
 OWNER . . . : EVEN PAR DEVELOPMENT LLC PHONE :
 PARCEL . . . : 01-0525- - -0062- -17-
 APPL NUMBER: 10-50023546 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/09/2010 07:26 PM VBROWN ----
 158 WINGED FOOT DRIVE, WALNUT GROVE SUB
 DIV #8. 210S, LEFT ON LASATER RD, LEFT
 INTO WALNUT GROVE DRIVE, LEFT ON WINGED
 FOOT DRIVE, LOT ON RIGHT.

STRUCTURE: 000 000 46X55 3BDR 2.5BATH SFD WITH GAR, DECK, CWL
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/08/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001891466
	3/08/10	AP	
B103 01	3/18/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001896602
	3/18/10	AP	
B105 01	3/25/10	DT	R*OPEN FLOOR VRU #: 001899253
	3/25/10	AP	
R425 01	4/20/10	DT	FOUR TRADE ROUGH IN VRU #: 001912328
	4/20/10	DA	1. Window within 24 inches of rear door must be tempered. 2. No gas pressure. 3. Plumbing boots missing. 4. Front door not installed. Okay to side and insulate. T/S: 04/20/2010 12:47 PM DETAYLOR -----
A814 01	4/20/10	FB	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001912310
	4/19/10	AP	T/S: 04/19/2010 08:16 AM VBROWN ----- T/S: 04/19/2010 10:27 AM FBURGESS ----- 158 WINGED FOOT DR BUNNLEVEL, NC 28323 LOT 8
I129 01	4/23/10	DT	R*INSULATION INSPECTION VRU #: 001914852
	4/23/10	AP	
R327 01	4/23/10	DT	THREE TRADE ROUGH IN >2500 VRU #: 001914837
	4/23/10	AP	If tempered window is not changed by inspection it will be done by siding guy and before final
H824 01	5/28/10	OT	ENVR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001935121
	5/28/10	AP	T/S: 06/01/2010 12:09 PM SSTEWARD ----- T/S: 06/01/2010 12:10 PM SSTEWARD -----
R431 01	8/09/10	TI	FOUR TRADE FINAL >2500 VRU #: 001966082
	8/09/10	CA	T/S: 08/09/2010 09:21 AM NTART -----
R431 02	8/10/10	TI	FOUR TRADE FINAL >2500 VRU #: 001967306

8/10/10 APDT

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Kenneth A Moss

Building: _____

Electrical: _____

Address: 158 Winged Foot Dr
Bunnlevel, NC 28323

Insulation: _____

Plumbing: _____

Mechanical: 10-50023546

MFG Home: _____

Date: 8/10/10

Building Official: DEDE