
ADDRESS . . : 20 BLUEBONNET OAK CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER . . . : H & H CONSTRUCTORS INC
PARCEL . . . : 01-0536-05- -0028- -27-
APPL NUMBER: 10-50023619 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/15/2010 10:32 AM JBROCK -----
HWY 27 W TO NURSERY RD TO LEMUEL BLACK
RD TO FOREST OAKS LEFT ON VALLEY OAK DR
INTO S/D LOT 140 ON BASKET OAK DR

SUBDIV: FOREST OAKS PH 3 99LOTS
PHONE : (910) 486-4864
PHONE : (910) 486-4864

STRUCTURE: 000 000 39X56 3BDR SLAB W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/18/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001896281
	3/18/10	AP	
B103 01	3/24/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001898766
	<u>3/24/10</u>	<u>AP DJ</u>	

----- COMMENTS AND NOTES -----

ADDRESS . . : 20 BLUEBONNET OAK CT
 CONTRACTOR : H & H CONSTRUCTORS INC
 OWNER . . . : H & H CONSTRUCTORS INC
 PARCEL . . . : 01-0536-05- -0028- -27-
 APPL NUMBER: 10-50023619 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/15/2010 10:32 AM JBROCK -----
 HWY 27 W TO NURSERY RD TO LEMUEL BLACK
 RD TO FOREST OAKS LEFT ON VALLEY OAK DR
 INTO S/D LOT 140 ON BASKET OAK DR

STRUCTURE: 000 000 39X56 3BDR SLAB W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/18/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001896281
	3/18/10	AP	
B103 01	3/24/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001898766
	3/24/10	AP	
P309 01	3/31/10	TI	R*PLUMB UNDER SLAB VRU #: 001902683

3-31-10 AP JH

----- COMMENTS AND NOTES -----

ADDRESS : 20 BLUEBONNET OAK CT SUBDIV: FOREST OAKS PH 3 99LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 PARCEL : 01-0536-05- -0028- -27-
 APPL NUMBER: 10-50023619 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/15/2010 10:32 AM JBROCK ----
 HWY 27 W TO NURSERY RD TO LEMUEL BLACK
 RD TO FOREST OAKS LEFT ON VALLEY OAK DR
 INTO S/D LOT 140 ON BASKET OAK DR

STRUCTURE: 000 000 39X56 3BDR SLAB W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/18/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001896281
	3/18/10	AP	
B103 01	3/24/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001898766
	3/24/10	AP	
P309 01	3/31/10	JH	R*PLUMB UNDER SLAB VRU #: 001902683
	3/31/10	AP	
B111 01	4/05/10 <u>4-5-10</u>	TI <u>APIBS</u>	R*BLDG SLAB INSP VRU #: 001903350

----- COMMENTS AND NOTES -----

ADDRESS : 20 BLUEBONNET OAK CT SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
PARCEL : 01-0536-05- -0028- -27-
APPL NUMBER: 10-50023619 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/15/2010 10:32 AM JBROCK ----
HWY 27 W TO NURSERY RD TO LEMUEL BLACK
RD TO FOREST OAKS LEFT ON VALLEY OAK DR
INTO S/D LOT 140 ON BASKET OAK DR

STRUCTURE: 000 000 39X56 3BDR SLAB W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/18/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001896281
	3/18/10	AP	
B103 01	3/24/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001898766
	3/24/10	AP	
P309 01	3/31/10	JH	R*PLUMB UNDER SLAB VRU #: 001902683
	3/31/10	AP	
B111 01	4/05/10	BS	R*BLDG SLAB INSP VRU #: 001903350
	4/05/10	AP	T/S: April 05, 2010 12:37 PM BSUTTON -----
A814 01	4/22/10	TI	ADDRESS CONFIRMATION VRU #: 001913821
R425 01	4/26/10	TI	FOUR TRADE ROUGH IN VRU #: 001915008
	<u>4-26-10</u>	<u>DA-MR</u>	

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 04-26-10

PERMIT # 10-50023619

ADDRESS: 20 bluebonnet oak.

VIOLATIONS:

1. No water in riser for test
2. Trusses not strapped
3. Ac line blocking access to attic

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 20 BLUEBONNET OAK CT
 CONTRACTOR : H & H CONSTRUCTORS INC
 OWNER : H & H CONSTRUCTORS INC
 PARCEL : 01-0536-05- -0028- -27-
 APPL NUMBER: 10-50023619 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/15/2010 10:32 AM JBROCK ----
 HWY 27 W TO NURSERY RD TO LEMUEL BLACK
 RD TO FOREST OAKS LEFT ON VALLEY OAK DR
 INTO S/D LOT 140 ON BASKET OAK DR

STRUCTURE: 000 000 39X56 3BDR SLAB W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/18/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001896281
	3/18/10	AP	
B103 01	3/24/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001898766
	3/24/10	AP	
P309 01	3/31/10	JH	R*PLUMB UNDER SLAB VRU #: 001902683
	3/31/10	AP	
B111 01	4/05/10	BS	R*BLDG SLAB INSP VRU #: 001903350
	4/05/10	AP	T/S: April 05, 2010 12:37 PM BSUTTON -----
A814 01	4/22/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001913821
	4/26/10	AP	20 BLUEBONNET OAK CT LOT 140 ----- BUNNLEVEL 28323 T/S: 04/26/2010 10:34 AM TWARD -----
R425 01	4/26/10	MR	FOUR TRADE ROUGH IN VRU #: 001915008
	4/26/10	DA	T/S: 04/26/2010 12:58 PM MREARIC ----- 1. no water in riser 2. trusses not strapped 3. ac line blocking attic access
I129 01	4/28/10	TI	R*INSULATION INSPECTION VRU #: 001916873
	<u>4-28-10</u>	<u>AP-MR</u>	
R425 02	4/28/10	TI	FOUR TRADE ROUGH IN VRU #: 001916865
	<u>4-28-10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : 20 BLUEBONNET OAK CT SUBDIV: FOREST OAKS PH 3 99LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
PARCEL : 01-0536-05- -0028- -27-
APPL NUMBER: 10-50023619 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/15/2010 10:32 AM JBROCK ----
HWY 27 W TO NURSERY RD TO LEMUEL BLACK
RD TO FOREST OAKS LEFT ON VALLEY OAK DR
INTO S/D LOT 140 ON BASKET OAK DR

STRUCTURE: 000 000 39X56 3BDR SLAB W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/18/10	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001896281
	3/18/10	AP	
B103 01	3/24/10	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 001898766
	3/24/10	AP	
P309 01	3/31/10	JH	R*PLUMB UNDER SLAB VRU #: 001902683
	3/31/10	AP	
B111 01	4/05/10	BS	R*BLDG SLAB INSP VRU #: 001903350
	4/05/10	AP	T/S: April 05, 2010 12:37 PM BSUTTON -----
A814 01	4/22/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001913821
	4/26/10	AP	✓ 20 BLUEBONNET OAK CT LOT 140 ----- BUNNLEVEL 28323 T/S: 04/26/2010 10:34 AM TWARD -----
R425 01	4/26/10	MR	FOUR TRADE ROUGH IN VRU #: 001915008
	4/26/10	DA	T/S: 04/26/2010 12:58 PM MREARIC ----- 1. no water in riser 2. trusses not strapped 3. ac line blocking attic access
I129 01	4/28/10	MR	R*INSULATION INSPECTION VRU #: 001916873
	4/28/10	AP	T/S: 04/28/2010 12:19 PM MREARIC -----
R425 02	4/28/10	MR	FOUR TRADE ROUGH IN VRU #: 001916865
	4/28/10	AP	T/S: 04/28/2010 12:19 PM MREARIC -----
H824 01	5/19/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001929983
	5/19/10	AP	T/S: 05/20/2010 10:18 AM SSTEWARD ----- T/S: 05/20/2010 10:18 AM SSTEWARD -----
R429 01	6/24/10	MR	FOUR TRADE FINAL VRU #: 001945526
	6/24/10	CA	T/S: 06/24/2010 12:58 PM MREARIC ----- per customer
R429 02	6/25/10	TI	FOUR TRADE FINAL VRU #: 001946185

6-25-10 AP-IVR

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: H + H Constructors

Building: 10-50023619

Address: _____

Electrical: 11

20 Bluebonnet Oak Ct

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

Date: 6-25-10

Building Official: T. Michael Reavis