

COMMENTS: BM 7/7/2010

Spoke with Matt Low from H&H Const. & discussed 10 ft setback from any waterline. He will have the irrigation system marked & I will call Sara Scott & meet her on site on 7/8/2010 if possible.

BM 7/9/2010 I spoke w/ Sara Scott about the irrigation system running over the septic tank & drain lines. She said that they would have it corrected & call me back. I then left her a message ~~later~~ later that she should have the septic contractor remove the irrigation over the drain lines so they could verify whether the system was damaged or not.

BM 7/14/2010 Made a site visit to lot 140 Forest Oaks. Tried to probe the area where the irrigation line was, it could not locate. It appears that the line had been removed & the required setbacks are now met.