RESIDENTIAL WELL CONSTRUCTION RECORD

North Carolina Department of Environment and Natural Resources- Division of Water Quality

WELL CONTRACTOR CERTIFICATION # 2179

1. WELL CONTRACTOR:

Roger W. Jackson
Well Contractor (individual) Name

Jackson Well Company
Well Contractor Company Name

STREET ADDRESS 5660 McDougald Road

Lillington, North Carolina 27546
City or Town State Zip Code

(910) 893-2372
Area code- Phone number

2. WELL INFORMATION:

SITE WELL ID #(if applicable)

STATE WELL PERMIT#(if applicable)

DWQ or OTHER PERMIT #(if applicable)

WELL USE (Check Applicable Box): Residential Water Supply ☑

DATE DRILLED 9-22-10

TIME COMPLETED 2:00 AM☐ PM☑

WELL LOCATION:

CITY: Duncan F.V. COUNTY Harnett

5953 Coresbury Rd Duncan F.V.
(Street Name, Numbers, Community, Subdivision, Lot No., Parcel, Zip Code) 27526-9170

TOPOGRAPHIC / LAND SETTING:
☑Slope ☐Valley ☐Flat ☐Ridge ☐ Other
(check appropriate box)

LATITUDE 35° 37.292
LONGITUDE 78° 49.690

May be in degrees, minutes, seconds or in a decimal format

Latitude/longitude source: ☑GPS ☐Topographic map

(location of well must be shown on a USGS topo map and attached to this form if not using GPS)

4. WELL OWNER

OWNER'S NAME Charles Galloway

STREET ADDRESS 5953 Coresbury Rd

Duncan F.V. N.C. 27526-9170
City or Town State Zip Code

(910) 890 4594
Area code- Phone number

5. WELL DETAILS:

a. TOTAL DEPTH: 160'

b. DOES WELL REPLACE EXISTING WELL? YES☐ NO☑

c. WATER LEVEL Below Top of Casing: 20 FT.
(Use "+" if Above Top of Casing)

TOP OF CASING IS / FT. Above Land Surface*
*Top of casing terminated at/or below land surface may require a variance in accordance with 15A NCAC 2C .0118.

e. YIELD (gpm): 25 METHOD OF TEST Air

f. DISINFECTION: Type HTH Amount 16oz

g. WATER ZONES (depth):

From 85 To 90 From To
From 122 To 124 From To
From To From To

6. CASING:

	Depth		Diameter	Thickness/ Weight	Material
From 0	To 70	Ft.	6"	SR21	PVC
From	To	Ft.			
From	To	Ft.			

7. GROUT:

	Depth		Material	Method
From 0	To 20	Ft.	Sand Cement	Pouring
From	To	Ft.		
From	To	Ft.		

8. SCREEN:

	Depth		Diameter	Slot Size	Material
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	
From	To	Ft.	in.	in.	

9. SAND/GRAVEL PACK:

	Depth		Size	Material
From	To	Ft.		
From	To	Ft.		
From	To	Ft.		

10. DRILLING LOG

From	To	Formation Description
0	65	Clay
65	160	Granite

11. REMARKS:

I DO HEREBY CERTIFY THAT THIS WELL WAS CONSTRUCTED IN ACCORDANCE WITH 15A NCAC 2C, WELL CONSTRUCTION STANDARDS, AND THAT A COPY OF THIS RECORD HAS BEEN PROVIDED TO THE WELL OWNER.

Roger W. Jackson 9-28-10
SIGNATURE OF CERTIFIED WELL CONTRACTOR DATE

Roger W. Jackson
PRINTED NAME OF PERSON CONSTRUCTING THE WELL

Submit the original to the Division of Water Quality within 30 days. Attn: Information Mgt.,

Form GW-1a