
ADDRESS . . : 224 CASTLEROCK DR SUBDIV: THE SUMMIT SEC3 50 LOTS
 -CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER . . : WEAVER DEVELOPMENT CO INC PHONE : (910) 630-2100
 PARCEL . . : 03-9587-13- -0020- -15-
 APPL NUMBER: 10-50023637 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/20/2010 09:39 AM JBROCK ----
 HWY 27 W TO BUFFALO LAKE RD TO ALPINE
 DR TO TIMBERLAND TO CASTLE ROCK CT LOT
 95

STRUCTURE: 000 000 43X38 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/19/10 <u>2-19-10</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001885250 T/S: 02/18/2010 12:14 PM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS : 224 CASTLEROCK DR SUBDIV: THE SUMMIT SEC3 50 LOTS
CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
OWNER : WEAVER DEVELOPMENT CO INC PHONE : (910) 630-2100
PARCEL : 03-9587-13- -0020- -15-
APPL NUMBER: 10-50023637 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/20/2010 09:39 AM JBROCK ----
HWY 27 W TO BUFFALO LAKE RD TO ALPINE
DR TO TIMBERLAND TO CASTLE ROCK CT LOT
95

STRUCTURE: 000 000 43X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/19/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001885250
	2/19/10	AP	T/S: 02/18/2010 12:14 PM VBROWN ----- T/S: 02/19/2010 12:31 PM MREARIC -----
B103 01	3/08/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001890760
	<u>3-8-10</u>	<u>AP-MB</u>	VOICE MESSAGE LEFT

----- COMMENTS AND NOTES -----

ADDRESS : 224 CASTLEROCK DR
 CONTRACTOR : WEAVER DEVELOPMENT CO INC
 OWNER : WEAVER DEVELOPMENT CO INC
 PARCEL : 03-9587-13- -0020- -15-
 APPL NUMBER: 10-50023637 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/20/2010 09:39 AM JBROCK ----
 HWY 27 W TO BUFFALO LAKE RD TO ALPINE
 DR TO TIMBERLAND TO CASTLE ROCK CT LOT
 95

SUBDIV: THE SUMMIT SEC3 50 LOTS
 PHONE : (910) 433-0888
 PHONE : (910) 630-2100

STRUCTURE: 000 000 43X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/19/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001885250
	2/19/10	AP	T/S: 02/18/2010 12:14 PM VBROWN ----- T/S: 02/19/2010 12:31 PM MREARIC -----
B103 01	3/08/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001890760
	3/08/10	AP	VOICE MESSAGE LEFT T/S: 03/08/2010 11:55 AM MREARIC -----
A814 01	3/10/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001890779
	3/12/10	AP	224 castlerock dr lot 95 ----- sanford 27332 T/S: 03/12/2010 11:07 AM TWARD -----
B105 01	3/16/10	TI	R*OPEN FLOOR VRU #: 001894855
	<u>3-16-10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : 224 CASTLEROCK DR SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER : WEAVER DEVELOPMENT CO INC PHONE : (910) 630-2100
 PARCEL : 03-9587-13- -0020- -15-
 APPL NUMBER: 10-50023637 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/20/2010 09:39 AM JBROCK ----
 HWY 27 W TO BUFFALO LAKE RD TO ALPINE
 DR TO TIMBERLAND TO CASTLE ROCK CT LOT
 95

STRUCTURE: 000 000 43X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/19/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001885250
	2/19/10	AP	T/S: 02/18/2010 12:14 PM VBROWN ----- T/S: 02/19/2010 12:31 PM MREARIC -----
B103 01	3/08/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001890760
	3/08/10	AP	VOICE MESSAGE LEFT T/S: 03/08/2010 11:55 AM MREARIC -----
A814 01	3/10/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001890779
	3/12/10	AP	224 castlerock dr lot 95 ----- sanford 27332 T/S: 03/12/2010 11:07 AM TWARD -----
B105 01	3/16/10	MR	R*OPEN FLOOR VRU #: 001894855
	3/16/10	AP	T/S: 03/16/2010 12:45 PM MREARIC -----
R427 01	3/31/10	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001901188
	3/30/10	CA	VOICE MESSAGE LEFT
R427 02	4/01/10	TI	FOUR TRADE ROUGH IN >2500 VRU #: 001902481

4-1-10 DA-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 04-01-10

PERMIT # 10-50023637

ADDRESS: 224 castlerock

VIOLATIONS:

1. Load point by garage side door is not supported per plans (5sc)
2. load point under lvl by stairs is not supported by stud column per plans
3. Windows are not installed
4. Flash under doors(tyvek is not flashing)

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 224 CASTLEROCK DR SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER : WEAVER DEVELOPMENT CO INC PHONE : (910) 630-2100
 PARCEL : 03-9587-13- -0020- -15-
 APPL NUMBER: 10-50023637 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 01/20/2010 09:39 AM JBROCK ----
 HWY 27 W TO BUFFALO LAKE RD TO ALPINE
 DR TO TIMBERLAND TO CASTLE ROCK CT LOT
 95

STRUCTURE: 000 000 43X38 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/19/10 2/19/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001885250 T/S: 02/18/2010 12:14 PM VBROWN ----- T/S: 02/19/2010 12:31 PM MREARIC -----
B103 01	3/08/10 3/08/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001890760 VOICE MESSAGE LEFT T/S: 03/08/2010 11:55 AM MREARIC -----
A814 01	3/10/10 3/12/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001890779 224 castlerock dr lot 95 ----- sanford 27332 T/S: 03/12/2010 11:07 AM TWARD -----
B105 01	3/16/10 3/16/10	MR AP	R*OPEN FLOOR VRU #: 001894855 T/S: 03/16/2010 12:45 PM MREARIC -----
R427 01	3/31/10 3/30/10	TI CA	FOUR TRADE ROUGH IN >2500 VRU #: 001901188 VOICE MESSAGE LEFT
R427 02	4/01/10 4/01/10	MR DA	FOUR TRADE ROUGH IN >2500 VRU #: 001902481 T/S: 04/01/2010 01:58 PM MREARIC ----- 1. load point by garage side door is not supported 2. load point under lvl by stairs not supported 3. windows not installed 4. flash under doors
I129 01	4/09/10 <u>4-9-10</u>	TI <u>AP-MR</u>	R*INSULATION INSPECTION VRU #: 001906995
R427 03	4/09/10 <u>4-9-10</u>	TI <u>AP-MR</u>	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001907542 T/S: 04/08/2010 02:24 PM NTART -----

COMMENTS AND NOTES

ADDRESS : 224 CASTLEROCK DR SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER : WEAVER DEVELOPMENT CO INC PHONE : (910) 630-2100
 PARCEL : 03-9587-13- -0020- -15-
 APPL NUMBER: 10-50023637 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/20/2010 09:39 AM JBROCK ----
 HWY 27 W TO BUFFALO LAKE RD TO ALPINE
 DR TO TIMBERLAND TO CASTLE ROCK CT LOT
 95

STRUCTURE: 000 000 43X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/19/10 2/19/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001885250 T/S: 02/18/2010 12:14 PM VBROWN ----- T/S: 02/19/2010 12:31 PM MREARIC -----
B103 01	3/08/10 3/08/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001890760 VOICE MESSAGE LEFT T/S: 03/08/2010 11:55 AM MREARIC -----
A814 01	3/10/10 3/12/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001890779 224 castlerock dr lot 95 ----- sanford 27332 T/S: 03/12/2010 11:07 AM TWARD -----
B105 01	3/16/10 3/16/10	MR AP	R*OPEN FLOOR VRU #: 001894855 T/S: 03/16/2010 12:45 PM MREARIC -----
R427 01	3/31/10 3/30/10	TI CA	FOUR TRADE ROUGH IN >2500 VRU #: 001901188 VOICE MESSAGE LEFT
R427 02	4/01/10 4/01/10	MR DA	FOUR TRADE ROUGH IN >2500 VRU #: 001902481 T/S: 04/01/2010 01:58 PM MREARIC ----- 1. load point by garage side door is not supported 2. load point under lvl by stairs not supported 3. windows not installed 4. flash under doors
I129 01	4/09/10 4/09/10	MR AP	R*INSULATION INSPECTION VRU #: 001906995 T/S: 04/09/2010 01:27 PM MREARIC -----
R427 03	4/09/10 4/09/10	MR AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001907542 T/S: 04/08/2010 02:24 PM NTART ----- T/S: 04/09/2010 01:27 PM MREARIC -----
H824 01	4/20/10 4/20/10	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001914399 T/S: 04/22/2010 09:59 AM SSTEWARD ----- T/S: 04/22/2010 10:00 AM SSTEWARD -----
R431 01	6/02/10	TI	FOUR TRADE FINAL >2500 VRU #: 001935133

G-2-10 AP-MR

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: _____

Building: 10-50023637

224 Castlerock

Electrical: 11

Address: _____

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____

Date: 6-2-10

Building Official: T. Michael Reare