

Bryan McSwain

From: Mike Eaker <mike@southeasternsoil.com>
Sent: Friday, March 25, 2011 2:55 PM
To: Bryan McSwain
Subject: Re: Tingen Pt. lot 30 application #10-5-23705

Thanks!

I'll be in contact!

From: Bryan McSwain <bmcswain@harnett.org>
To: "edward@wynnconstruct.com" <edward@wynnconstruct.com>
Cc: "Mike Eaker (mike@southeasternsoil.com)" <mike@southeasternsoil.com>; Oliver Tolksdorf <otolksdorf@harnett.org>; Susan G. Stewart <sgstewart@harnett.org>; Donna Johnson <djohnson@harnett.org>
Sent: Fri, March 25, 2011 10:38:35 AM
Subject: Tingen Pt. lot 30 application #10-5-23705

Mr. Averett,

On March 24, 2011 a meeting between Southeastern Soil & Associates, Inc. and The Harnett County Environmental Health Section took place on lot 30 in Tingen Point subdivision. It was determined at the meeting that the septic system could not be installed as permitted due to the removal of soil in the initial drain field area. The Authorization to Construct the septic system (permit # 25829) that was issued based on a proposal attached to the application must be revoked. I suggest that you contact Southeastern Soil & Associates, Inc. to re-evaluate the lot. Once a new proposal is received and verified in the field a new Authorization to Construct may be issued. I suggest for future reference, that the areas for the initial and repair drain fields, be paid close attention to when any lot is cleared. If you have any questions or concerns please feel free to contact me.

Bryan McSwain, R.E.H.S.
On-site Waste Water Program Specialist
Harnett County Department of Public Health
307 W. Cornelius Harnett Blvd.
Lillington, N.C. 27546
910-893-7547

COMMENTS:

3/12/2011 Am Thornton's Plumbing called for a septic installation on 3/16/11. Because of the rain on 3/15/11 I did them to wait. I made a visit on 3/16 to see how wet the soil was. The lot has been cleared & enough soil removed that the system cannot be installed as permitted. I spoke w/ Mr. Averett of Wynn Construction about the lot. Asked for him to contact Mike Eaker (soil consultant) & have Mr. Eaker contact me.