

HTE# 10-5-23707R

# Harnett County Department of Public Health

25836

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Wade Hare, South Sea PROPERTY LOCATION: Hwy 27 west  
 NEW  REPAIR  EXPANSION  SUBDIVISION: Tingen Pointe LOT # 32  
 Type of Structure: SFD 60x50 Site Improvements required prior to Construction Authorization Issuance:  
 Proposed Wastewater System Type: 25% Reduction System  
 Projected Daily Flow: 360 GPD  
 Number of bedrooms: 3 Number of Occupants: 6 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well \_\_\_\_\_ feet Permit valid for:  Five years  
 Permit conditions: \_\_\_\_\_  No expiration

Authorized State Agent: Bryan McSwain, RCHS Date: 3/3/2010 9/29/2015 SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Wade Hare, South Sea PROPERTY LOCATION: Hwy 27 west  
 SUBDIVISION: Tingen Pointe LOT # 32  
 Facility Type: SFD  New  Expansion  Repair  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* 25% Reduction System (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable  25% Reduction System (Repair)  
**Installation Requirements/Conditions**  
 Septic Tank Size 1000 gallons Number of trenches 2  
 Pump Tank Size \_\_\_\_\_ gallons Exact length of each trench 60 feet Trench Spacing: 9 Feet on Center  
 Trenches shall be installed on contour at a Soil Cover: 8 inches  
 Maximum Trench Depth of: 20 inches (Maximum soil cover shall not exceed  
 (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)  
 in all directions)  
 Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM \_\_\_\_\_ inches below pipe  
 Aggregate Depth: \_\_\_\_\_ inches above pipe  
 \_\_\_\_\_ inches total  
 Conditions: Permit based on consultants proposal. See attachments for sketch. No utilities allowed in system & or repair areas. Water line must be 10ft. from any part of septic system


\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: Bryan McSwain, RCHS Date: 3/3/2010 9/29/2015  
 Construction Authorization Expiration Date: 3/3/2010 9/28/2020

UNKNOWN EST.  
PG. C. SLIDE 1  
HARNETT COUNTY  
OF DEEDS  
ZONE: RA-2



SOUTHEASTERN SOIL & ENVIRONMENTAL ASSOC, INC.

PROPOSED SUBSURFACE WASTE DISPOSAL SYSTEM DETAIL SHEET

SUBDIVISION T. L. Green Pt 1

LOT 32

INITIAL SYSTEM Approved 25% reduction

REPAIR Approved 25% reduction

DISTRIBUTION D-box

DISTRIBUTION P-box

BENCHMARK 100.0

LOCATION Top of elev. box pt 31/32

NO. BEDROOMS 3

proposed URE = 0.29 gal/hr

<u>LINE</u>	<u>FLAG COLOR</u>	<u>ELEVATION</u>	<u>ACTUAL LENGTH</u>
-------------	-------------------	------------------	----------------------

In. and

1	O	94.25	60'
2	W	93.50	60'
			120'
3	O	92.92	60'
4	W	92.42	60'
			120'

BY M. EAKER

DATE 08/2009

- (\*) Remove vegetation only when clearing
- (\*) Do not remove soil

Typ Profile  
 0-47 s/w (VF, wet)  
 47-48 s/w (F, soil)  
 CA 2244  
 INSTAL @ 18"