
ADDRESS : 289 STRIKE EAGLE DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOME OF FAY PHONE : (910) 426-2898
 PARCEL : 03-9597- - -0039- -13-
 APPL NUMBER: 10-50023763 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/10/2010 11:27 AM JBROCK ----
 27 TOWARDS 87 TURN LEFT ON TINGEN RD
 TURN LEFT INTO S/D ON STRIKE EAGLE DR
 LOT IS DOWN STRIKE EAGLE DR LOT 15

STRUCTURE: 000 000 64X43 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
COMPLETED	RESULT	RESULTS/COMMENTS	
B101 01	3/16/10	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001894971
	<u>3-16-10</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 289 STRIKE EAGLE DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOME OF FAY PHONE : (910) 426-2898
 PARCEL : 03-9597- - -0039- -13-
 APPL NUMBER: 10-50023763 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/10/2010 11:27 AM JBROCK ----
 27 TOWARDS 87 TURN LEFT ON TINGEN RD
 TURN LEFT INTO S/D ON STRIKE EAGLE DR
 LOT IS DOWN STRIKE EAGLE DR LOT 15

STRUCTURE: 000 000 64X43 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/16/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001894971
	3/16/10	AP	T/S: 03/16/2010 12:45 PM MREARIC -----
A814 01	3/22/10	TI	ADDRESS CONFIRMATION VRU #: 001897883
B103 01	3/22/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001897867
	<u>3-22-10</u>	<u>AP-UR</u>	

----- COMMENTS AND NOTES -----

*Need
Compaction*

ADDRESS : 289 STRIKE EAGLE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOME OF FAY PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -13-
APPL NUMBER: 10-50023763 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/10/2010 11:27 AM JBROCK ----
27 TOWARDS 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
LOT IS DOWN STRIKE EAGLE DR LOT 15

STRUCTURE: 000 000 64X43 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/16/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001894971
	3/16/10	AP	T/S: 03/16/2010 12:45 PM MREARIC -----
B103 01	3/22/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001897867
	3/22/10	AP	T/S: 03/22/2010 12:46 PM MREARIC -----
A814 01	3/22/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001897883
	3/30/10	AP	289 strike eagle dr lot 15 ----- broadway 27505 T/S: 03/30/2010 03:49 PM TWARD -----
P309 01	4/09/10	TI	R*PLUMB UNDER SLAB VRU #: 001907096

4-9-10 AP-MR

----- COMMENTS AND NOTES -----

Bill Clark Homes of Fayetteville
200 E Arlington Blvd
200 E Arlington Blvd
Greenville, NC 27858

04/02/2010

Attention : JJ Brenning

RE: Daily Field Report for 04/01/2010
Patton's Point-Lot 15, Bill Clark Homes
KAM Project No : 10-0079

Ladies and Gentlemen:

On this date, representative(s) of KAM Engineering Services, P.C. were present to perform construction material testing services at this project site. Our testing and observations for this date include the following:

ST-1 : In place field density testing was performed for Building Pads. The field density testing was performed in general accordance with ASTM D1556, using the results of field one-point Proctors and laboratory Proctors for compaction comparison. One(1) in-place field density test was performed on this date. The testing results indicate that in-place compaction and moisture content at the location and depth tested meet or exceed the specified requirements outlined in the project plans and specifications. For additional details of our testing, please refer to the attached Field Density Test Report.

Closing

The testing and observations identified above have been reviewed by our project manager. If you have questions regarding this information, please do not hesitate to contact us.

Respectfully Submitted,
KAM Engineering Services, P.C.

Enclosures : ST-1

Field Density Test Report

Project: Patton's Point-Lot 15, Bill Clark Homes
10-0079
Technician : J. Jernigan

Client: Bill Clark Homes of Fayetteville
200 E Arlington Blvd
200 E Arlington Blvd
Greenville, NC 27858

Distribution List: jbrening@billclarkhomes.com

Test No.	Re-Test Stamp	Dry Density (pcf)	Moisture Content % ASTM D 4959	Maximum Dry Density (pcf)	Optimum Moisture Content %	Compaction %	Required Compaction %	USCS	Proctor Type	ASTM Method	Location of Test	Depth
1		111.6	12.4	113.2	14	99%	95%	SC	ASTM D-698	ASTMD1556	Building Pads : Lot 15 NW Corner 20' E : 7' S	FSG

Reviewed By

ADDRESS : 289 STRIKE EAGLE DR
CONTRACTOR : BILL CLARK HOMES LLC
OWNER : BILL CLARK HOME OF FAY
PARCEL : 03-9597- - -0039- -13-
APPL NUMBER: 10-50023763 CP NEW RESIDENTIAL (SFD)

SUBDIV: PATTONS POINT
PHONE : (252) 355-5805
PHONE : (910) 426-2898

DIRECTIONS : T/S: 02/10/2010 11:27 AM JBROCK ----
27 TOWARDS 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
LOT IS DOWN STRIKE EAGLE DR LOT 15

STRUCTURE: 000 000 64X43 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

REQUESTED	INSP	DESCRIPTION
TYP/SQ	COMPLETED	RESULT RESULTS/COMMENTS
B101 01	3/16/10	MR R*BLDG FOOTING / TEMP SVC POLE VRU #: 001894971
	3/16/10	AP T/S: 03/16/2010 12:45 PM MREARIC
B103 01	3/22/10	MR R*BLDG FOUND & TEMP SVC POLE VRU #: 001897867
	3/22/10	AP T/S: 03/22/2010 12:46 PM MREARIC
A814 01	3/22/10	TW ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001897883
	3/30/10	AP 289 strike eagle dr lot 15
		broadway 27505
		T/S: 03/30/2010 03:49 PM TWARD
P309 01	4/09/10	MR R*PLUMB UNDER SLAB VRU #: 001907096
	4/09/10	AP T/S: 04/09/2010 01:27 PM MREARIC
B111 01	4/12/10	TR R*BLDG SLAB INSP TIME: 17:00 VRU #: 001908318
	4/12/10	DA DT T/S: 04/12/2010 08:00 AM NTART

COMMENTS AND NOTES

ADDRESS : 289 STRIKE EAGLE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOME OF FAY PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -13-
APPL NUMBER: 10-50023763 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/10/2010 11:27 AM JBROCK ----
27 TOWARDS 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
LOT IS DOWN STRIKE EAGLE DR LOT 15

STRUCTURE: 000 000 64X43 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/16/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001894971
	3/16/10	AP	T/S: 03/16/2010 12:45 PM MREARIC -----
B103 01	3/22/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001897867
	3/22/10	AP	T/S: 03/22/2010 12:46 PM MREARIC -----
A814 01	3/22/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001897883
	3/30/10	AP	289 strike eagle dr lot 15 ----- broadway 27505 T/S: 03/30/2010 03:49 PM TWARD -----
P309 01	4/09/10	MR	R*PLUMB UNDER SLAB VRU #: 001907096
	4/09/10	AP	T/S: 04/09/2010 01:27 PM MREARIC -----
B111 01	4/12/10	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001908318
	4/12/10	AP	T/S: 04/12/2010 08:00 AM NTART ----- Need compaction letter where fill exceeds 24 inches. See residential code section R506.2.1 T/S: 04/12/2010 11:23 AM DETAYLOR -----
R425 01	5/13/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001925544
	<u>5-13-10</u>	<u>AP-MR</u>	T/S: 05/12/2010 01:22 PM JBROCK -----

COMMENTS AND NOTES

ADDRESS : 289 STRIKE EAGLE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOME OF FAY PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -13-
APPL NUMBER: 10-50023763 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/10/2010 11:27 AM JBROCK ----
27 TOWARDS 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
LOT IS DOWN STRIKE EAGLE DR LOT 15

STRUCTURE: 000 000 64X43 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/16/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001894971
	3/16/10	AP	T/S: 03/16/2010 12:45 PM MREARIC -----
B103 01	3/22/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001897867
	3/22/10	AP	T/S: 03/22/2010 12:46 PM MREARIC -----
A814 01	3/22/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001897883
	3/30/10	AP	289 strike eagle dr lot 15 ----- broadway 27505 T/S: 03/30/2010 03:49 PM TWARD -----
P309 01	4/09/10	MR	R*PLUMB UNDER SLAB VRU #: 001907096
	4/09/10	AP	T/S: 04/09/2010 01:27 PM MREARIC -----
B111 01	4/12/10	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001908318
	4/12/10	AP	T/S: 04/12/2010 08:00 AM NTART ----- Need compaction letter where fill exceeds 24 inches. See residential code section R506.2.1 T/S: 04/12/2010 11:23 AM DETAYLOR -----
R425 01	5/13/10	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001925544
	5/13/10	AP	T/S: 05/12/2010 01:22 PM JBROCK ----- T/S: 05/13/2010 12:03 PM MREARIC -----
I129 01	5/17/10	TI	R*INSULATION INSPECTION VRU #: 001926875
	<u>5-17-10</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 289 STRIKE EAGLE DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOME OF FAY PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -13-
APPL NUMBER: 10-50023763 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/10/2010 11:27 AM JBROCK ----
27 TOWARDS 87 TURN LEFT ON TINGEN RD
TURN LEFT INTO S/D ON STRIKE EAGLE DR
LOT IS DOWN STRIKE EAGLE DR LOT 15

STRUCTURE: 000 000 64X43 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/16/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001894971
	3/16/10	AP	T/S: 03/16/2010 12:45 PM MREARIC -----
B103 01	3/22/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001897867
	3/22/10	AP	T/S: 03/22/2010 12:46 PM MREARIC -----
A814 01	3/22/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001897883
	3/30/10	AP	✓ 289 strike eagle dr lot 15 ----- broadway 27505 T/S: 03/30/2010 03:49 PM TWARD -----
P309 01	4/09/10	MR	R*PLUMB UNDER SLAB VRU #: 001907096
	4/09/10	AP	T/S: 04/09/2010 01:27 PM MREARIC -----
B111 01	4/12/10	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001908318
	4/12/10	AP	T/S: 04/12/2010 08:00 AM NTART ----- Need compaction letter where fill exceeds 24 inches. See residential code section R506.2.1 T/S: 04/12/2010 11:23 AM DETAYLOR -----
R425 01	5/13/10	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001925544
	5/13/10	AP	T/S: 05/12/2010 01:22 PM JBROCK ----- T/S: 05/13/2010 12:03 PM MREARIC -----
I129 01	5/17/10	MR	R*INSULATION INSPECTION VRU #: 001926875
	5/17/10	AP	T/S: 05/17/2010 12:40 PM MREARIC -----
R429 01	7/21/10	TI	FOUR TRADE FINAL VRU #: 001957182

7-21-10 ~~DR~~
CA-MR

COMMENTS AND NOTES

Brace Porch
Kick Plates on garage stairs

HTE# 10-S-23763

Harnett County Department of Public Health

21462

PERMIT # 25905

Operation Permit

New Installation Septic Tank Repair Nitrification Line Expansion

PROPERTY LOCATION: Tingen Rd

Name: (owner) Bill Clark Homes Inc SUBDIVISION PATTONS POINT LOT # 15

System Installer: LARRY SHARP Registration # _____

Basement with plumbing: Garage Number of Bedrooms 3


Type of Water Supply: Community Public Well Distance from well 100 feet

System Type: III Types V and VI Systems expire in 5 years.

(In accordance with Table V a)

Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: _____
Subsurface system operator required? Yes No
If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: _____
- V. Other: _____

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system: Conventional Other TIRE CHIPS Septic Tank: 1000 gallons Pump Tank: _____ gallons
 Subsurface No. of exact length width of depth of
 Drainage Field ditches _____ of each ditch 200 feet ditches 3 feet ditches 24 inches
 French Drain Required: _____ Linear feet

Authorized State Agent

RENS

Date 5/25/10

ADDRESS : 289 STRIKE EAGLE DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOME OF FAY PHONE : (910) 426-2898
 PARCEL : 03-9597- - -0039- -13-
 APPL NUMBER: 10-50023763 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/10/2010 11:27 AM JBROCK ----
 27 TOWARDS 87 TURN LEFT ON TINGEN RD
 TURN LEFT INTO S/D ON STRIKE EAGLE DR
 LOT IS DOWN STRIKE EAGLE DR LOT 15

STRUCTURE: 000 000 64X43 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/16/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001894971
	3/16/10	AP	T/S: 03/16/2010 12:45 PM MREARIC -----
B103 01	3/22/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001897867
	3/22/10	AP	T/S: 03/22/2010 12:46 PM MREARIC -----
A814 01	3/22/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001897883
	3/30/10	AP	✓ 289 strike eagle dr lot 15 ----- broadway 27505 T/S: 03/30/2010 03:49 PM TWARD -----
P309 01	4/09/10	MR	R*PLUMB UNDER SLAB VRU #: 001907096
	4/09/10	AP	T/S: 04/09/2010 01:27 PM MREARIC -----
B111 01	4/12/10	DT	R*BLDG SLAB INSP TIME: 17:00 VRU #: 001908318
	4/12/10	AP	T/S: 04/12/2010 08:00 AM NTART ----- Need compaction letter where fill exceeds 24 inches. See residential code section R506.2.1 T/S: 04/12/2010 11:23 AM DETAYLOR -----
R425 01	5/13/10	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001925544
	5/13/10	AP	T/S: 05/12/2010 01:22 PM JBROCK ----- T/S: 05/13/2010 12:03 PM MREARIC -----
I129 01	5/17/10	MR	R*INSULATION INSPECTION VRU #: 001926875
	5/17/10	AP	T/S: 05/17/2010 12:40 PM MREARIC -----
H824 01	5/26/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001957398
	5/26/10	AP	T/S: 07/20/2010 03:18 PM SSTEWARD ----- T/S: 07/20/2010 03:18 PM SSTEWARD -----
R429 01	7/21/10	MR	FOUR TRADE FINAL VRU #: 001957182
	7/21/10	CA	T/S: 07/21/2010 12:25 PM JBROCK ----- ca for mike
R429 02	7/22/10	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 001957695
	7/22/10	AP	T/S: 07/21/2010 12:26 PM JBROCK ----- please do inspection after lunch

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Bill Clark Homes

Building: _____

Electrical: _____

Address: 289 Strike Eagle Dr.

Insulation: _____

Broadway, NC 27505

Plumbing: _____

Mechanical: 10

MFG Home: _____

Date: 7/22/10

Building Official: [Signature]