

HTE# 10-5-23765

# Hartnett County Department of Public Health

25909

## Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: WYNN CONSTRUCTION PROPERTY LOCATION: ADCOCK RD  
 NEW  REPAIR  EXPANSION  SUBDIVISION: PIONEER FARMS LOT # 11  
 Type of Structure: SFD (50'x60') Site Improvements required prior to Construction Authorization Issuance:  
 Proposed Wastewater System Type: PUMP TO 2' CHAMBER  
 Projected Daily Flow: 360 GPD  
 Number of bedrooms: 3 Number of Occupants: 6 max  
 Basement  Yes  No  
 Pump Required:  Yes  No  May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community  Public  Well Distance from well 100 feet Permit valid for:  Five years  
 Permit conditions:  No expiration

Authorized State Agent: [Signature] RENS Date: 3/3/10 SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: WYNN CONSTRUCTION PROPERTY LOCATION: ADCOCK RD  
 Facility Type: SFD (50'x60') INCLUDES PATIO  New  Expansion  Repair  
 Basement?  Yes  No Basement Fixtures?  Yes  No  
 Type of Wastewater System\*\* PUMP TO 2' CHAMBER (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable )  
LPP (Repair)

Installation Requirements/Conditions  
 Septic Tank Size 1000 gallons Number of trenches 4  
 Pump Tank Size 1000 gallons Exact length of each trench 85 feet Trench Spacing: 6 Feet on Center  
 Trenches shall be installed on contour at a Soil Cover: 6 inches  
 Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed  
 (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)  
 in all directions)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM \_\_\_\_\_ inches below pipe  
 Aggregate Depth: \_\_\_\_\_ inches above pipe

Conditions: WATER LINE MUST BE 10' FROM SEPTIC SYSTEM. NO UTILITIES  
MAY ENCRUSHY ON INITIAL OR REPAIR AREAS, DUE TO LOT 12 SEPTIC EASEMENT AND AVAILABLE SPACE  
NO POOL OR OUTBUILDINGS WILL BE PERMITTED ON THIS LOT.

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] RENS Date: 3/3/10  
 Construction Authorization Expiration Date: 3/3/15

HTE# 10-5-23765

Permit # 25909

# Harnett County Department of Public Health Site Sketch

ISSUED TO: WYNN CONSTRUCTION PROPERTY LOCATOR: ADCOCK RD  
SUBDIVISION PIONEER FARMS LOT # 11

Authorized State Agent: ~~REMS (OLIVER TOLKSOO)~~ Date: 3/3/10

DRAWING  
NTS

