

**SOIL/SITE EVALUATION**  
 for ON-SITE WASTEWATER SYSTEM

Owner:                      Applicant:

Address:

Proposed Facility: 3 Bedroom      Date Evaluated: 2/25/10  
 Design Flow (.1949): 360 gpd

Location of Site:

Property Recorded:

Property Size:

Water Supply:

Public                       Individual                       Well

Spring                       Other

Evaluation Method:

Auger Boring                       Pit

Cut  
 Mixed

Type of Wastewater:

Sewage                       Industrial Process

SEPTIC EMPLMENT  
 ON LOT 11

PROFILE #	.1940 Landscape Position/Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Prof. Class. & L.
			.1941 Structure/Texture	.1941 Consistence/Mineralogy	.1943 Soil Wetness/Color	.1943 Soil Depth (IN.)	.1956 Sapre Class	.1944 Rooting Horiz.	
1	L5 2-5%	0-14	G S	VF2 N3/NE					
		14-42	SBK SCL*	FR S/SP					
		42"	Pm	RECOX @ 40"					PS-3
2	R	0-10"	G S	VF2 N3/NE					
		10-34"	SBK SCL*	FR S/SP	10YR 7/1 @ 33"				NS-35

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OT Others Present: /
Available Space (.1943)	N/A	✓	
System Type(s)	PUMPED 26%	PUMPED 25%	
Site LTAR	.35	.35	