

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: 3-3-4-10
 Proposed Facility: SFD Design Flow (.1949): 360 Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope%	Horizon Depth (IN.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Saprol Class	.1944 Restr. Horiz	
1	L 6	6" 0-8 SL	FR GR NSNP						.3 0.25
		8-48 SL-CLAY MIX WITH SAPROL	FR L SBL S.P.		30" ? 7.5% 6L	30" max	Grp III?		
2	L 7%	0-10 SL	FR GR NSNP						.3
		10-48 SL-CLAY	FR L SBL S.P.		42" 7.5% 7.1				
3	L 7%	0-10 SL	FR GR NSNP						.3
		10-48 SL-CLAY	FR L SBL S.P.		40" 10% 7.1				

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	25%	25%
Site LTAR	.3	.3.25

Other Factors (.1946): _____
 Site Classification (.1948): PS
 Evaluated By: [Signature]
 Others Present: _____