

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:

Address:

Date Evaluated: 3/2/10

Proposed Facility: 3 RESIDUAL  
 150 CM E

Design Flow (.1949): 360 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public       Individual       Well       Spring       Other

Evaluation Method:

Auger Boring       Pit       Cut

Type of Wastewater:

Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7%	0-24"	GS	VER NS/NP					
		24-38"	SBK SCL	FR SS/SP					PS.4
		38"	PM						
2		0-18"	GS	VER NS/NP					S.8
		18-34"	SBK SCL	FR SS/SP					PS.4
3		0-24"	GS	VER NS/NP					
		24-38"	SBK SCL	FR SS/SP					PS.4
4		0-24"	GS	VER NS/NP					
		24-38"	SBK SCL	FR SS/SP					PS.4
5		0-38"	GS	VER NS/NP					
		38"	SBK SCL	FR SS/SP					PS.4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OS Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	RCMP 4005% = REPAIR		
Site LTAR	.4	.4	