

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Date Evaluated: 3/23/88

Proposed Facility: 4 cess. system

Design Flow (.1949): 480 gpd

Property Size:

Location of Site:

Property Recorded:

Water Supply:

Public Individual Well Spring Other

Evaluation Method:

Auger Boring Pit Cut

Type of Wastewater:

Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (In.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS S-2.0%	0-42	GS	VFN NS/NP					
		42-48	SBK SCL	FR SS/SP					PS.4
2		0-48	GS	VFN NS/NP					PS.8
3		0-24	GS	VFN NS/NP					PS.4
		24-48	SBK SCL	FR SS/SP					
4		0-40	GS	VFN NS/NP	WET @ 40"				PS.8

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	PUMP 2S	= 2GP 2S	
Site LTAR	4	4	