

PREPARED 8/16/10, 14:03:22
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 13
DATE 8/17/10

ADDRESS . . : 81 WHITE TAIL PATH
 CONTRACTOR : GREEN RESIDENTIAL LLC
 OWNER . . . : CARROLL DAVID B & WIFE
 PARCEL . . . : 07-0588- - -0093- -27-
 APPL NUMBER: 10-50023926 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/05/2010 12:06 PM JBROCK ----
 HWY 421 TOWARDS DUNN TURN RIGHT ON OLD
 STAGE RD TRUN RIGHT ON THORTONS CREEK
 RD WHITETAIL PATH ON LEFT
 LAND NOTES : LXMN 1/07/05 SPLIT FROM THE 05

STRUCTURE: 000 000 60X61 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/10 <u>8-17-10</u>	TI <u>APBS</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001969831

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

ADDRESS . . : 81 WHITE TAIL PATH
 CONTRACTOR : GREEN RESIDENTIAL LLC
 OWNER . . . : CARROLL DAVID B & WIFE
 PARCEL . . . : 07-0588- - -0093- -27-
 APPL NUMBER: 10-50023926 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/05/2010 12:06 PM JBROCK ----
 HWY 421 TOWARDS DUNN TURN RIGHT ON OLD
 STAGE RD TRUN RIGHT ON THORTONS CREEK
 RD WHITETAIL PATH ON LEFT
 PRE # 52742770
 LAND NOTES : LXMN 1/07/05 SPLIT FROM THE 05

SUBDIV: DEER PATH FARMS
 PHONE : (919) 417-1747
 PHONE : (910) 890-1842

STRUCTURE: 000 000 60X61 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPNP 00 CP MISC NOTIFICATION PERMIT

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
H800 01	3/19/10	JM	ENVIR. HLTH. CONFIRMATION VRU #: 001891457
	3/16/10	DA	T/S: 03/17/2010 11:29 AM SSTEWARD -----
H800 02	4/07/10	JM	ENVIR. HLTH. CONFIRMATION VRU #: 001898726
	3/23/10	AP	T/S: 03/25/2010 10:38 AM SSTEWARD -----
H800 03	6/30/10	JM	ENVIR. HLTH. CONFIRMATION VRU #: 001941858
	6/22/10	AP	T/S: 06/22/2010 10:11 AM SZIMMER -----

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001969831
	8/17/10	AP	T/S: August 17, 2010 11:21 AM BSUTTON -----
A814 01	8/23/10	TI	ADDRESS CONFIRMATION VRU #: 001972959
B103 01	<u>8/23/10</u> <u>8-23-10</u>	<u>TI</u> <u>ARB</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001972942

COMMENTS AND NOTES

 ADDRESS . . : 81 WHITE TAIL PATH SUBDIV: DEER PATH FARMS
 CONTRACTOR : GREEN RESIDENTIAL LLC PHONE : (919) 417-1747
 OWNER . . : CARROLL DAVID B & WIFE PHONE : (910) 890-1842
 PARCEL . . : 07-0588- - -0093- -27-
 APPL NUMBER: 10-50023926 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/05/2010 12:06 PM JBROCK -----
 HWY 421 TOWARDS DUNN TURN RIGHT ON OLD
 STAGE RD TRUN RIGHT ON THORTONS CREEK
 RD WHITETAIL PATH ON LEFT
 PRE # 52742770
 LAND NOTES : LXMN 1/07/05 SPLIT FROM THE 05

STRUCTURE: 000 000 60X61 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001969831
	8/17/10	AP	T/S: August 17, 2010 11:21 AM BSUTTON -----
A814 01	8/23/10	TI	ADDRESS CONFIRMATION VRU #: 001972959
B103 01	8/23/10	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001972942
	8/23/10	AP	T/S: August 23, 2010 02:06 PM BSUTTON -----
B105 01	8/25/10	TI	R*OPEN FLOOR VRU #: 001974609
	<u>8/25</u>	<u>AP</u>	
----- COMMENTS AND NOTES -----			

#111593

ADDRESS : 81 WHITE TAIL PATH SUBDIV: DEER PATH FARMS
 CONTRACTOR : GREEN RESIDENTIAL LLC PHONE : (919) 417-1747
 OWNER : CARROLL DAVID B & WIFE PHONE : (910) 890-1842
 PARCEL : 07-0588- - -0093- -27-
 APPL NUMBER: 10-50023926 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/05/2010 12:06 PM JBROCK ----
 HWY 421 TOWARDS DUNN TURN RIGHT ON OLD
 STAGE RD TRUN RIGHT ON THORTONS CREEK
 RD WHITETAIL PATH ON LEFT
 PRE # 52742770
 LAND NOTES : LXMN 1/07/05 SPLIT FROM THE 05

STRUCTURE: 000 000 60X61 3BDR CRAWL W/ GARAGE
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001969831
	8/17/10	AP	T/S: August 17, 2010 11:21 AM BSUTTON -----
B103 01	8/23/10	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001972942
	8/23/10	AP	T/S: August 23, 2010 02:06 PM BSUTTON -----
A814 01	8/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001972959
	8/25/10	AP	T/S: 08/25/2010 02:01 PM TWARD ----- 81 white tail path lot 12 T/S: 08/25/2010 02:01 PM TWARD -----
B105 01	8/25/10	KS	R*OPEN FLOOR VRU #: 001974609
	8/25/10	AP	
R425 01	9/27/10	BS	FOUR TRADE ROUGH IN VRU #: 001986942
	9/27/10	CA	T/S: 09/27/2010 07:41 AM JBROCK -----
R425 02	10/04/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001988286
	<u>10-4</u>	<u>DA</u>	Requesting PM inspection T/S: 09/30/2010 07:39 AM NTART ----- T/S: 09/30/2010 07:40 AM NTART ----- T/S: 10/01/2010 07:38 AM NTART -----

OK. to Insulate + Brick

COMMENTS AND NOTES -----

**Violation Notice
Do Not Remove**

**Harnett County Inspection Department
102 East Front St P.O. Box 65
Lillington, NC 27546
Phone (910) 893-7525 Fax (910) 893-2793**

10-500223926

October 4, 2010

1. House not permitted for upstairs habitable space.
2. Girder truss T-8 not nailed per cut sheet
3. Fire block between bottom stair stringers
4. Fire caulk chase nest to fireplace
5. Install and test upstairs bath/shower
6. Install and test master bedroom shower

**Ken Slattum
Building Code Administrator**

ADDRESS : 81 WHITE TAIL PATH SUBDIV: DEER PATH FARMS
 CONTRACTOR : GREEN RESIDENTIAL LLC PHONE : (919) 417-1747
 OWNER : CARROLL DAVID B & WIFE PHONE : (910) 890-1842
 PARCEL : 07-0588- - -0093- -27-
 APPL NUMBER: 10-50023926 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/05/2010 12:06 PM JBROCK ----
 HWY 421 TOWARDS DUNN TURN RIGHT ON OLD
 STAGE RD TRUN RIGHT ON THORTONS CREEK
 RD WHITETAIL PATH ON LEFT
 PRE # 52742770

LAND NOTES : LXMN 1/07/05 SPLIT FROM THE 05

STRUCTURE: 000 000 60X61 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001969831
	8/17/10	AP	T/S: August 17, 2010 11:21 AM BSUTTON -----
B103 01	8/23/10	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001972942
	8/23/10	AP	T/S: August 23, 2010 02:06 PM BSUTTON -----
A814 01	8/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001972959
	8/25/10	AP	T/S: 08/25/2010 02:01 PM TWARD ----- 81 white tail path lot 12 T/S: 08/25/2010 02:01 PM TWARD -----
B105 01	8/25/10	KS	R*OPEN FLOOR VRU #: 001974609
	8/25/10	AP	
R425 01	9/27/10	BS	FOUR TRADE ROUGH IN VRU #: 001986942
	9/27/10	CA	T/S: 09/27/2010 07:41 AM JBROCK -----
R425 02	10/04/10	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001988286
	10/04/10	DA	Requesting PM inspection T/S: 09/30/2010 07:39 AM NTART ----- T/S: 09/30/2010 07:40 AM NTART ----- T/S: 10/01/2010 07:38 AM NTART -----
			✓ 1-HOUSE NOT PERMITTED FOR UPSTAIRS HABITABLE SPACE. ✓ 2-GIRDER TRUSS T-8 NOT NAILED PER CUT SHEET. ✓ 3-FIRE BLOCK BETWEEN BOTTOM STAIR STRINGERS. ✓ 4-FIRE CAULK CHASE NEXT TO FIREPLACE. ✓ 5-INSTALL AND TEST UPSTAIRS BATH/SHOWER. ✓ 6-INSTALL AND TEST MASTER BEDROOM SHOWER. OKAY TO BRICK AND INSULATE. KS
I129 01	10/06/10	TI	R*INSULATION INSPECTION VRU #: 001989714
	<u>10-6</u>	<u>AP</u>	
R425 03	10/06/10	TI	FOUR TRADE ROUGH IN VRU #: 001989706
	<u>10-6</u>	<u>AP</u>	

----- COMMENTS AND NOTES -----

 ADDRESS . . : 81 WHITE TAIL PATH SUBDIV: DEER PATH FARMS
 CONTRACTOR : GREEN RESIDENTIAL LLC PHONE : (919) 417-1747
 OWNER . . : CARROLL DAVID B & WIFE PHONE : (910) 890-1842
 PARCEL . . : 07-0588- - -0093- -27-
 APPL NUMBER: 10-50023926 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/05/2010 12:06 PM JBROCK ----
 HWY 421 TOWARDS DUNN TURN RIGHT ON OLD
 STAGE RD TRUN RIGHT ON THORTONS CREEK
 RD WHITETAIL PATH ON LEFT
 PRE # 52742770
 LAND NOTES : LXMN 1/07/05 SPLIT FROM THE 05

STRUCTURE: 000 000 60X61 3BDR CRAWL W/ GARAGE
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001969831
	8/17/10	AP	T/S: August 17, 2010 11:21 AM BSUTTON -----
B103 01	8/23/10	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001972942
	8/23/10	AP	T/S: August 23, 2010 02:06 PM BSUTTON -----
A814 01	8/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001972959
	8/25/10	AP	T/S: 08/25/2010 02:01 PM TWARD ----- ✓ 81 white tail path lot 12 T/S: 08/25/2010 02:01 PM TWARD -----
B105 01	8/25/10	KS	R*OPEN FLOOR VRU #: 001974609
	8/25/10	AP	
R425 01	9/27/10	BS	FOUR TRADE ROUGH IN VRU #: 001986942
	9/27/10	CA	T/S: 09/27/2010 07:41 AM JBROCK -----
R425 02	10/04/10	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001988286
	10/04/10	DA	Requesting PM inspection T/S: 09/30/2010 07:39 AM NTART ----- T/S: 09/30/2010 07:40 AM NTART ----- T/S: 10/01/2010 07:38 AM NTART ----- 1-HOUSE NOT PERMITTED FOR UPSTAIRS HABITABLE SPACE. 2-GIRDER TRUSS T-8 NOT NAILED PER CUT SHEET. 3-FIRE BLOCK BETWEEN BOTTOM STAIR STRINGERS. 4-FIRE CAULK CHASE NEXT TO FIREPLACE. 5-INSTALL AND TEST UPSTAIRS BATH/SHOWER. 6-INSTALL AND TEST MASTER BEDROOM SHOWER. OKAY TO BRICK AND INSULATE. KS
I129 01	10/06/10	KS	R*INSULATION INSPECTION VRU #: 001989714
	10/06/10	AP	
R425 03	10/06/10	KS	FOUR TRADE ROUGH IN VRU #: 001989706
	10/06/10	AP	
H824 01	12/17/10	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002020261
	12/17/10	AP	T/S: 12/17/2010 08:20 AM SZIMMER ----- T/S: 12/17/2010 08:21 AM SZIMMER -----
R429 01	12/22/10	TI	FOUR TRADE FINAL VRU #: 002021723

12-22 DA

 COMMENTS AND NOTES

Canth under approved 35' x 11' porch support
17ndw Access shedrock + garage.

**Violation Notice
Do Not Remove**

**Harnett County Inspection Department
102 East Front St P.O. Box 65
Lillington, NC 27546
Phone (910) 893-7525 Fax (910) 893-2793**

10-50023926

Dec 23, 2010

1. No 911 numbers on house.
2. Windows shall be caulked to brick
3. Back steps shall have two handrails with pickets.
4. All stair hand rails shall return to wall
5. Access doors shall be painted or treated lumber
6. Garage walls and ceiling shall be taped and finished

**Ken Slattum
Building Code Administrator**

ADDRESS : 81 WHITE TAIL PATH
CONTRACTOR : GREEN RESIDENTIAL LLC
OWNER : CARROLL DAVID B & WIFE
PARCEL : 07-0588- -0093- -27-
APPL NUMBER: 10-50023926 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/05/2010 12:06 PM JBROCK ----
HWY 421 TOWARDS DUNN TURN RIGHT ON OLD
STAGE RD TRUN RIGHT ON THORTONS CREEK
RD WHITETAIL PATH ON LEFT
PRE # 52742770
LAND NOTES : LXMN 1/07/05 SPLIT FROM THE 05

SUBDIV: DEER PATH FARMS
PHONE : (919) 417-1747
PHONE : (910) 890-1842

STRUCTURE: 000 000 60X61 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/17/10	BS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001969831 T/S: August 17, 2010 11:21 AM BSUTTON
B103 01	8/23/10	BS	R*BLDG FOUND & TEMP SVC POLE VRU #: 001972942 T/S: August 23, 2010 02:06 PM BSUTTON
A814 01	8/23/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001972959
	8/25/10	AP	T/S: 08/25/2010 02:01 PM TWARD 81 white tail path lot 12 T/S: 08/25/2010 02:01 PM TWARD
B105 01	8/25/10	KS	R*OPEN FLOOR VRU #: 001974609
	8/25/10	AP	
R425 01	9/27/10	BS	FOUR TRADE ROUGH IN VRU #: 001986942 T/S: 09/27/2010 07:41 AM JBROCK
	9/27/10	CA	
R425 02	10/04/10	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001988286 Requesting PM inspection
	10/04/10	DA	T/S: 09/30/2010 07:39 AM NTART T/S: 09/30/2010 07:40 AM NTART T/S: 10/01/2010 07:38 AM NTART 1-HOUSE NOT PERMITTED FOR UPSTAIRS HABITABLE SPACE. 2-GIRDER TRUSS T-8 NOT NAILED PER CUT SHEET. 3-FIRE BLOCK BETWEEN BOTTOM STAIR STRINGERS. 4-FIRE CAULK CHASE NEXT TO FIREPLACE. 5-INSTALL AND TEST UPSTAIRS BATH/SHOWER. 6-INSTALL AND TEST MASTER BEDROOM SHOWER. OKAY TO BRICK AND INSULATE. KS
I129 01	10/06/10	KS	R*INSULATION INSPECTION VRU #: 001989714
	10/06/10	AP	
R425 03	10/06/10	KS	FOUR TRADE ROUGH IN VRU #: 001989706
	10/06/10	AP	
H824 01	12/17/10	JM	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002020261
	12/17/10	AP	T/S: 12/17/2010 08:20 AM SZIMMER T/S: 12/17/2010 08:21 AM SZIMMER
R429 01	12/22/10	KS	FOUR TRADE FINAL VRU #: 002021723
	12/22/10	DA	T/S: 12/22/2010 02:54 PM KSLATTUM 1.no 911 numbers 2. Windows shall be caulked

ADDRESS . . : 81 WHITE TAIL PATH
CONTRACTOR : GREEN RESIDENTIAL LLC
OWNER . . . : CARROLL DAVID B & WIFE
PARCEL . . . : 07-0588- - -0093- -27-
APPL NUMBER: 10-50023926 CP NEW RESIDENTIAL (SFD)

SUBDIV: DEER PATH FARMS
PHONE : (919) 417-1747
PHONE : (910) 890-1842

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 02	12/30/10 <u>12-30</u>	TI <u>AP</u>	3. Back steps shall have two handrails with pickets. 4. All stair hand rails shall return to wall 5. Access doors shall be painted. 6. Garage walls and ceiling shall be taped. FOUR TRADE FINAL VRU #: 002023919 ****Key will be in permit box****
----- COMMENTS AND NOTES -----			

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: Occupancy: ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: David Carroll

Address: 81 Whitetail Path

Date: 12-30-10

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Building Official: [Signature]

50023926