
ADDRESS : 508 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
 OWNER : CRESTVIEW DEVELOPMENT LLC PHONE :
 PARCEL : 09-9567-02- -0006- -29-
 APPL NUMBER: 10-50023944 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/09/2010 12:36 PM VBROWN ----
 508 SPRING FLOWERS DRIVE, CORNER LOT ON
 THE CORNER OF SPRINGFLOWER DRIVE AND A
 STEET UN NAMED THAT IS NOT ON THE SITE
 PLAN OR GIS, THE DRIVEWAY IS ON THE UN
 NAMED STREET. CAROLINA SEASONS SUB DIV
 #30. GO DOWN PONDEROSA, RIGHT ONTO FEM
 RIDGE, RIGHT ONTO GREEN LINKS, LEFT
 ONTO SPRING FLOWERS DRIVE, LOT IS DOWN
 ON RIGHT.

STRUCTURE: 000 000 60.4X63.5 4BDR 3BATH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUTNY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/10 <u>3-26</u>	TI <u>MP</u>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001900760 T/S: 03/25/2010 01:35 PM RDCONTE -----

----- COMMENTS AND NOTES -----

ADDRESS : 508 SPRING FLOWERS DR
CONTRACTOR : JASON PRICE CONST. INC
OWNER : CRESTVIEW DEVELOPMENT LLC
PARCEL : 09-9567-02- -0006- -29-
APPL NUMBER: 10-50023944 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/09/2010 12:36 PM VBROWN ----
508 SPRING FLOWERS DRIVE, CORNER LOT ON
THE CORNER OF SPRINGFLOWER DRIVE AND A
STREET UN NAMED THAT IS NOT ON THE SITE
PLAN OR GIS, THE DRIVEWAY IS ON THE UN
NAMED STREET. CAROLINA SEASONS SUB DIV
#30. GO DOWN PONDEROSA, RIGHT ONTO FEM
RIDGE, RIGHT ONTO GREEN LINKS, LEFT
ONTO SPRING FLOWERS DRIVE, LOT IS DOWN
ON RIGHT.

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
PHONE : (910) 897-8811
PHONE :

STRUCTURE: 000 000 60.4X63.5 4BDR 3BATH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUTNY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/10 3/26/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001900760 T/S: 03/25/2010 01:35 PM RDCONTE ----- no tpole up at inspection T/S: 03/26/2010 01:14 PM KSLATTUM -----
A814 01	3/31/10	TI	ADDRESS CONFIRMATION VRU #: 001902352
B103 01	3/31/10 <u>3/31/10</u>	TI <u>DAEDT</u>	R*BLDG FOUND & TEMP SVC POLE VRU #: 001902345

COMMENTS AND NOTES

ADDRESS : 508 SPRING FLOWERS DR
 CONTRACTOR : JASON PRICE CONST. INC
 OWNER : CRESTVIEW DEVELOPMENT LLC
 PARCEL : 09-9567-02- -0006- -29-
 APPL NUMBER: 10-50023944 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/09/2010 12:36 PM VBROWN ----
 508 SPRING FLOWERS DRIVE, CORNER LOT ON
 THE CORNER OF SPRINGFLOWER DRIVE AND A
 STEET UN NAMED THAT IS NOT ON THE SITE
 PLAN OR GIS, THE DRIVEWAY IS ON THE UN
 NAMED STREET. CAROLINA SEASONS SUB DIV
 #30. GO DOWN PONDEROSA, RIGHT ONTO FEM
 RIDGE, RIGHT ONTO GREEN LINKS, LEFT
 ONTO SPRING FLOWERS DRIVE, LOT IS DOWN
 ON RIGHT.

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 PHONE : (910) 897-8811
 PHONE :

STRUCTURE: 000 000 60.4X63.5 4BDR 3BATH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00
 SEPTIC - EXISTING? : NEW SEPTIC
 PROPOSED USE : SFD
 WATER SUPPLY : COUTNY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/10 3/26/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001900760 T/S: 03/25/2010 01:35 PM RDCONTE ----- no tpole up at inspection T/S: 03/26/2010 01:14 PM KSLATTUM -----
A814 01	3/31/10	TI	ADDRESS CONFIRMATION VRU #: 001902352
B103 01	3/31/10 3/31/10	DT AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001902345 1. Missing projection for pier marked on plans. Have repair and call for open floor inspection. T/S: 03/31/2010 11:12 AM DETAYLOR ----- T/S: 03/31/2010 01:55 PM NTART ----- T/S: 03/31/2010 01:55 PM DETAYLOR -----
B105 01	4/01/10 <u>4/1/10</u>	TI <u>AP IV</u>	R*OPEN FLOOR VRU #: 001903459

COMMENTS AND NOTES

ADDRESS : 508 SPRING FLOWERS DR
CONTRACTOR : JASON PRICE CONST. INC
OWNER : CRESTVIEW DEVELOPMENT LLC
PARCEL : 09-9567-02- -0006- -29-
APPL NUMBER: 10-50023944 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/09/2010 12:36 PM VBROWN ----
508 SPRING FLOWERS DRIVE, CORNER LOT ON
THE CORNER OF SPRINGFLOWER DRIVE AND A
STREET UN NAMED THAT IS NOT ON THE SITE
PLAN OR GIS, THE DRIVEWAY IS ON THE UN
NAMED STREET. CAROLINA SEASONS SUB DIV
#30. GO DOWN PONDEROSA, RIGHT ONTO FEM
RIDGE, RIGHT ONTO GREEN LINKS, LEFT
ONTO SPRING FLOWERS DRIVE, LOT IS DOWN
ON RIGHT.

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
PHONE : (910) 897-8811
PHONE :

STRUCTURE: 000 000 60.4X63.5 4BDR 3BATH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00
SEPTIC - EXISTING? : NEW SEPTIC
PROPOSED USE : SFD
WATER SUPPLY : COUTNY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/10 3/26/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001900760 T/S: 03/25/2010 01:35 PM RDCONTE ----- no tpole up at inspection T/S: 03/26/2010 01:14 PM KSLATTUM -----
B103 01	3/31/10 3/31/10	DT AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001902345 1. Missing projection for pier marked on plans. Have repair and call for open floor inspection. T/S: 03/31/2010 11:12 AM DEXTAYLOR ----- T/S: 03/31/2010 01:55 PM NTART ----- T/S: 03/31/2010 01:55 PM DEXTAYLOR -----
A814 01	3/31/10 4/01/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902352 508 SPRING FLOWERS DR LOT 30 ----- CAMERON 28326 ***NOTE: DRIVE OFF UN NAMED(WETLAND ISSUE)FACING SPRING FLOWERS.....WILL BE ADDRESSED OFF OF SPRING FLOWERS DR T/S: 04/01/2010 11:05 AM TWARD -----
B105 01	4/01/10 4/01/10	DT AP	R*OPEN FLOOR VRU #: 001903459
R427 01	4/19/10 <i>4-19-10</i>	TT <i>DA</i>	FOUR TRADE ROUGH IN >2500 VRU #: 001911429

COMMENTS AND NOTES

*FLR. NOT FINISHED
NEED TEST ON PLUMBING
DOUBLE TRUSS IN GARAGE NEED TRUSS*

ADDRESS : 508 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
 OWNER : CRESTVIEW DEVELOPMENT LLC PHONE :
 PARCEL : 09-9567-02- -0006- -29-
 APPL NUMBER: 10-50023944 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/09/2010 12:36 PM VBROWN ----
 508 SPRING FLOWERS DRIVE, CORNER LOT ON
 THE CORNER OF SPRINGFLOWER DRIVE AND A
 STEET UN NAMED THAT IS NOT ON THE SITE
 PLAN OR GIS, THE DRIVEWAY IS ON THE UN
 NAMED STREET. CAROLINA SEASONS SUB DIV
 #30. GO DOWN PONDEROSA, RIGHT ONTO FEM
 RIDGE, RIGHT ONTO GREEN LINKS, LEFT
 ONTO SPRING FLOWERS DRIVE, LOT IS DOWN
 ON RIGHT.

STRUCTURE: 000 000 60.4X63.5 4BDR 3BATH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUTNY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/10 3/26/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001900760 T/S: 03/25/2010 01:35 PM RDCONTE ----- no tpole up at inspection T/S: 03/26/2010 01:14 PM KSLATTUM -----
B103 01	3/31/10 3/31/10	DT AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001902345 1. Missing projection for pier marked on plans. Have repair and call for open floor inspection. T/S: 03/31/2010 11:12 AM DETAYLOR ----- T/S: 03/31/2010 01:55 PM NTART ----- T/S: 03/31/2010 01:55 PM DETAYLOR -----
A814 01	3/31/10 4/01/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902352 508 SPRING FLOWERS DR LOT 30 ----- CAMERON 28326 ***NOTE: DRIVE OFF UN NAMED(WETLAND ISSUE) FACING SPRING FLOWERS.....WILL BE ADDRESSED OFF OF SPRING FLOWERS DR T/S: 04/01/2010 11:05 AM TWARD -----
B105 01	4/01/10 4/01/10	DT AP	R*OPEN FLOOR VRU #: 001903459
R427 01	4/19/10 4/19/10	FS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001911429 T/S: 04/19/2010 02:03 PM NTART ----- ELECTRICAL, NO TEST ON PLUMBING AND TRUSS TIE IN GARAGE.
R427 02	4/20/10 4-20-10	TI AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001913060 T/S: 04/19/2010 02:04 PM NTART -----

COMMENTS AND NOTES

JS

ADDRESS : 508 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
 OWNER : CRESTVIEW DEVELOPMENT LLC PHONE :
 PARCEL : 09-9567-02- -0006- -29-
 APPL NUMBER: 10-50023944 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/09/2010 12:36 PM VBROWN ----
 508 SPRING FLOWERS DRIVE, CORNER LOT ON
 THE CORNER OF SPRINGFLOWER DRIVE AND A
 STEET UN NAMED THAT IS NOT ON THE SITE
 PLAN OR GIS, THE DRIVEWAY IS ON THE UN
 NAMED STREET. CAROLINA SEASONS SUB DIV
 #30. GO DOWN PONDEROSA, RIGHT ONTO FEM
 RIDGE, RIGHT ONTO GREEN LINKS, LEFT
 ONTO SPRING FLOWERS DRIVE, LOT IS DOWN
 ON RIGHT.

STRUCTURE: 000 000 60.4X63.5 4BDR 3BATH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUTNY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/10 3/26/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001900760 T/S: 03/25/2010 01:35 PM RDCONTE ----- no tpole up at inspection T/S: 03/26/2010 01:14 PM KSLATTUM -----
B103 01	3/31/10 3/31/10	DT AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001902345 1. Missing projection for pier marked on plans. Have repair and call for open floor inspection. T/S: 03/31/2010 11:12 AM DETAYLOR ----- T/S: 03/31/2010 01:55 PM NTART ----- T/S: 03/31/2010 01:55 PM DETAYLOR -----
A814 01	3/31/10 4/01/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902352 508 SPRING FLOWERS DR LOT 30 ----- CAMERON 28326 ***NOTE: DRIVE OFF UN NAMED(WETLAND ISSUE)FACING SPRING FLOWERS.....WILL BE ADDRESSED OFF OF SPRING FLOWERS DR T/S: 04/01/2010 11:05 AM TWARD -----
B105 01	4/01/10 4/01/10	DT AP	R*OPEN FLOOR VRU #: 001903459
R427 01	4/19/10 4/19/10	FS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001911429 T/S: 04/19/2010 02:03 PM NTART ----- ELECTRICAL, NO TEST ON PLUMBING AND TRUSS TIE IN GARAGE.
R427 02	4/20/10 4/20/10	FS AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001913060 T/S: 04/19/2010 02:04 PM NTART ----- T/S: 04/20/2010 02:40 PM FSPIVEY -----
I129 01	4/22/10 <u>4/22/10</u>	TI <u>AP D</u>	R*INSULATION INSPECTION VRU #: 001913391

COMMENTS AND NOTES

ADDRESS : 508 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 CONTRACTOR : JASON PRICE CONST. INC PHONE : (910) 897-8811
 OWNER : CRESTVIEW DEVELOPMENT LLC PHONE :
 PARCEL : 09-9567-02- -0006- -29-
 APPL NUMBER: 10-50023944 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/09/2010 12:36 PM VBROWN ----
 508 SPRING FLOWERS DRIVE, CORNER LOT ON
 THE CORNER OF SPRINGFLOWER DRIVE AND A
 STEET UN NAMED THAT IS NOT ON THE SITE
 PLAN OR GIS, THE DRIVEWAY IS ON THE UN
 NAMED STREET. CAROLINA SEASONS SUB DIV
 #30. GO DOWN PONDEROSA, RIGHT ONTO FEM
 RIDGE, RIGHT ONTO GREEN LINKS, LEFT
 ONTO SPRING FLOWERS DRIVE, LOT IS DOWN
 ON RIGHT.

STRUCTURE: 000 000 60.4X63.5 4BDR 3BATH GAR DECK CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW SEPTIC WATER SUPPLY : COUTNY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/10 3/26/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001900760 T/S: 03/25/2010 01:35 PM RDCONTE ----- no tpole up at inspection T/S: 03/26/2010 01:14 PM KSLATTUM -----
B103 01	3/31/10 3/31/10	DT AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001902345 1. Missing projection for pier marked on plans. Have repair and call for open floor inspection. T/S: 03/31/2010 11:12 AM DEXTAYLOR ----- T/S: 03/31/2010 01:55 PM NTART ----- T/S: 03/31/2010 01:55 PM DEXTAYLOR -----
A814 01	3/31/10 4/01/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001902352 508 SPRING FLOWERS DR LOT 30 ----- CAMERON 28326 ***NOTE: DRIVE OFF UN NAMED(WETLAND ISSUE)FACING SPRING FLOWERS.....WILL BE ADDRESSED OFF OF SPRING FLOWERS DR T/S: 04/01/2010 11:05 AM TWARD -----
B105 01	4/01/10 4/01/10	DT AP	R*OPEN FLOOR VRU #: 001903459
R427 01	4/19/10 4/19/10	FS DA	FOUR TRADE ROUGH IN >2500 VRU #: 001911429 T/S: 04/19/2010 02:03 PM NTART ----- ELECTRICAL, NO TEST ON PLUMBING AND TRUSS TIE IN GARAGE.
R427 02	4/20/10 4/20/10	FS AP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 001913060 T/S: 04/19/2010 02:04 PM NTART ----- T/S: 04/20/2010 02:40 PM FSPIVEY -----
I129 01	4/22/10 4/22/10	DT AP	R*INSULATION INSPECTION VRU #: 001913391
H824 01	5/11/10 5/11/10	OT AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001925296 T/S: 05/12/2010 10:30 AM SSTEWARD ----- T/S: 05/12/2010 10:30 AM SSTEWARD -----
R431 01	6/02/10	TI	FOUR TRADE FINAL >2500 VRU #: 001935154

ADDRESS . : 508 SPRING FLOWERS DR
CONTRACTOR : JASON PRICE CONST. INC
OWNER . . : CRESTVIEW DEVELOPMENT LLC
PARCEL . . : 09-9567-02- -0006- -29-
APPL NUMBER: 10-50023944 CP NEW RESIDENTIAL (SFD)

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
PHONE : (910) 897-8811
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

	10 6-2-10	AP	
--	-------------------------	----	--

COMMENTS AND NOTES

FS

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: V Home

Name: JASON PRICK

Address: 508 SPRING FLOWERS
CAMERON 28325

Date: 6-2-10

Building Official: [Signature]

Permit Numbers

Building: 10-5-23944

Electrical: 10-5-25944

Insulation: 10-5-25944

Plumbing: 10-5-25944

Mechanical: 10-5-25944

MEG Home: 1