

ADDRESS : 409 SPRING FLOWERS DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : CRESTVIEW DEVELOPMENT LLC
PARCEL : 09-9567-02- -0006- -51-
APPL NUMBER: 10-50023948 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/10/2010 10:41 AM JBROCK ----
TAKE HWY 27 TAKE A RIGHT ON
JOHNSONVILLESCHOOL RD TAKE RIGHT ON
PONDEROSA RD TURN LEFT INTO S/D TURN
RIGHT ON GREEN LINKS DR TURN LEFT ON
SPRING FLOWERS DR LOT ON LEFT LOT 52

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
PHONE : (910) 892-4345
PHONE :

STRUCTURE: 000 000 52X52 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00
SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------------|-----------------|---|
| B101 01 | 4/15/10 <i>4-15-10</i> | TI <i>AP</i> | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001910365 |

COMMENTS AND NOTES

FS

ADDRESS . . : 409 SPRING FLOWERS DR
 CONTRACTOR : CUMBERLAND HOMES INC
 OWNER . . . : CRESTVIEW DEVELOPMENT LLC
 PARCEL . . . : 09-9567-02- -0006- -51-
 APPL NUMBER: 10-50023948 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/10/2010 10:41 AM JBROCK ----
 TAKE HWY 27 TAKE A RIGHT ON
 JOHNSONVILLESCHOOL RD TAKE RIGHT ON
 PONDEROSA RD TURN LEFT INTO S/D TURN
 RIGHT ON GREEN LINKS DR TURN LEFT ON
 SPRING FLOWERS DR LOT ON LEFT LOT 52

STRUCTURE: 000 000 52X52 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------------|-----------------|--|
| B101 01 | 4/15/10 4/15/10 | DT DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001910365 1. Girder truss not strapped for uplift. T/S: 04/15/2010 10:54 AM DETAYLOR ----- T/S: 04/26/2010 12:27 PM NTART ----- |
| B101 02 | 4/27/10 <i>4/27/10</i> | TI <i>AC</i> | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001916238 T/S: 04/26/2010 12:29 PM NTART ----- |
| B103 01 | 4/27/10 | TI | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001916253 T/S: 04/26/2010 12:30 PM NTART ----- |

----- COMMENTS AND NOTES -----

FS

ADDRESS : 409 SPRING FLOWERS DR
CONTRACTOR : CUMBERLAND HOMES INC
OWNER : CRESTVIEW DEVELOPMENT LLC
PARCEL : 09-9567-02--0006-51-
APPL NUMBER: 10-50023948 CP NEW RESIDENTIAL (SFD)

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
PHONE : (910) 892-4345
PHONE :

DIRECTIONS : T/S: 03/10/2010 10:41 AM JBROCK ----
TAKE HWY 27 TAKE A RIGHT ON
JOHNSONVILLESCHOOL RD TAKE RIGHT ON
PONDEROSA RD TURN LEFT INTO S/D TURN
RIGHT ON GREEN LINKS DR TURN LEFT ON
SPRING FLOWERS DR LOT ON LEFT LOT 52

STRUCTURE: 000 000 52X52 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|---|
| B101 01 | 4/15/10 | DT | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001910365 |
| | 4/15/10 | DA | 1. Girder truss not strapped for uplift. T/S: 04/15/2010 10:54 AM DETAYLOR T/S: 04/26/2010 12:27 PM NTART |
| B101 02 | 4/27/10 | FS | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001916238 |
| | 4/27/10 | AP | T/S: 04/26/2010 12:29 PM NTART T/S: 04/27/2010 07:35 AM NTART |
| B103 01 | 4/27/10 | TI | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001916253 |
| | | | T/S: 04/26/2010 12:30 PM NTART |

COMMENTS AND NOTES

ADDRESS : 409 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : CRESTVIEW DEVELOPMENT LLC PHONE :
PARCEL : 09-9567-02- -0006- -51-
APPL NUMBER: 10-50023948 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/10/2010 10:41 AM JBROCK ----
TAKE HWY 27 TAKE A RIGHT ON
JOHNSONVILLESCHOOL RD TAKE RIGHT ON
PONDEROSA RD TURN LEFT INTO S/D TURN
RIGHT ON GREEN LINKS DR TURN LEFT ON
SPRING FLOWERS DR LOT ON LEFT LOT 52

STRUCTURE: 000 000 52X52 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|--------------------------|-----------------|--|
| B101 01 | 4/15/10 4/15/10 | DT DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001910365 1. Girder truss not strapped for uplift. T/S: 04/15/2010 10:54 AM DETAYLOR ----- T/S: 04/26/2010 12:27 PM NTART ----- |
| B101 02 | 4/27/10 4/27/10 | FS AP | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001916238 T/S: 04/26/2010 12:29 PM NTART ----- T/S: 04/27/2010 07:35 AM NTART ----- |
| B103 01 | 4/27/10 4/28/10 | FS AP | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001916253 T/S: 04/26/2010 12:30 PM NTART ----- T/S: 04/28/2010 06:53 AM FSPIVEY ----- |
| B111 01 | 5/03/10 <i>5-3-10</i> | TI <i>AP</i> | R*BLDG SLAB INSP VRU #: 001919117 |
| P309 01 | 5/03/10 <i>5-3-10</i> | TI <i>AP</i> | R*PLUMB UNDER SLAB VRU #: 001918895 |
| A814 01 | 5/03/10 4/30/10 | TW AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001918911 409 SPRING FLOWERS DR LOT 52 CAMERON 28326 T/S: 04/30/2010 09:57 AM TWARD ----- |

COMMENTS AND NOTES

FS

ADDRESS : 409 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
OWNER : CRESTVIEW DEVELOPMENT LLC PHONE :
PARCEL : 09-9567-02- -0006- -51-
APPL NUMBER: 10-50023948 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/10/2010 10:41 AM JBROCK ----
TAKE HWY 27 TAKE A RIGHT ON
JOHNSONVILLESCHOOL RD TAKE RIGHT ON
PONDEROSA RD TURN LEFT INTO S/D TURN
RIGHT ON GREEN LINKS DR TURN LEFT ON
SPRING FLOWERS DR LOT ON LEFT LOT 52

STRUCTURE: 000 000 52X52 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------------|-----------------|--|
| B101 01 | 4/15/10 4/15/10 | DT DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001910365 1. Girder truss not strapped for uplift. T/S: 04/15/2010 10:54 AM DETAYLOR ----- T/S: 04/26/2010 12:27 PM NTART ----- |
| B101 02 | 4/27/10 4/27/10 | FS AP | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001916238 T/S: 04/26/2010 12:29 PM NTART ----- T/S: 04/27/2010 07:35 AM NTART ----- |
| B103 01 | 4/27/10 4/28/10 | FS AP | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001916253 T/S: 04/26/2010 12:30 PM NTART ----- T/S: 04/28/2010 06:53 AM FSPIVEY ----- |
| B111 01 | 5/03/10 5/03/10 | FS AP | R*BLDG SLAB INSP VRU #: 001919117 T/S: 05/03/2010 02:22 PM FSPIVEY ----- |
| P309 01 | 5/03/10 5/03/10 | FS AP | R*PLUMB UNDER SLAB VRU #: 001918895 T/S: 05/03/2010 02:22 PM FSPIVEY ----- |
| A814 01 | 5/03/10 4/30/10 | TW AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001918911 409 SPRING FLOWERS DR LOT 52 CAMERON 28326 T/S: 04/30/2010 09:57 AM TWARD ----- |
| R427 01 | 5/27/10 <i>5/27/10</i> | TW <i>AP</i> | FOUR TRADE ROUGH IN >2500 VRU #: 001933282 |

COMMENTS AND NOTES

FS

ADDRESS : 409 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
 OWNER : CRESTVIEW DEVELOPMENT LLC PHONE :
 PARCEL : 09-9567-02- -0006- -51-
 APPL NUMBER: 10-50023948 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/10/2010 10:41 AM JBROCK ----
 TAKE HWY 27 TAKE A RIGHT ON
 JOHNSONVILLESCHOOL RD TAKE RIGHT ON
 PONDEROSA RD TURN LEFT INTO S/D TURN
 RIGHT ON GREEN LINKS DR TURN LEFT ON
 SPRING FLOWERS DR LOT ON LEFT LOT 52

STRUCTURE: 000 000 52X52 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| B101 01 | 4/15/10 4/15/10 | DT DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001910365 1. Girder truss not strapped for uplift. T/S: 04/15/2010 10:54 AM DETAYLOR ----- T/S: 04/26/2010 12:27 PM NTART ----- |
| B101 02 | 4/27/10 4/27/10 | FS AP | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001916238 T/S: 04/26/2010 12:29 PM NTART ----- T/S: 04/27/2010 07:35 AM NTART ----- |
| B103 01 | 4/27/10 4/28/10 | FS AP | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001916253 T/S: 04/26/2010 12:30 PM NTART ----- T/S: 04/28/2010 06:53 AM FSPIVEY ----- |
| B111 01 | 5/03/10 5/03/10 | FS AP | R*BLDG SLAB INSP VRU #: 001919117 T/S: 05/03/2010 02:22 PM FSPIVEY ----- |
| P309 01 | 5/03/10 5/03/10 | FS AP | R*PLUMB UNDER SLAB VRU #: 001918895 T/S: 05/03/2010 02:22 PM FSPIVEY ----- |
| A814 01 | 5/03/10 4/30/10 | TW AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001918911 409 SPRING FLOWERS DR LOT 52 CAMERON 28326 T/S: 04/30/2010 09:57 AM TWARD ----- |
| R427 01 | 5/27/10 5/27/10 | FS AP | FOUR TRADE ROUGH IN >2500 VRU #: 001933282 T/S: 05/27/2010 01:54 PM FSPIVEY ----- |
| I129 01 | 6/02/10 | TI | R*INSULATION INSPECTION VRU #: 001935170 |

Handwritten signature and date:
 6-2-10 [Signature]

COMMENTS AND NOTES

Large handwritten mark or signature.

ADDRESS : 409 SPRING FLOWERS DR
 CONTRACTOR : CUMBERLAND HOMES INC
 OWNER : CRESTVIEW DEVELOPMENT LLC
 PARCEL : 09-9567-02- -0006- -51-
 APPL NUMBER: 10-50023948 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/10/2010 10:41 AM JBROCK ----
 TAKE HWY 27 TAKE A RIGHT ON
 JOHNSONVILLESCHOOL RD TAKE RIGHT ON
 PONDEROSA RD TURN LEFT INTO S/D TURN
 RIGHT ON GREEN LINKS DR TURN LEFT ON
 SPRING FLOWERS DR LOT ON LEFT LOT 52

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 PHONE : (910) 892-4345
 PHONE :

STRUCTURE: 000 000 52X52 4BDR SLAB W/ GARAGE & PATIO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00
 SEPTIC - EXISTING? : NEW
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| B101 01 | 4/15/10 4/15/10 | DT DA | R*BLDG FOOTING / TEMP SVC POLE VRU #: 001910365 1. Girder truss not strapped for uplift. T/S: 04/15/2010 10:54 AM DETAYLOR ----- T/S: 04/26/2010 12:27 PM NTART ----- |
| B101 02 | 4/27/10 4/27/10 | FS AP | R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001916238 T/S: 04/26/2010 12:29 PM NTART ----- T/S: 04/27/2010 07:35 AM NTART ----- |
| B103 01 | 4/27/10 4/28/10 | FS AP | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001916253 T/S: 04/26/2010 12:30 PM NTART ----- T/S: 04/28/2010 06:53 AM FSPIVEY ----- |
| B111 01 | 5/03/10 5/03/10 | FS AP | R*BLDG SLAB INSP VRU #: 001919117 T/S: 05/03/2010 02:22 PM FSPIVEY ----- |
| P309 01 | 5/03/10 5/03/10 | FS AP | R*PLUMB UNDER SLAB VRU #: 001918895 T/S: 05/03/2010 02:22 PM FSPIVEY ----- |
| A814 01 | 5/03/10 4/30/10 | TW AP | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001918911 409 SPRING FLOWERS DR LOT 52 CAMERON 28326 T/S: 04/30/2010 09:57 AM TWARD ----- |
| R427 01 | 5/27/10 5/27/10 | FS AP | FOUR TRADE ROUGH IN >2500 VRU #: 001933282 T/S: 05/27/2010 01:54 PM FSPIVEY ----- |
| I129 01 | 6/02/10 6/03/10 | FS AP | R*INSULATION INSPECTION VRU #: 001935170 T/S: 06/03/2010 02:50 PM FSPIVEY ----- |
| H824 01 | 7/30/10 7/30/10 | OT AP | ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001962554 T/S: 08/02/2010 09:17 AM SZIMMER ----- T/S: 08/02/2010 09:18 AM SZIMMER ----- |
| R429 01 | 8/03/10 8.5.10 | TI AP | FOUR TRADE FINAL VRU #: 001962786 |

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: HOME

Permit Numbers

Name: CHRISTVIEW DRIVE

Building: KS-25948

Address: 409 SPRING FLOWERS
CAMERON RD 2525

Electrical: KS-25948

Insulation: KS-25948

Plumbing: KS-25948

Mechanical: KS-25948

MFG Home:

Date: 8-5-10

Building Official: [Signature]