

PREPARED 4/30/10, 14:14:48
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 35
DATE 5/03/10

ADDRESS . . : 405 FIFTY CALIBER DR
CONTRACTOR : BILL CLARK HOMES LLC
OWNER . . . : BILL CLARK HOMES OF FAY
PARCEL . . . : 03-9597- - -0039- -16-
APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/16/2010 10:14 AM JBROCK ----
27 TOWARD 87 TURN LEFT ON TINGEN RD
TURN LEFT IN S/D ON STRIKE EAGLE DR
TURN LEFT ON BUNKER BUSTER CT TURN LEFT
ON FIFTY CALIBER DR LOT 19

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	5/03/10	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973

5-3-10 DA-MR

----- COMMENTS AND NOTES -----

Clean-out Footer

ADDRESS : 405 FIFTY CALIBER DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES OF FAY PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -16-
APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 03/16/2010 10:14 AM JBROCK ----
27 TOWARD 87 TURN LEFT ON TINGEN RD
TURN LEFT IN S/D ON STRIKE EAGLE DR
TURN LEFT ON BUNKER BUSTER CT TURN LEFT
ON FIFTY CALIBER DR LOT 19

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/03/10 5/03/10	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973 T/S: 05/03/2010 11:51 AM MREARIC ----- clae n out footer
B101 02	5/04/10 <u>5-4-10</u>	TI <u>AP-MR</u>	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001920255 T/S: 05/03/2010 03:50 PM JBROCK -----

----- COMMENTS AND NOTES -----

ADDRESS : 405 FIFTY CALIBER DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES OF FAY PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -16-
APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/16/2010 10:14 AM JBROCK ----
27 TOWARD 87 TURN LEFT ON TINGEN RD
TURN LEFT IN S/D ON STRIKE EAGLE DR
TURN LEFT ON BUNKER BUSTER CT TURN LEFT
ON FIFTY CALIBER DR LOT 19

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973
	5/03/10	DA	T/S: 05/03/2010 11:51 AM MREARIC ----- claen out footer
B101 02	5/04/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001920255
	5/04/10	AP	T/S: 05/03/2010 03:50 PM JBROCK ----- T/S: 05/04/2010 12:34 PM MREARIC -----
B103 01	5/25/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001931486

5-25-10 AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 405 FIFTY CALIBER DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC. PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES OF FAY PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -16-
APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/16/2010. 10:14 AM JBROCK ----
27 TOWARD 87 TURN LEFT ON TINGEN RD
TURN LEFT IN S/D ON STRIKE EAGLE DR
TURN LEFT ON BUNKER BUSTER CT TURN LEFT
ON FIFTY CALIBER DR LOT 19

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/03/10 5/03/10	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973 T/S: 05/03/2010 11:51 AM MREARIC ----- claen out footer
B101 02	5/04/10 5/04/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001920255 T/S: 05/03/2010 03:50 PM JBROCK ----- T/S: 05/04/2010 12:34 PM MREARIC -----
B103 01	5/25/10 5/25/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001931486 T/S: 05/25/2010 11:34 AM MREARIC -----
P309 01	6/03/10	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001935378 T/S: 06/01/2010 03:03 PM DJOHNSON -----

6-3-10 AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 405 FIFTY CALIBER DR
CONTRACTOR : BILL CLARK HOMES LLC
OWNER : BILL CLARK HOMES OF FAY
PARCEL : 03-9597- - -0039- -16-
APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/16/2010 10:14 AM JBROCK ----
27 TOWARD 87 TURN LEFT ON TINGEN RD
TURN LEFT IN S/D ON STRIKE EAGLE DR
TURN LEFT ON BUNKER BUSTER CT TURN LEFT
ON FIFTY CALIBER DR LOT 19

SUBDIV: PATTONS POINT
PHONE : (252) 355-5805
PHONE : (910) 426-2898

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973
	5/03/10	DA	T/S: 05/03/2010 11:51 AM MREARIC claen out footer
B101 02	5/04/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001920255
	5/04/10	AP	T/S: 05/03/2010 03:50 PM JBROCK T/S: 05/04/2010 12:34 PM MREARIC
B103 01	5/25/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001931486
	5/25/10	AP	T/S: 05/25/2010 11:34 AM MREARIC
P309 01	6/03/10	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001935378
	6/03/10	AP	T/S: 06/01/2010 03:03 PM DJOHNSON T/S: 06/03/2010 11:39 AM MREARIC
A814 01	6/07/10	TI	ADDRESS CONFIRMATION VRU #: 001936624
3111 01	6/07/10	TI	R*BLDG SLAB INSP VRU #: 001936616

6-7-10 AP-MR

COMMENTS AND NOTES

Harnett County

INSPECTOR: IVR

DATE 7/09/10

ADDRESS . . : 405 FIFTY CALIBER DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER . . : BILL CLARK HOMES OF FAY PHONE : (910) 426-2898
 PARCEL . . : 03-9597- - -0039- -16-
 APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/16/2010 10:14 AM JBROCK ----
 27 TOWARD 87 TURN LEFT ON TINGEN RD
 TURN LEFT IN S/D ON STRIKE EAGLE DR
 TURN LEFT ON BUNKER BUSTER CT TURN LEFT
 ON FIFTY CALIBER DR LOT 19

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/03/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973
	5/03/10	DA	T/S: 05/03/2010 11:51 AM MREARIC ----- claen out footer
B101 02	5/04/10	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001920255
	5/04/10	AP	T/S: 05/03/2010 03:50 PM JBROCK ----- T/S: 05/04/2010 12:34 PM MREARIC -----
B103 01	5/25/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001931486
	5/25/10	AP	T/S: 05/25/2010 11:34 AM MREARIC -----
P309 01	6/03/10	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001935378
	6/03/10	AP	T/S: 06/01/2010 03:03 PM DJOHNSON ----- T/S: 06/03/2010 11:39 AM MREARIC -----
B111 01	6/07/10	MR	R*BLDG SLAB INSP VRU #: 001936616
	6/07/10	AP	T/S: 06/07/2010 01:32 PM MREARIC -----
A814 01	6/07/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001936624
	6/15/10	AP	T/S: 06/15/2010 01:47 PM TWARD ----- T/S: 06/15/2010 01:47 PM TWARD -----
R425 01	7/09/10	TI	FOUR TRADE ROUGH IN VRU #: 001951664

7-9-10 DA-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 07-09-10

PERMIT # 10-50023979

ADDRESS: 405 fifty caliper dr.

VIOLATIONS:

1. Truss Strap missing in garage
2. No water pressure
3. No water in riser
4. Specs needed on truss d3g
5. Outlet box wire over-fill in dining area

Ok to side and insulate

Harnett County Building Department

Mike Rearic cell# (910) 984-4772

ADDRESS : 405 FIFTY CALIBER DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOMES OF FAY PHONE : (910) 426-2898
 PARCEL : 03-9597- - -0039- -16-
 APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/16/2010 10:14 AM JBROCK ----
 27 TOWARD 87 TURN LEFT ON TINGEN RD
 TURN LEFT IN S/D ON STRIKE EAGLE DR
 TURN LEFT ON BUNKER BUSTER CT TURN LEFT
 ON FIFTY CALIBER DR LOT 19

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/03/10 5/03/10	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973 T/S: 05/03/2010 11:51 AM MREARIC ----- claen out footer
B101 02	5/04/10 5/04/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001920255 T/S: 05/03/2010 03:50 PM JBROCK ----- T/S: 05/04/2010 12:34 PM MREARIC -----
B103 01	5/25/10 5/25/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001931486 T/S: 05/25/2010 11:34 AM MREARIC -----
P309 01	6/03/10 6/03/10	MR AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001935378 T/S: 06/01/2010 03:03 PM DJOHNSON ----- T/S: 06/03/2010 11:39 AM MREARIC -----
B111 01	6/07/10 6/07/10	MR AP	R*BLDG SLAB INSP VRU #: 001936616 T/S: 06/07/2010 01:32 PM MREARIC -----
A814 01	6/07/10 6/15/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001936624 T/S: 06/15/2010 01:47 PM TWARD ----- T/S: 06/15/2010 01:47 PM TWARD -----
R425 01	7/09/10 7/09/10	MR DA	FOUR TRADE ROUGH IN VRU #: 001951664 T/S: 07/09/2010 12:24 PM MREARIC ----- truss strap missing on garage no water pressure no riser water needspecs on truss d3g outlet box in din ing area over filled ok to side and insul.
I129 01	7/13/10 7-13-10	TI AP-IVR	R*INSULATION INSPECTION VRU #: 001953082
R425 02	7/13/10 7-13-10	TI AP-MR	FOUR TRADE ROUGH IN VRU #: 001953074

----- COMMENTS AND NOTES -----

ADDRESS : 405 FIFTY CALIBER DR SUBDIV: PATTONS POINT
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
 OWNER : BILL CLARK HOMES OF FAY PHONE : (910) 426-2898
 PARCEL : 03-9597- - -0039- -16-
 APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/16/2010 10:14 AM JBROCK ----
 27 TOWARD 87 TURN LEFT ON TINGEN RD
 TURN LEFT IN S/D ON STRIKE EAGLE DR
 TURN LEFT ON BUNKER BUSTER CT TURN LEFT
 ON FIFTY CALIBER DR LOT 19

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/03/10 5/03/10	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973 T/S: 05/03/2010 11:51 AM MREARIC claen out footer
B101 02	5/04/10 5/04/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001920255 T/S: 05/03/2010 03:50 PM JBROCK T/S: 05/04/2010 12:34 PM MREARIC
B103 01	5/25/10 5/25/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001931486 T/S: 05/25/2010 11:34 AM MREARIC
P309 01	6/03/10 6/03/10	MR AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001935378 T/S: 06/01/2010 03:03 PM DJOHNSON T/S: 06/03/2010 11:39 AM MREARIC
B111 01	6/07/10 6/07/10	MR AP	R*BLDG SLAB INSP VRU #: 001936616 T/S: 06/07/2010 01:32 PM MREARIC
A814 01	6/07/10 6/15/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001936624 T/S: 06/15/2010 01:47 PM TWARD T/S: 06/15/2010 01:47 PM TWARD
H824 01	7/08/10 7/08/10	BM AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001953587 T/S: 07/13/2010 10:15 AM SZIMMER T/S: 07/13/2010 10:16 AM SZIMMER
R425 01	7/09/10 7/09/10	MR DA	FOUR TRADE ROUGH IN VRU #: 001951664 T/S: 07/09/2010 12:24 PM MREARIC truss strap missing on garage no water pressure no riser water needspecs on truss d3g outlet box in din ing area over filled ok to side and insul.
I129 01	7/13/10 7/13/10	MR AP	R*INSULATION INSPECTION VRU #: 001953082 T/S: 07/13/2010 01:37 PM MREARIC
R425 02	7/13/10 7/13/10	MR AP	FOUR TRADE ROUGH IN VRU #: 001953074 T/S: 07/13/2010 01:37 PM MREARIC
R429 01	9/30/10	TI	FOUR TRADE FINAL VRU #: 001987988

9-30-10 DP-UR

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 09-30-10

PERMIT # 10-50023979

ADDRESS: 405 fifty caliper

CORRECTIONS NEEDED:

1. Water heater needs a lock out or a disc.
2. Four steps are needed in garage and a handrail
Steps are uneven and one is over 8-1/4"
Fee 50.00

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 405 FIFTY CALIBER DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER : BILL CLARK HOMES OF FAY PHONE : (910) 426-2898
PARCEL : 03-9597- - -0039- -16-
APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/16/2010 10:14 AM JBROCK ----
27 TOWARD 87 TURN LEFT ON TINGEN RD
TURN LEFT IN S/D ON STRIKE EAGLE DR
TURN LEFT ON BUNKER BUSTER CT TURN LEFT
ON FIFTY CALIBER DR LOT 19

STRUCTURE: 000 000 66X39 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	5/03/10 5/03/10	MR DA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001918973 T/S: 05/03/2010 11:51 AM MREARIC ---- claen out footer
B101 02	5/04/10 5/04/10	MR AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 001920255 T/S: 05/03/2010 03:50 PM JBROCK ---- T/S: 05/04/2010 12:34 PM MREARIC ----
B103 01	5/25/10 5/25/10	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 001931486 T/S: 05/25/2010 11:34 AM MREARIC ----
P309 01	6/03/10 6/03/10	MR AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001935378 T/S: 06/01/2010 03:03 PM DJOHNSON ---- T/S: 06/03/2010 11:39 AM MREARIC ----
B111 01	6/07/10 6/07/10	MR AP	R*BLDG SLAB INSP VRU #: 001936616 T/S: 06/07/2010 01:32 PM MREARIC ----
A814 01	6/07/10 6/15/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001936624 T/S: 06/15/2010 01:47 PM TWARD ---- T/S: 06/15/2010 01:47 PM TWARD ----
H824 01	7/08/10 7/08/10	BM AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001953587 T/S: 07/13/2010 10:15 AM SZIMMER ---- T/S: 07/13/2010 10:16 AM SZIMMER ----
R425 01	7/09/10 7/09/10	MR DA	FOUR TRADE ROUGH IN VRU #: 001951664 T/S: 07/09/2010 12:24 PM MREARIC ---- truss strap missing on garage no water pressure no riser water needspecs on truss d3g outlet box in din ing area over filled ok to side and insul.
I129 01	7/13/10 7/13/10	MR AP	R*INSULATION INSPECTION VRU #: 001953082 T/S: 07/13/2010 01:37 PM MREARIC ----
R425 02	7/13/10 7/13/10	MR AP	FOUR TRADE ROUGH IN VRU #: 001953074 T/S: 07/13/2010 01:37 PM MREARIC ----
R429 01	9/30/10 9/30/10	MR DP	FOUR TRADE FINAL VRU #: 001987988 T/S: 09/30/2010 10:49 AM MREARIC ---- water heater needs lock out or disc. 4 steps are needed to garage a, handrail also T/S: 10/01/2010 11:52 AM NTART ----

PREPARED 10/01/10, 14:13:35
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 4
DATE 10/04/10

ADDRESS . : 405 FIFTY CALIBER DR SUBDIV: PATTONS POINT
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805
OWNER . . : BILL CLARK HOMES OF FAY PHONE : (910) 426-2898
PARCEL . . : 03-9597- - -0039- -16-
APPL NUMBER: 10-50023979 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
R429 02	10/04/10 <u>10/4/10</u>	TI <u>AS DJ</u>	FOUR TRADE FINAL VRU #: 001989144

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Permit Numbers

Name: Bill Clark Homes LLC

Building: _____

Address: 405 Fifty Caliber Dr

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: 10-50023979

MFG Home: _____

Date: 10/4/10

Building Official: [Signature]