
ADDRESS . . : 71 COPPER LOOP SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER . . : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
 PARCEL . . : 03-9587-13- -0020- -45-
 APPL NUMBER: 10-50024000 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/17/2010 02:42 PM JBROCK ----
 HWY 27 WEST TURN LEFT ON BUFFALO LAKE
 RD TURN LEFT ALPINE TUR NLEFT SUMMIT
 TURN RIGHT SILVERTHORNE LOT ON RIGHT
 LOT 125
 T/S: 04/06/2010 08:18 AM DJOHNSON --
 T/S: 04/06/2010 08:05 AM NTART -----

STRUCTURE: 000 000 48X40 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10 <i>4-8-10</i>	TI <i>AP-MR</i>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001906209

COMMENTS AND NOTES -----

ADDRESS : 71 COPPER LOOP
CONTRACTOR : CEBCO CONSTRUCTION INC
OWNER : KENNETH CUMMINGS LLC
PARCEL : 03-9587-13- -0020- -45-
APPL NUMBER: 10-50024000 CP NEW RESIDENTIAL (SFD)

SUBDIV: THE SUMMIT SEC3 50 LOTS
PHONE : (910) 893-3331
PHONE : (910) 893-5826

DIRECTIONS : T/S: 03/17/2010 02:42 PM JBROCK ----
HWY 27 WEST TURN LEFT ON BUFFALO LAKE
RD TURN LEFT ALPINE TUR NLEFT SUMMIT
TURN RIGHT SILVERTHORNE LOT ON RIGHT
LOT 125
T/S: 04/06/2010 08:18 AM DJOHNSON --
T/S: 04/06/2010 08:05 AM NTART -----

STRUCTURE: 000 000 48X40 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001906209
	4/08/10	AP	T/S: 04/08/2010 12:54 PM MREARIC -----
B103 01	4/13/10	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001909100
	<u>4/13/10</u>	<u>AP DJR</u>	T/S: 04/12/2010 03:07 PM NTART -----

COMMENTS AND NOTES

ADDRESS : 71 COPPER LOOP SUBDIV: THE SUMMIT SEC3 50 LOTS
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
PARCEL : 03-9587-13- -0020- -45-
APPL NUMBER: 10-50024000 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/17/2010 02:42 PM JBROCK ----
HWY 27 WEST TURN LEFT ON BUFFALO LAKE
RD TURN LEFT ALPINE TUR NLEFT SUMMIT
TURN RIGHT SILVERTHORNE LOT ON RIGHT
LOT 125
T/S: 04/06/2010 08:18 AM DJOHNSON --
T/S: 04/06/2010 08:05 AM NTART -----

STRUCTURE: 000 000 48X40 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001906209
	4/08/10	AP	T/S: 04/08/2010 12:54 PM MREARIC -----
B103 01	4/13/10	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001909100
	4/13/10	AP	T/S: 04/12/2010 03:07 PM NTART -----
B105 01	4/14/10	TI	R*OPEN FLOOR VRU #: 001909377

4-14-10 AP-MR

----- COMMENTS AND NOTES -----

ADDRESS . . : 71 COPPER LOOP
 CONTRACTOR : CEBCO CONSTRUCTION INC
 OWNER . . : KENNETH CUMMINGS LLC
 PARCEL . . : 03-9587-13- -0020- -45-
 APPL NUMBER: 10-50024000 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/17/2010 02:42 PM JBROCK ----
 HWY 27 WEST TURN LEFT ON BUFFALO LAKE
 RD TURN LEFT ALPINE TUR NLEFT SUMMIT
 TURN RIGHT SILVERTHORNE LOT ON RIGHT
 LOT 125
 T/S: 04/06/2010 08:18 AM DJOHNSON --
 T/S: 04/06/2010 08:05 AM NTART -----

STRUCTURE: 000 000 48X40 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001906209
	4/08/10	AP	T/S: 04/08/2010 12:54 PM MREARIC -----
B103 01	4/13/10	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001909100
	4/13/10	AP	T/S: 04/12/2010 03:07 PM NTART -----
B105 01	4/14/10	MR	R*OPEN FLOOR VRU #: 001909377
	4/14/10	AP	T/S: 04/14/2010 12:59 PM MREARIC -----
R425 01	4/27/10	TI	FOUR TRADE ROUGH IN VRU #: 001916449

4-27-10 4-27-10
 AP-MR

COMMENTS AND NOTES -----

ADDRESS . . : 71 COPPER LOOP SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER . . : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
 PARCEL . . : 03-9587-13- -0020- -45-
 APPL NUMBER: 10-50024000 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/17/2010 02:42 PM JBROCK ----
 HWY 27 WEST TURN LEFT ON BUFFALO LAKE
 RD TURN LEFT ALPINE TUR NLEFT SUMMIT
 TURN RIGHT SILVERTHORNE LOT ON RIGHT
 LOT 125
 T/S: 04/06/2010 08:18 AM DJOHNSON --
 T/S: 04/06/2010 08:05 AM NTART -----

STRUCTURE: 000 000 48X40 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001906209
	4/08/10	AP	T/S: 04/08/2010 12:54 PM MREARIC -----
B103 01	4/13/10	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001909100
	4/13/10	AP	T/S: 04/12/2010 03:07 PM NTART -----
B105 01	4/14/10	MR	R*OPEN FLOOR VRU #: 001909377
	4/14/10	AP	T/S: 04/14/2010 12:59 PM MREARIC -----
R425 01	4/27/10	MR	FOUR TRADE ROUGH IN VRU #: 001916449
	4/27/10	AP	T/S: 04/27/2010 12:47 PM MREARIC -----
A814 01	4/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001916467
	4/27/10	AP	71 copper loop lot 125 ----- sanford 27332
			T/S: 04/27/2010 10:01 AM TWARD -----
I129 01	5/03/10	TI	R*INSULATION INSPECTION VRU #: 001919570

5-3-10 DA-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 05-03-10

PERMIT # 10-24000

ADDRESS: 71 copper loop

VIOLATIONS:

1. Insulate all water lines in garage walls and ceiling

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS . . : 71 COPPER LOOP SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER . . . : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
 PARCEL . . . : 03-9587-13- -0020- -45-
 APPL NUMBER: 10-50024000 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/17/2010 02:42 PM JBROCK -----
 HWY 27 WEST TURN LEFT ON BUFFALO LAKE
 RD TURN LEFT ALPINE TUR NLEFT SUMMIT
 TURN RIGHT SILVERTHORNE LOT ON RIGHT
 LOT 125
 T/S: 04/06/2010 08:18 AM DJOHNSON --
 T/S: 04/06/2010 08:05 AM NTART -----

STRUCTURE: 000 000 48X40 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001906209
	4/08/10	AP	T/S: 04/08/2010 12:54 PM MREARIC -----
B103 01	4/13/10	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001909100
	4/13/10	AP	T/S: 04/12/2010 03:07 PM NTART -----
B105 01	4/14/10	MR	R*OPEN FLOOR VRU #: 001909377
	4/14/10	AP	T/S: 04/14/2010 12:59 PM MREARIC -----
R425 01	4/27/10	MR	FOUR TRADE ROUGH IN VRU #: 001916449
	4/27/10	AP	T/S: 04/27/2010 12:47 PM MREARIC -----
A814 01	4/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001916467
	4/27/10	AP	71 copper loop lot 125 ----- sanford 27332 T/S: 04/27/2010 10:01 AM TWARD -----
I129 01	5/03/10	MR	R*INSULATION INSPECTION VRU #: 001919570
	5/03/10	DA	T/S: 05/03/2010 11:51 AM MREARIC ----- insulate all pipes in garage
I129 02	5/04/10	TI	R*INSULATION INSPECTION VRU #: 001920032

5-4-10 AP-MR

COMMENTS AND NOTES

ADDRESS : 71 COPPER LOOP SUBDIV: THE SUMMIT SEC3 50 LOTS
 CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
 OWNER : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
 PARCEL : 03-9587-13- -0020- -45-
 APPL NUMBER: 10-50024000 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 03/17/2010 02:42 PM JBROCK ----
 HWY 27 WEST TURN LEFT ON BUFFALO LAKE
 RD TURN LEFT ALPINE TUR NLEFT SUMMIT
 TURN RIGHT SILVERTHORNE LOT ON RIGHT
 LOT 125
 T/S: 04/06/2010 08:18 AM DJOHNSON --
 T/S: 04/06/2010 08:05 AM NTART -----

STRUCTURE: 000 000 48X40 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001906209
	4/08/10	AP	T/S: 04/08/2010 12:54 PM MREARIC -----
B103 01	4/13/10	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001909100
	4/13/10	AP	T/S: 04/12/2010 03:07 PM NTART -----
B105 01	4/14/10	MR	R*OPEN FLOOR VRU #: 001909377
	4/14/10	AP	T/S: 04/14/2010 12:59 PM MREARIC -----
R425 01	4/27/10	MR	FOUR TRADE ROUGH IN VRU #: 001916449
	4/27/10	AP	T/S: 04/27/2010 12:47 PM MREARIC -----
A814 01	4/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001916467
	4/27/10	AP	✓ 71 copper loop lot 125 ----- sanford 27332 T/S: 04/27/2010 10:01 AM TWARD -----
I129 01	5/03/10	MR	R*INSULATION INSPECTION VRU #: 001919570
	5/03/10	DA	T/S: 05/03/2010 11:51 AM MREARIC ----- insulate all pipes in garage
I129 02	5/04/10	MR	R*INSULATION INSPECTION VRU #: 001920032
	5/04/10	AP	T/S: 05/04/2010 12:34 PM MREARIC -----
H824 01	5/11/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001925304
	5/11/10	AP	T/S: 05/12/2010 10:34 AM SSTEWARD ----- T/S: 05/12/2010 10:34 AM SSTEWARD -----
R429 01	6/08/10	TI	FOUR TRADE FINAL VRU #: 001937505

6-840 DA-MR

COMMENTS AND NOTES

wood to Attic A/c

ADDRESS : 71 COPPER LOOP SUBDIV: THE SUMMIT SEC3 50 LOTS
CONTRACTOR : CEBCO CONSTRUCTION INC PHONE : (910) 893-3331
OWNER : KENNETH CUMMINGS LLC PHONE : (910) 893-5826
PARCEL : 03-9587-13- -0020- -45-
APPL NUMBER: 10-50024000 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 03/17/2010 02:42 PM JBROCK ----
HWY 27 WEST TURN LEFT ON BUFFALO LAKE
RD TURN LEFT ALPINE TUR NLEFT SUMMIT
TURN RIGHT SILVERTHORNE LOT ON RIGHT
LOT 125
T/S: 04/06/2010 08:18 AM DJOHNSON --
T/S: 04/06/2010 08:05 AM NTART -----

STRUCTURE: 000 000 48X40 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	4/08/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001906209
	4/08/10	AP	T/S: 04/08/2010 12:54 PM MREARIC -----
B103 01	4/13/10	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 001909100
	4/13/10	AP	T/S: 04/12/2010 03:07 PM NTART -----
B105 01	4/14/10	MR	R*OPEN FLOOR VRU #: 001909377
	4/14/10	AP	T/S: 04/14/2010 12:59 PM MREARIC -----
R425 01	4/27/10	MR	FOUR TRADE ROUGH IN VRU #: 001916449
	4/27/10	AP	T/S: 04/27/2010 12:47 PM MREARIC -----
A814 01	4/30/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001916467
	4/27/10	AP	✓ 71 copper loop lot 125 sanford 27332 T/S: 04/27/2010 10:01 AM TWARD -----
I129 01	5/03/10	MR	R*INSULATION INSPECTION VRU #: 001919570
	5/03/10	DA	T/S: 05/03/2010 11:51 AM MREARIC ----- insulate all pipes in garage
I129 02	5/04/10	MR	R*INSULATION INSPECTION VRU #: 001920032
	5/04/10	AP	T/S: 05/04/2010 12:34 PM MREARIC -----
H824 01	5/11/10	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001925304
	5/11/10	AP	T/S: 05/12/2010 10:34 AM SSTEWARD ----- T/S: 05/12/2010 10:34 AM SSTEWARD -----
R429 01	6/08/10	MR	FOUR TRADE FINAL VRU #: 001937505
	6/08/10	DA	T/S: 06/08/2010 12:39 PM MREARIC ----- just need a wood walkway to attic ac
R429 02	6/09/10	TT	FOUR TRADE FINAL VRU #: 001938078

6-9-10
AP

COMMENTS AND NOTES

FS

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: V HOME

Permit Numbers

Name: KENNETH CUMMINGS

Building: D.S. 24000

Address: 171 COPPER LOOP
SAFFORD 27532

Electrical: D.S. 24000

Insulation: D.S. 24000

Plumbing: D.S. 24000

Mechanical: D.S. 24000

MEG Home: _____

Date: 6-9-10

Building Official: [Signature]