

HTE# 10-5-24079

Harnett County Department of Public Health

25734

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Barbara Wilson PROPERTY LOCATION: 521418 RIVER RD
 NEW REPAIR EXPANSION SUBDIVISION Regal Crest LOT # 11
 Type of Structure: SFD Site Improvements required prior to Construction Authorization Issuance:
 Proposed Wastewater System Type: 25% REDUCTION System "Accepted"
 Projected Daily Flow: 480 GPD
 Number of bedrooms: 4 Number of Occupants: 8 max
 Basement Yes No
 Pump Required: Yes No May be required based on final location and elevations of facilities
 Type of Water Supply: Community Public Well Distance from well _____ feet Permit valid for: Five years
 Permit conditions: NO ERAGATION IN SYSTEM + Repair AREA. No expiration

Authorized State Agent: James E. Markert Date: 4-6-10 SEE ATTACHED SITE SKETCH
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Barbara Wilson PROPERTY LOCATION: 521418 RIVER RD
 Facility Type: SFD New Expansion Repair
 Basement? Yes No Basement Fixtures? Yes No
 Type of Wastewater System** "Accepted" 25% REDUCTION System (Initial) Wastewater Flow: 480 GPD
 (See note below, if applicable)

Accepted 25% REDUCTION System (Repair)
Installation Requirements/Conditions
 Septic Tank Size 1200 gallons Number of trenches 4
 Pump Tank Size _____ gallons Exact length of each trench 90 feet Trench Spacing: 9 Feet on Center
 Trenches shall be installed on contour at a Soil Cover: 6 inches
 Maximum Trench Depth of: 24-22-18 inches (Maximum soil cover shall not exceed
 (Trench bottoms shall be level to +/- 1/4" 36" above the trench bottom)
 in all directions)
 Pump Requirements: _____ ft. TDH vs. _____ GPM Aggregate Depth: 6 inches below pipe
2 inches above pipe
 Conditions: Septic Tank TO BE 15' OFF of Swimming 12 inches total
POOL - MINIMUM

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.

SEE ATTACHED SITE SKETCH

Authorized State Agent: James E. Markert Date: 4-6-10
 Construction Authorization Expiration Date: 4-6-15

HTE# 10-5-24079

Permit # 25734

Harnett County Department of Public Health Site Sketch

ISSUED TO: Barbara Wilson PROPERTY LOCATION: SR 1418 RIVER RD
SUBDIVISION: Regal Crest LOT # 11

Authorized State Agent: James S. Moulton Date: 4-6-10

FUNING
BANK

150' x 100'
System Repair
* THIS AREA
TO HAVE NO
IRRIGATION LINES
WATER LINES OR
POWER LINES
LOCATED THERE

