

-----  
ADDRESS . . : 25 SWORD LOOP SUBDIV: TINGEN POINTE 86LOTS  
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
OWNER . . : WYNN CONSTRUCTION PHONE : (919) 756-3080  
PARCEL . . : 03-9576- - -0088- -13-  
APPL NUMBER: 10-50024132 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 04/07/2010 08:00 AM RDCONTE ---  
25 SWORD LOOP / TINGEN POINT #13  
TAKE 27W, T/L INTO TINGEN POINT  
-----

-----  
STRUCTURE: 000 000 50X60 CRAWL 3BD/3BA  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/30/10 <u>6:30:10</u>	TI <u>APMUR</u>	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001947932

----- COMMENTS AND NOTES -----

ADDRESS : 25 SWORD LOOP  
CONTRACTOR : WYNN CONSTRUCTION, INC.  
OWNER : WYNN CONSTRUCTION  
PARCEL : 03-9576- - 7-0088- -13-  
APPL NUMBER: 10-50024132 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 04/07/2010 08:00 AM RDCONTE ---  
25 SWORD LOOP / TINGEN POINT #13  
TAKE 27W, T/L INTO TINGEN POINT

SUBDIV: TINGEN POINTE 86LOTS  
PHONE : (919) 528-1347  
PHONE : (919) 756-3080

STRUCTURE: 000 000 50X60 CRAWL 3BD/3BA

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00  
SEPTIC - EXISTING? : NEW TANK  
PROPOSED USE : SFD  
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/30/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001947932
	6/30/10	AP	T/S: 06/30/2010 01:24 PM MREARIC
B103 01	7/06/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001949556

7-6-10 AP-MR

COMMENTS AND NOTES

#  
21910915

Fayette County

ADDRESS : 25 SWORD LOOP  
CONTRACTOR : WYNN CONSTRUCTION, INC.  
OWNER : WYNN CONSTRUCTION  
PARCEL : 03-9576- - -0088- -13-  
APPL NUMBER: 10-50024132 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 04/07/2010 08:00 AM RDCONTE ---  
25 SWORD LOOP / TINGEN POINT #13  
TAKE 27W, T/L INTO TINGEN POINT

SUBDIV: TINGEN POINTE 86LOTS  
PHONE : (919) 528-1347  
PHONE : (919) 756-3080

**STRUCTURE: 000 000 50X60 CRAWL 3BD/3BA**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3.00  
SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD  
WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/30/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001947932
	6/30/10	AP	T/S: 06/30/2010 01:24 PM MREARIC -----
B103 01	7/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001949556
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC ----- premise # 21910915
B105 01	7/09/10	TI	R*OPEN FLOOR VRU #: 001952006
	<u>7-9-10</u>	<u>AP-MR</u>	

COMMENTS AND NOTES

ADDRESS : 25 SWORD LOOP SUBDIV: TINGEN POINTE 86LOTS  
CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
OWNER : WYNN CONSTRUCTION PHONE : (919) 756-3080  
PARCEL : 03-9576- - -0088- -13-  
APPL NUMBER: 10-50024132 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 04/07/2010 08:00 AM RDCONTE ---  
25 SWORD LOOP / TINGEN POINT #13  
TAKE 27W, T/L INTO TINGEN POINT

STRUCTURE: 000 000 50X60 CRAWL 3BD/3BA  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . . : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/30/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001947932
	6/30/10	AP	T/S: 06/30/2010 01:24 PM MREARIC -----
B103 01	7/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001949556
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC ----- premise # 21910915
B105 01	7/09/10	MR	R*OPEN FLOOR VRU #: 001952006
	7/09/10	AP	T/S: 07/09/2010 02:01 PM MREARIC -----
A814 01	7/21/10	FB	ADDRESS CONFIRMATION VRU #: 001955147
	7/16/10	AP	T/S: 07/16/2010 10:24 AM FBURGESS ----- 158 OMAHA DR BROADWAY, NC 27505 LOT 13
R425 01	7/26/10	TI	FOUR TRADE ROUGH IN VRU #: 001959022

7-26-10 DA MR

----- COMMENTS AND NOTES -----

# **HARNETT COUNTY**

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

**DO NOT REMOVE**

DATE: 07-26-10

PERMIT # 10-50024132

ADDRESS: 25 sword loop

1. 1. Sheathe inside wing walls at garage door wall
2. No water in riser test
3. Ok to side and insul....Will check on insulation insp.

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 25 SWORD LOOP SUBDIV: TINGEN POINTE 86LOTS  
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
 OWNER : WYNN CONSTRUCTION PHONE : (919) 756-3080  
 PARCEL : 03-9576- - -0088- -13-  
 APPL NUMBER: 10-50024132 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 04/07/2010 08:00 AM RDCONTE ---  
 25 SWORD LOOP / TINGEN POINT #13  
 TAKE 27W, T/L INTO TINGEN POINT

**STRUCTURE: 000 000 50X60 CRAWL 3BD/3BA**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/30/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001947932
	6/30/10	AP	T/S: 06/30/2010 01:24 PM MREARIC
B103 01	7/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001949556
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC premise # 21910915
B105 01	7/09/10	MR	R*OPEN FLOOR VRU #: 001952006
	7/09/10	AP	T/S: 07/09/2010 02:01 PM MREARIC
A814 01	7/21/10	FB	ADDRESS CONFIRMATION VRU #: 001955147
	7/16/10	AP	T/S: 07/16/2010 10:24 AM FBURGESS 158 OMAHA DR BROADWAY, NC 27505 LOT 13
R425 01	7/26/10	MR	FOUR TRADE ROUGH IN VRU #: 001959022
	7/26/10	DA	T/S: 07/26/2010 12:56 PM MREARIC 1. sheath inside garage doo wing wall 2. no water in riser 3. ok to side and insul
I129 01	7/29/10	TI	R*INSULATION INSPECTION VRU #: 001960095
	7/29/10	APDC	
R425 02	7/29/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001961077
	7/29/10	AP	T/S: 07/28/2010 02:09 PM JBROCK

COMMENTS AND NOTES

ADDRESS : 25 SWORD LOOP SUBDIV: TINGEN POINTE 86LOTS  
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
 OWNER : WYNN CONSTRUCTION PHONE : (919) 756-3080  
 PARCEL : 03-9576- - -0088- -13-  
 APPL NUMBER: 10-50024132 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 04/07/2010 08:00 AM RDCONTE ---  
 25 SWORD LOOP / TINGEN POINT #13  
 TAKE 27W, T/L INTO TINGEN POINT

**STRUCTURE: 000 000 50X60 CRAWL 3BD/3BA**  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/30/10	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001947932
	6/30/10	AP	T/S: 06/30/2010 01:24 PM MREARIC
B103 01	7/06/10	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 001949556
	7/06/10	AP	T/S: 07/06/2010 12:22 PM MREARIC premise # 21910915
B105 01	7/09/10	MR	R*OPEN FLOOR VRU #: 001952006
	7/09/10	AP	T/S: 07/09/2010 02:01 PM MREARIC
A814 01	7/21/10	FB	ADDRESS CONFIRMATION VRU #: 001955147
	7/16/10	AP	T/S: 07/16/2010 10:24 AM FBURGESS ✓158 OMAHA DR BROADWAY, NC 27505 LOT 13
R425 01	7/26/10	MR	FOUR TRADE ROUGH IN VRU #: 001959022
	7/26/10	DA	T/S: 07/26/2010 12:56 PM MREARIC 1. sheath inside garage doo wing wall 2. no water in riser 3. ok to side and insul
I129 01	7/29/10	DT	R*INSULATION INSPECTION VRU #: 001960095
	7/29/10	AP	
R425 02	7/29/10	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001961077
	7/29/10	AP	T/S: 07/28/2010 02:09 PM JBROCK
H824 01	8/04/10	BM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001964147
	8/04/10	DA	PER BRYAN MCSWAIN- HOLD FOR D BOX, PUMP, ALARM, H2O LINE, PWR LINE. T/S: 08/04/2010 09:19 AM SZIMMER T/S: 08/04/2010 09:21 AM SZIMMER
H824 02	9/28/10	OT	✓ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001988062
	9/28/10	AP	T/S: 09/29/2010 09:56 AM SZIMMER T/S: 09/29/2010 09:57 AM SZIMMER
R429 01	10/01/10	TI	FOUR TRADE FINAL VRU #: 001988476

10-1-10 AP-MR

COMMENTS AND NOTES

County of Harnett  
Building Inspections Department  
Planning Services

Certificate of Compliance: x Occupancy: x

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Permit Numbers

Name: Wynn Construction

Building: 10-50024132

Electrical: 11

Address: 158 Omaha

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: \_\_\_\_\_

Date: 10-1-10

Building Official: T. Michael Rouse