
ADDRESS : 314 SCUPPERNONG LN SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : JERNIGAN STEPHEN PHONE : (919) 894-7688
 OWNER : S & K HOME BUILDERS PHONE : (910) 890-4658
 PARCEL : 11-0651- - -0057- -63-
 APPL NUMBER: 10-50024220 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/16/2010 02:09 PM JBROCK ----
 210 TOWARD ANGIER TRUN ELFT ON TRIPP RD
 S/D ON LEFT LOT 28
 T/S: 06/09/2010 10:12 AM NTART -----
 PREMISE # 00872579.....
 LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 04 PARCEL

STRUCTURE: 000 000 59X53 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/08/10	KS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001937140
	6/08/10	AP	T/S: 06/09/2010 10:13 AM NTART ----- CALLED PROGRESS ENERGY ON 06/10/10 FOR TSP @ 10:00 BY N TART.
B103 01	6/21/10	TI	R*BLDG FOUND & TEMP SVC POLE VRU #: 001943080

6-21 AP

----- COMMENTS AND NOTES -----

ADDRESS : 314 SCUPPERNONG LN SUBDIV: PLTN VINEYARD GREEN
CONTRACTOR : JERNIGAN STEPHEN PHONE : (919) 894-7688
OWNER : S & K HOME BUILDERS PHONE : (910) 890-4658
PARCEL : 11-0651- - -0057- -63-
APPL NUMBER: 10-50024220 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 04/16/2010 02:09 PM JBROCK ----
210 TOWARD ANGIER TRUN ELFT ON TRIPP RD
S/D ON LEFT LOT 28
T/S: 06/09/2010 10:12 AM NTART -----
PREMISE # 00872579.....
LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 04 PARCEL

STRUCTURE: 000 000 59X53 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/08/10 6/08/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001937140 T/S: 06/09/2010 10:13 AM NTART ----- CALLED PROGRESS ENERGY ON 06/10/10 FOR TSP @ 10:00 BY N TART.
B103 01	6/21/10 6/21/10	KS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001943080 Dampproof high end of foundation T/S: 06/21/2010 10:12 AM KSLATTUM -----
B105 01	6/24/10 6/24/10	BS AP	R*OPEN FLOOR VRU #: 001945364 T/S: June 24, 2010 10:20 AM BSUTTON -----
A814 01	6/24/10 6/23/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001943099 T/S: 06/23/2010 02:07 PM TWARD ----- 314 SCUPPERNONG LN LOT 28 LILLINGTON 27546 T/S: 06/23/2010 02:07 PM TWARD -----
R425 01	7/13/10 <u>7.13.10</u>	TI <u>DABS</u>	FOUR TRADE ROUGH IN VRU #: 001953032

----- COMMENTS AND NOTES -----

ADDRESS : 314 SCUPPERNONG LN SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : JERNIGAN STEPHEN PHONE : (919) 894-7688
 OWNER : S & K HOME BUILDERS PHONE : (910) 890-4658
 PARCEL : 11-0651- - -0057- -63-
 APPL NUMBER: 10-50024220 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/16/2010 02:09 PM JBROCK ----
 210 TOWARD ANGIER TRUN ELFT ON TRIPP RD
 S/D ON LEFT LOT 28
 T/S: 06/09/2010 10:12 AM NTART -----
 PREMISE # 00872579.....
 LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 04 PARCEL

STRUCTURE: 000 000 59X53 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSP 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/08/10 6/08/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001937140 T/S: 06/09/2010 10:13 AM NTART ----- CALLED PROGRESS ENERGY ON 06/10/10 FOR TSP @ 10:00 BY N TART.
B103 01	6/21/10 6/21/10	KS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001943080 Dampproof high end of foundation T/S: 06/21/2010 10:12 AM KSLATTUM -----
B105 01	6/24/10 6/24/10	BS AP	R*OPEN FLOOR VRU #: 001945364 T/S: June 24, 2010 10:20 AM BSUTTON -----
A814 01	6/24/10 6/23/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001943099 T/S: 06/23/2010 02:07 PM TWARD ----- 314 SCUPPERNONG LN LOT 28 LILLINGTON 27546 T/S: 06/23/2010 02:07 PM TWARD -----
R425 01	7/13/10 7/13/10	DS DA	FOUR TRADE ROUGH IN VRU #: 001953032 1. Rodentproof hole where HVAC lineset penetrates floor behind hall tub. Rodentproofing must be 3/4 wood cut to fit tight or metal. Firecaulk. 2. No insulation baffles in cathdrals. ③ Install fireplace, run gas line and test. Gas line must be installed out to its final location. (no short stubouts) OK to side DO NOT INSULATE
R425 02	7/15/10 7-15	TI AE	FOUR TRADE ROUGH IN VRU #: 001954415

Not Done

COMMENTS AND NOTES

ADDRESS . . : 314 SCUPPERNONG LN SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : JERNIGAN STEPHEN PHONE : (919) 894-7688
 OWNER . . . : S & K HOME BUILDERS PHONE : (910) 890-4658
 PARCEL . . . : 11-0651- - -0057- -63-
 APPL NUMBER: 10-50024220 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/16/2010 02:09 PM JBROCK ----
 210 TOWARD ANGIER TRUN ELFT ON TRIPP RD
 S/D ON LEFT LOT 28
 T/S: 06/09/2010 10:12 AM NTART -----
 PREMISE # 00872579.....
 LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 04 PARCEL

STRUCTURE: 000 000 59X53 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/08/10 6/08/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001937140 T/S: 06/09/2010 10:13 AM NTART ----- CALLED PROGRESS ENERGY ON 06/10/10 FOR TSP @ 10:00 BY N TART.
B103 01	6/21/10 6/21/10	KS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001943080 Dampproof high end of foundation T/S: 06/21/2010 10:12 AM KSLATTUM -----
B105 01	6/24/10 6/24/10	BS AP	R*OPEN FLOOR VRU #: 001945364 T/S: June 24, 2010 10:20 AM BSUTTON -----
A814 01	6/24/10 6/23/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001943099 T/S: 06/23/2010 02:07 PM TWARD ----- 314 SCUPPERNONG LN LOT 28 LILLINGTON 27546 T/S: 06/23/2010 02:07 PM TWARD -----
R425 01	7/13/10 7/13/10	BS DA	FOUR TRADE ROUGH IN VRU #: 001953032 1. Rodentproof hole where HVAC lineset penetrates floor behind hall tub. Rodentproofing must be 3/4 wood cut to fit tight or metal. Firecaulk. 2. No insulation baffles in cathdrals. 3. Install fireplace, run gas line and test. Gas line must be installed out to its final location. (no short stubouts) OK to side DO NOT INSULATE
R425 02	7/15/10 7/15/10	KS AE	FOUR TRADE ROUGH IN VRU #: 001954415 Gas line not installed nor tested. OK to insulate T/S: 07/15/2010 01:36 PM KSLATTUM -----
I129 01	7/21/10 <u>7-21</u>	TI <u>AP</u>	R*INSULATION INSPECTION VRU #: 001956761

----- COMMENTS AND NOTES -----

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Permit Numbers

Name: S&K Home Builders

Building: 10-50024220

Address: 314 Scuppernong Lane

Electrical: 10-50024220

Lillington NC 27546

Insulation: 10-50024220

Plumbing: 10-50024220

Mechanical: 10-50024220

MFG Home: NANANANANANA

Date: 10-12-2010

Building Official: BSutton

ADDRESS : 314 SCUPPERNONG LN SUBDIV: PLTN VINEYARD GREEN
 CONTRACTOR : JERNIGAN STEPHEN PHONE : (919) 894-7688
 OWNER : S & K HOME BUILDERS PHONE : (910) 890-4658
 PARCEL : 11-0651- - -0057- -63-
 APPL NUMBER: 10-50024220 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 04/16/2010 02:09 PM JBROCK ----
 210 TOWARD ANGIER TRUN ELFT ON TRIPP RD
 S/D ON LEFT LOT 28
 T/S: 06/09/2010 10:12 AM NTART -----
 PREMISE # 00872579.....
 LAND NOTES : LXMN 10/05/04 SPLIT FROM THE 04 PARCEL

STRUCTURE: 000 000 59X53 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	6/08/10 6/08/10	KS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 001937140 T/S: 06/09/2010 10:13 AM NTART ----- CALLED PROGRESS ENERGY ON 06/10/10 FOR TSP @ 10:00 BY N TART.
B103 01	6/21/10 6/21/10	KS AE	R*BLDG FOUND & TEMP SVC POLE VRU #: 001943080 Dampproof high end of foundation T/S: 06/21/2010 10:12 AM KSLATTUM -----
B105 01	6/24/10 6/24/10	BS AP	R*OPEN FLOOR VRU #: 001945364 T/S: June 24, 2010 10:20 AM BSUTTON -----
A814 01	6/24/10 6/23/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001943099 T/S: 06/23/2010 02:07 PM TWARD ----- ✓ 314 SCUPPERNONG LN LOT 28 LILLINGTON 27546 T/S: 06/23/2010 02:07 PM TWARD -----
R425 01	7/13/10 7/13/10	BS DA	FOUR TRADE ROUGH IN VRU #: 001953032 1. Rodentproof hole where HVAC lineset penetrates floor behind hall tub. Rodentproofing must be 3/4 wood cut to fit tight or metal. Firecaulk. 2. No insulation baffles in cathdrals. 3. Install fireplace, run gas line and test. Gas line must be installed out to its final location. (no short stubouts) OK to side DO NOT INSULATE
R425 02	7/15/10 7/15/10	KS AE	FOUR TRADE ROUGH IN VRU #: 001954415 Gas line not installed nor tested. OK to insulate T/S: 07/15/2010 01:36 PM KSLATTUM -----
I129 01	7/21/10 7/21/10	KS AP	R*INSULATION INSPECTION VRU #: 001956761 Test on gas line OK--fireplace installed T/S: 07/21/2010 01:57 PM KSLATTUM -----
H824 01	8/31/10 8/31/10	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001977412 T/S: 09/01/2010 12:03 PM SZIMMER ----- T/S: 09/01/2010 12:04 PM SZIMMER -----
R429 01	10/12/10 <u>10-12-10</u>	TI <u>APBS</u>	FOUR TRADE FINAL VRU #: 001992446 VOICE MESSAGE LEFT

COMMENTS AND NOTES