26114

HTE# 10-5-247221R


Harnett county Department of Public Hearin

Improvement Permit

PROPERTY LOCATION: 12, 22 PD			
ISSUED TO: S+K Homes BLORS SUBDIVISION PLANTATION @ VINEYARD LOT # 29			
NEW X REPAIR REPAIR Site Improvements required prior to Construction Authorization Issuance: Type of Structure:			
Proposed Wastewater System Type: 25% REDUCTION SYSTEM			
Projected Daily Flow: 360 GPD			
Number of bedrooms: Number of Occupants: max			
Basement			
Pump Required: □Yes □ No ☑ May be required based on final location and elevations of facilities			
Type of Water Supply: Community Public Well Distance from well 100 feet Permit valid for: Five years			
Permit conditions:			
Authorized State Agent:: Date: 6210 SEE ATTACHED SITE SKETCH			
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This			
site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of			
the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.			
Construction Authorization			
(Required for Building Permit)			
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance			
with the attached system layout.			
ISSUED TO: S+K Homes BLORS PROPERTY LOCATION: TRIPE RD			
SUBDIVISION PLANTATION @ VINEYARD LOT # 29			
CC-(1. ' ZB')			
Basement? Yes No Basement Fixtures? Yes No			
Type of Wastewater System** 25°10 REDUCTION SYSTEM (Initial) Wastewater Flow: 360 GPD			
(See note below, if applicable			
PRETREATHER LPP (Repair)			
Installation Requirements/Conditions Number of trenches\			
Septic Tank Size 1000 gallons Exact length of each trench 225 feet Trench Spacing: Feet on Center			
Pump Tank Size gallons Trenches shall be installed on contour at a Soil Cover: 6 inches			
Maximum Trench Depth of: \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\ \\			
(Trench bottoms shall be level to $\pm \frac{1}{4}$ 36" above the trench bottom)			
in all directions)			
Aggregate Depth: inches above pipe			
Conditions: THE PERMY BASED ON PROPOSAL FROM APPLICANTS SOIL CONSUMANT, inches total			
WATER LINE MUST BEIG FROM SEPTIC SYSTEM. NO UTILITIES MAY ENCROACH ON			
Ly ITIAL OR REPAIR ARGA.			
**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.			
Owner/Legal Representative Signature: Date:			
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This			
Construction Authorization is subject to compliance with the prayision of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.			
Authorized State Agent: Date: Callo			
Construction Authorization Expiration Date: 6215			
1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1			

Harnett County Department of Public Health Site Sketch

ISSUED TO: S+K HOMES BLORS	PROPERTY LOCATON: TRIPE POPULATION PLANTATION & VINEYARD	LOT # 29
	REHS (OLIVER TOLKSDORS) Date: 6/2/10	



SCUPPERNONG LN