

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:

Address:

Date Evaluated: *6-15-10 7.8-10*

Proposed Facility: *SD*

Design Flow (.1949):

Property Size:

Location of Site:

Property Recorded:

Water Supply:

- Public Individual Well Spring Other
 Auger Boring Pit Cut
 Sewage Industrial Process Mixed

Evaluation Method:

Type of Wastewater:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>L 2.3%</i>	<i>0-18</i>	<i>SL</i>	<i>FLG2 NSWP</i>					<i>3</i>
		<i>18-36</i>	<i>SCL</i>	<i>FL 1 SBLS WP</i>	<i>32" 7.54L</i>				
2	<i>L 2%</i>	<i>0-24</i>	<i>SL</i>	<i>FLG2 NSWP</i>					<i>4</i>
		<i>24-40</i>	<i>SCL</i>	<i>FLG 1 SBLS.P.</i>	<i>36" 7.54L</i>			<i>pm</i>	
3	<i>L 2.7%</i>	<i>0-24</i>	<i>SL</i>	<i>FLG2 NSWP</i>					<i>4</i>
		<i>24-40</i>	<i>SCL</i>	<i>FLG 1 SBLS.P.</i>	<i>36" 7.54L</i>			<i>pm</i>	

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>PS</i> Evaluated By: <i>[Signature]</i> Others Present:
Available Space (.1943)	<i>✓</i>	<i>✓</i>	
System Type(s)	<i>7.6L</i>	<i>3</i>	
Site LTAR	<i>4</i>	<i>3</i>	