

SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 bedrooms Design Flow (.1949): 360 gpd
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1943 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 15-20%	0-12"	GRAVELLY SL	VFA NS/NP					
		12-30"	SBK SCL	FM SS/SR					PS.4
		30" x	PM						
2		0-10"	GRAVELLY SL	VFA NS/NP					
		10-30"	SBK SCL	FM SS/SR					PS.4
		30" x	PM						
3 PTA		0-12"	GRAVELLY SL	VFA NS/NP					
		12-34"	SBK SCL	FM SS/SR					PS.4
		34" x	PM						

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OK Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	CON	CON	
Site LTAR	.21	.17	

1 x 300' e 12"

