

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: MSP CONSTRUCTION PROPERTY LOCATION: SILVERTHORNE SUBDIVISION: THE SUMMIT LOT # 82
Type of Structure: SFD (48' x 56') REPAIR EXPANSION
Proposed Wastewater System Type: CONVENTIONAL
Projected Daily Flow: 360 GPD
Number of bedrooms: 3 Number of Occupants: 6 max
Basement: No
Pump Required: No
Type of Water Supply: Public
Permit valid for: Five years

Authorized State Agent: [Signature] Date: 5/25/10 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met.

ISSUED TO: MSP CONSTRUCTION PROPERTY LOCATION: SILVERTHORNE SUBDIVISION: THE SUMMIT LOT # 82
Facility Type: SFD (48' x 56') New
Basement? No Basement Fixtures? No
Type of Wastewater System: CONVENTIONAL (Initial) Wastewater Flow: 360 GPD

Installation Requirements/Conditions
Septic Tank Size: 1000 gallons
Pump Tank Size:
Number of trenches: 3
Exact length of each trench: 50 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 12-24 inches
Maximum Trench Depth of: 24-36 inches
Pump Requirements:
Aggregate Depth: 2 inches above pipe, 12 inches total

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: Date:

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 5/25/10
Construction Authorization Expiration Date: 5/25/15

HTE# 10-5-24385

Permit # 26103

# Harnett County Department of Public Health Site Sketch

ISSUED TO: MSR CONSTRUCTION PROPERTY LOCATOR: SILVERTHORNE  
SUBDIVISION THE SUMMIT LOT # 82

Authorized State Agent: \_\_\_\_\_ Date: \_\_\_\_\_

DRAWING  
NTS

