

Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: HOWARD BUILDERS LLC
PROPERTY LOCATION: MARKS RD
SUBDIVISION: ASHEFORD LOT # 81
NEW [X] REPAIR [] EXPANSION []
Type of Structure: SFD(56'x47')
Proposed Wastewater System Type: 25% REDUCTION SYSTEM
Projected Daily Flow: 480 GPD
Number of bedrooms: 4 Number of Occupants: 8 max
Basement [] Yes [X] No
Pump Required: [] Yes [] No [X] May be required based on final location and elevations of facilities
Type of Water Supply: [] Community [X] Public [] Well Distance from well 100 feet
Permit valid for: [X] Five years [] No expiration

Authorized State Agent: [Signature] Date: 5/17/10 SEE ATTACHED SITE SKETCH
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: HOWARD BUILDERS LLC
PROPERTY LOCATION: MARKS RD
SUBDIVISION: ASHEFORD LOT # 81
Facility Type: SFD(56'x47') [X] New [] Expansion [] Repair
Basement? [] Yes [X] No Basement Fixtures? [] Yes [X] No
Type of Wastewater System: 25% REDUCTION SYSTEM (Initial) Wastewater Flow: 480 GPD
(See note below, if applicable []) 25% REDUCTION SYSTEM (Repair)

Installation Requirements/Conditions
Septic Tank Size 1000 gallons
Pump Tank Size _____ gallons
Number of trenches 3
Exact length of each trench 70 feet
Trench Spacing: 9 Feet on Center
Soil Cover: 6-12 inches
Maximum Trench Depth of: 18-24 inches
(Pump Requirements: _____ ft. TDH vs. _____ GPM
Aggregate Depth: _____ inches below pipe
_____ inches above pipe
_____ inches total
Conditions: WATER LINE MUST BE 10' FROM SEPTIC SYSTEM. NO UTILITIES
MAY ENCROACH ON INITIAL OR REPAIR AREA

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.
Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 5/17/10
Construction Authorization Expiration Date: 5/17/15

HTE# 10-5.24405

Permit # 26045

Harnett County Department of Public Health Site Sketch

ISSUED TO: HOWARD BUNDERS LLC PROPERTY LOCATOR: MARXS RD
SUBDIVISION ASHFORD LOT # 81

Authorized State Agent: ~~REXS (OLIVER TOLKSOORF)~~ Date: 5/17/10

DRAWING
NTS

