

SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
 Address:
 Proposed Facility: 3 BEDROOM Date Evaluated: 6/15/10
 Location of Site: Design Flow (.1949): 360 GPD
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1936 Sapro Class	.1944 Restr Horiz	
1	LS 10%	0-39"	G S	VF2 NS/MP					PS 8
		39"	SP2 PM	FR SS/SP					
2		0-30"	G S	VF2 NS/MP					
		30-40"	SBK SCL	FR SS/MP					PS 5
3		0-24"	G S	VF2 NS/MP					
		24-40"	SBK SCL	FR SS/MP					PS 5
		40"	PM						

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1943)	✓	✓	Site Classification (.1948): PS
System Type(s)	95% RG	25% RPD	Evaluated By: BT
Site LTAR	15	15	Others Present: -

4x50 @ 20"