

ADDRESS : 272 GOLD CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576-01- -0088- -01-
APPL NUMBER: 10-50024595 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/10/2010 02:53 PM VBROWN ----
272 GOLD COURT, TINGEN POINT #97. 27W
3MI PAST WHHS ON LEFT.

SUBDIV: TINGEN POINTE PH 3B
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 60X60 3BDR 2BATH SFD WITH GAR SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
P309 01	7/15/10	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001954577
	<u>7-15-10</u>	<u>DA-MR</u>	T/S: 07/14/2010 01:51 PM RDCONTE

COMMENTS AND NOTES

Plumb in dirt not on it

42412019

ADDRESS : 272 GOLD CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576-01- -0088- -01-
APPL NUMBER: 10-50024595 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/10/2010 02:53 PM VBROWN ----
272 GOLD COURT, TINGEN POINT #97. 27W
3MI PAST WHHS ON LEFT.

SUBDIV: TINGEN POINTE PH 3B
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 60X60 3BDR 2BATH SFD WITH GAR SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/15/10 7/15/10	MR DA	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001954577 T/S: 07/14/2010 01:51 PM RDCONTE ----- T/S: 07/15/2010 12:22 PM MREARIC ----- plumbing must be in dirt not on it
P309 02	7/16/10 <u>7-16-10</u>	TI DA-MR <u>AP-MR</u>	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001955392 T/S: 07/15/2010 01:17 PM VBROWN -----

COMMENTS AND NOTES

uncovered drain lines

ADDRESS : 272 GOLD CT
CONTRACTOR : WYNN CONSTRUCTION, INC.
OWNER : THE HARNETT LAND GROUP II LLC
PARCEL : 03-9576-01- -0088- -01-
APPL NUMBER: 10-50024595 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/10/2010 02:53 PM VBROWN ----
272 GOLD COURT, TINGEN POINT #97. 27W
3MI PAST WHHS ON LEFT.

SUBDIV: TINGEN POINTE PH 3B
PHONE : (919) 528-1347
PHONE :

STRUCTURE: 000 000 60X60 3BDR 2BATH SFD WITH GAR SLAB

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/15/10	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001954577
	7/15/10	DA	T/S: 07/14/2010 01:51 PM RDCONTE T/S: 07/15/2010 12:22 PM MREARIC plumbing must be in dirt not on it
P309 02	7/16/10	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001955392
	7/16/10	AP	T/S: 07/15/2010 01:17 PM VBROWN T/S: 07/16/2010 01:47 PM NTART
B114 01	7/19/10	TI	R*BLDG MONOLITHIC SLAB TIME: 17:00 VRU #: 001956135
	<u>7-19-10</u>	<u>AP-MR</u>	T/S: 07/16/2010 01:38 PM NTART

COMMENTS AND NOTES

Rebar installed

Harnett County

INSPECTOR: IVR

DATE 8/06/10

ADDRESS . . : 272 GOLD CT SUBDIV: TINGEN POINTE PH 3B
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER . . : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL . . : 03-9576-01- -0088- -01-
 APPL NUMBER: 10-50024595 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/10/2010 02:53 PM VBROWN ----
 272 GOLD COURT, TINGEN POINT #97. 27W
 3MI PAST WHHS ON LEFT.

STRUCTURE: 000 000 60X60 3BDR 2BATH SFD WITH GAR SLAB

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/15/10	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001954577
	7/15/10	DA	T/S: 07/14/2010 01:51 PM RDCONTE ----- T/S: 07/15/2010 12:22 PM MREARIC ----- plumbing must be in dirt not on it
P309 02	7/16/10	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001955392
	7/16/10	AP	T/S: 07/15/2010 01:17 PM VBROWN ----- T/S: 07/16/2010 01:47 PM NTART -----
B114 01	7/19/10	MR	R*BLDG MONOLITHIC SLAB TIME: 17:00 VRU #: 001956135
	7/19/10	AP	T/S: 07/16/2010 01:38 PM NTART ----- T/S: 07/19/2010 11:22 AM MREARIC -----
A814 01	8/06/10	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001964998
			T/S: 08/05/2010 09:44 AM RDCONTE -----
R425 01	8/06/10	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001965003
	<u>8-6-10</u>	<u>DA-MR</u>	T/S: 08/05/2010 09:44 AM RDCONTE -----

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DO NOT REMOVE

DATE: 08-06-10

PERMIT # 10-50024595

ADDRESS: 272 gold

1. Provide dry prints and correct truss plans
2. Double girder beams must be shimmed in the middle with wood filler and nailed per Table 602.3(1) not hollow
3. Finish shingles and boots
4. Seal openings in slab under tubs
5. No water pressure
6. No water in riser
7. No fireplace or gas line

Harnett County Building Department

Mike Rearic cell# (910) 984- 4772

ADDRESS : 272 GOLD CT SUBDIV: TINGEN POINTE PH 3B
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576-01- -0088- -01-
 APPL NUMBER: 10-50024595 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/10/2010 02:53 PM VBROWN ----
 272 GOLD COURT, TINGEN POINT #97. 27W
 3MI PAST WHHS ON LEFT.

STRUCTURE: 000 000 60X60 3BDR 2BATH SFD WITH GAR SLAB

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/15/10 7/15/10	MR DA	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001954577 T/S: 07/14/2010 01:51 PM RDCONTE T/S: 07/15/2010 12:22 PM MREARIC plumbing must be in dirt not on it
P309 02	7/16/10 7/16/10	MR AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001955392 T/S: 07/15/2010 01:17 PM VBROWN T/S: 07/16/2010 01:47 PM NTART
B114 01	7/19/10 7/19/10	MR AP	R*BLDG MONOLITHIC SLAB TIME: 17:00 VRU #: 001956135 T/S: 07/16/2010 01:38 PM NTART T/S: 07/19/2010 11:22 AM MREARIC
A814 01	8/06/10 8/06/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001964998 T/S: 08/05/2010 09:44 AM RDCONTE 272 GOLD CT LOT 97 BROADWAY 27505 T/S: 08/06/2010 01:43 PM TWARD
R425 01	8/06/10 8/06/10	MR DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001965003 T/S: 08/05/2010 09:44 AM RDCONTE T/S: 08/06/2010 01:03 PM MREARIC provide dry prints double girder box beams must be nailed on 16" centers finish shingles and boots seal openings through slab no water tests were ready no fireplace or gas line installed
R425 02	8/09/10 <i>8-9-10</i>	TT <i>APJH</i>	FOUR TRADE ROUGH IN VRU #: 001966209

COMMENTS AND NOTES

ADDRESS : 272 GOLD CT
 CONTRACTOR : WYNN CONSTRUCTION, INC.
 OWNER : THE HARNETT LAND GROUP II LLC
 PARCEL : 03-9576-01- -0088- -01-
 APPL NUMBER: 10-50024595 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/10/2010 02:53 PM VBROWN ----
 272 GOLD COURT, TINGEN POINT #97. 27W
 3MI PAST WHHS ON LEFT.

SUBDIV: TINGEN POINTE PH 3B
 PHONE : (919) 528-1347
 PHONE :

STRUCTURE: 000 000 60X60 3BDR 2BATH SFD WITH GAR SLAB

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW TANK
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/15/10	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001954577
	7/15/10	DA	T/S: 07/14/2010 01:51 PM RDCONTE T/S: 07/15/2010 12:22 PM MREARIC plumbing must be in dirt not on it
P309 02	7/16/10	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001955392
	7/16/10	AP	T/S: 07/15/2010 01:17 PM VBROWN T/S: 07/16/2010 01:47 PM NTART
B114 01	7/19/10	MR	R*BLDG MONOLITHIC SLAB TIME: 17:00 VRU #: 001956135
	7/19/10	AP	T/S: 07/16/2010 01:38 PM NTART T/S: 07/19/2010 11:22 AM MREARIC
A814 01	8/06/10	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001964998
	8/06/10	AP	T/S: 08/05/2010 09:44 AM RDCONTE 272 GOLD CT LOT 97 BROADWAY 27505 T/S: 08/06/2010 01:43 PM TWARD
R425 01	8/06/10	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001965003
	8/06/10	DA	T/S: 08/05/2010 09:44 AM RDCONTE T/S: 08/06/2010 01:03 PM MREARIC provide dry prints double girder box beams must be nailed on 16" centers finish shingles and boots seal openings through slab no water tests were ready no fireplace or gas line installed
R425 02	8/09/10	JH	FOUR TRADE ROUGH IN VRU #: 001966209
	8/09/10	AP	
I129 01	8/11/10	TI	R*INSULATION INSPECTION VRU #: 001967697
	8/11/10	AP DT	

COMMENTS AND NOTES

ADDRESS : 272 GOLD CT SUBDIV: TINGEN POINTE PH 3B
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576-01- -0088- -01-
 APPL NUMBER: 10-50024595 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/10/2010 02:53 PM VBROWN ----
 272 GOLD COURT, TINGEN POINT #97. 27W
 3MI PAST WHHS ON LEFT.

STRUCTURE: 000 000 60X60 3BDR 2BATH SFD WITH GAR SLAB

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	7/15/10 7/15/10	MR DA	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001954577 T/S: 07/14/2010 01:51 PM RDCONTE T/S: 07/15/2010 12:22 PM MREARIC plumbing must be in dirt not on it
P309 02	7/16/10 7/16/10	MR AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 001955392 T/S: 07/15/2010 01:17 PM VBROWN T/S: 07/16/2010 01:47 PM NTART
B114 01	7/19/10 7/19/10	MR AP	R*BLDG MONOLITHIC SLAB TIME: 17:00 VRU #: 001956135 T/S: 07/16/2010 01:38 PM NTART T/S: 07/19/2010 11:22 AM MREARIC
A814 01	8/06/10 8/06/10	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 001964998 T/S: 08/05/2010 09:44 AM RDCONTE ✓ 272 GOLD CT LOT 97 BROADWAY 27505 T/S: 08/06/2010 01:43 PM TWARD
R425 01	8/06/10 8/06/10	MR DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 001965003 T/S: 08/05/2010 09:44 AM RDCONTE T/S: 08/06/2010 01:03 PM MREARIC provide dry prints double girder box beams must be nailed on 16" centers finish shingles and boots seal openings through slab no water tests were ready no fireplace or gas line installed
R425 02	8/09/10 8/09/10	JH AP	FOUR TRADE ROUGH IN VRU #: 001966209
I129 01	8/11/10 8/11/10	DT AP	R*INSULATION INSPECTION VRU #: 001967697
H824 01	8/17/10 8/16/10	OT AP	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 001971001 T/S: 08/17/2010 11:47 AM SSTEWARD T/S: 08/17/2010 11:47 AM SSTEWARD
R429 01	10/08/10	TI	FOUR TRADE FINAL VRU #: 001991009

10-B-10 AP MR

COMMENTS AND NOTES

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: X **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Name: Harnett Land Group II

Address: 272 Gold Ct

Date: 10-8-10

Building Official: T. M. E. (Rear)

Permit Numbers

Building: 10-50024595

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 11

MFG Home: _____